

Use F11 to navigate through fields.

FACILITY NAME AND PERMIT NUMBER:

Newport Wastewater Treatment Plant WA-0022322

This form is equivalent to EPA NPDES Form 3510-2A

FORM  
2A  
NPDES



## NPDES FORM 2A APPLICATION OVERVIEW

### APPLICATION OVERVIEW

Form 2A has been developed in a modular format and consists of a “Basic Application Information” packet and a “Supplemental Application Information” packet. The Basic Application Information packet is divided into two parts. All applicants must complete Parts A and C. Applicants with a design flow greater than or equal to 0.1 mgd must also complete Part B. Some applicants must also complete the Supplemental Application Information packet. The following items explain which parts of Form 2A you must complete.

### BASIC APPLICATION INFORMATION:

- A. Basic Application Information for all Applicants.** All applicants must complete questions A.1 through A.8. A treatment works that discharges effluent to surface waters of the United States must also answer questions A.9 through A.12.
- B. Additional Application Information for Applicants with a Design Flow  $\geq 0.1$  mgd.** All treatment works that have design flows greater than or equal to 0.1 million gallons per day must complete questions B.1 through B.6.
- C. Certification.** All applicants must complete Part C (Certification).

### SUPPLEMENTAL APPLICATION INFORMATION:

- D. Expanded Effluent Testing Data.** A treatment works that discharges effluent to surface waters of the United States and meets one or more of the following criteria must complete Part D (Expanded Effluent Testing Data):
  - 1. Has a design flow rate greater than or equal to 1mgd,
  - 2. Is required to have a pretreatment program (or has one in place), or
  - 3. Is otherwise required by the permitting authority to provide the information.
- E. Toxicity Testing Data.** A treatment works that meets one or more of the following criteria must complete Part E (Toxicity Testing Data):
  - 1. Has a design flow rate greater than or equal to 1 mgd,
  - 2. Is required to have a pretreatment program (or has one in place), or
  - 3. Is otherwise required by the permitting authority to submit results of toxicity testing.
- F. Industrial User Discharges and RCRA/CERCLA Wastes.** A treatment works that accepts process wastewater from any significant industrial users (SIUs) or receives RCRA or CERCLA wastes must complete Part F (Industrial User Discharges and RCRA/CERCLA Wastes). SIUs are defined as:
  - 1. All industrial users subject to Categorical Pretreatment Standards under 40 Code of Federal Regulations (CFR) 403.6 and 40 CFR Chapter I, Subchapter N (see instructions); and
  - 2. Any other industrial user that:
    - a. Discharges an average of 25,000 gallons per day or more of process wastewater to the treatment works (with certain exclusions); or
    - b. Contributes a process wastestream that makes up 5 percent or more of the average dry weather hydraulic or organic capacity of the treatment plant; or
    - c. Is designated as an SIU by the control authority.
- G. Combined Sewer Systems.** A treatment works that has a combined sewer system must complete Part G (Combined Sewer Systems).

### ALL APPLICANTS MUST COMPLETE PART C (CERTIFICATION)

To ask about the availability of this document in a format for the visually impaired, call the Water Quality Program at 360-407-6600. Persons with hearing loss can call 711 for Washington Relay Service. Persons with a speech disability can call 877-833-6341.

**FACILITY NAME AND PERMIT NUMBER:**

Newport Wastewater Treatment Plant WA-0022322

**BASIC APPLICATION INFORMATION****PART A. BASIC APPLICATION INFORMATION FOR ALL APPLICANTS:**

All treatment works must complete questions A.1 through A.8 of this Basic Application Information Packet.

**A.1. Facility Information.**

Facility Name Newport Wastewater Treatment Plant

Mailing Address 200 S Washington Avenue  
Newport, WA 99156

Contact Person Raymond D. King

Title City Administrator, Group III

Telephone Number (509) 447-5611

Facility Address 801 N Union Avenue  
(not P.O. Box) Newport, WA 99156

UBI Number 264000644

**A.2. Applicant Information.** If the applicant is different from the above, provide the following:

Applicant Name Same

Mailing Address \_\_\_\_\_

Contact Person \_\_\_\_\_

Title \_\_\_\_\_

Telephone Number ( ) \_\_\_\_\_

**Is the applicant the owner or operator (or both) of the treatment works?**☒ owner ☒ operator

Indicate whether correspondence regarding this permit should be directed to the facility or the applicant.

☐ facility ☒ applicant**A.3. Existing Environmental Permits.** Provide the permit number of any existing environmental permits that have been issued to the treatment works (include state-issued permits).

NPDES	<u>WA-0022322</u>	PSD	_____
UIC	_____	Other	_____
RCRA	_____	Other	_____

**A.4. Collection System Information.** Provide information on municipalities and areas served by the facility. Provide the name and population of each entity and, if known, provide information on the type of collection system (combined vs. separate) and its ownership (municipal, private, etc.).

Name	Population Served	Type of Collection System	Ownership
<u>City of Newport</u>	<u>2140</u>	<u>Municipal/Domestic</u>	<u>City of Newport</u>
<u>West Bonner Wtr</u>	<u>214</u>	<u>Municipal/Domestic</u>	<u>West Bonner Wtr</u>
<u>&amp; Swr District</u>	_____	_____	<u>&amp; Swr District</u>
Total population served	<u>2354</u>		

**FACILITY NAME AND PERMIT NUMBER:**

Newport Wastewater Treatment Plant WA-002232

**A.5. Indian Country.**

- a. Is the treatment works located in Indian Country?

☐ Yes ☒ No

- b. Does the treatment works discharge to a receiving water that is either in Indian Country or that is upstream from (and eventually flows through) Indian Country?

☒ Yes ☐ No**A.6. Flow.** Indicate the design flow rate of the treatment plant (i.e., the wastewater flow rate that the plant was built to handle). Also provide the average daily flow rate and maximum daily flow rate for each of the last three years. Each year's data must be based on a 12-month time period with the 12<sup>th</sup> month of "this year" occurring no more than three months prior to this application submittal.

- a. Design flow rate
- .500
- mgd

Two Years AgoLast YearThis Year

- b. Annual average daily flow rate

0.2650.2550.263

- c. Maximum daily flow rate

0.7000.7000.700**A.7. Collection System.** Indicate the type(s) of collection system(s) used by the treatment plant. Check all that apply. Also estimate the percent contribution (by miles) of each.

- ☒
- Separate sanitary sewer

100 %

- ☐
- Combined storm and sanitary sewer

                     %**A.8. Discharges and Other Disposal Methods.**

- a. Does the treatment works discharge effluent to waters of the U.S.?

☒ Yes☐ No

If yes, list how many of each of the following types of discharge points the treatment works uses:

- i. Discharges of treated effluent

100%

- ii. Discharges of untreated or partially treated effluent

                    

- iii. Combined sewer overflow points

                    

- iv. Constructed emergency overflows (prior to the headworks)

                    

- v. Other
- 

                    

- b. Does the treatment works discharge effluent to basins, ponds, or other surface impoundments that do not have outlets for discharge to waters of the U.S.?

☐ Yes☒ NoIf yes, provide the following for each surface impoundment:Location:                     

Annual average daily volume discharge to surface impoundment(s)

                     mgdIs discharge ☐ continuous or ☐ intermittent?

- c. Does the treatment works land-apply treated wastewater?

☐ Yes☒ NoIf yes, provide the following for each land application site:Location:                     Number of acres:                     

Annual average daily volume applied to site:

                     mgdIs land application ☐ continuous or ☐ intermittent?

- d. Does the treatment works discharge or transport treated or untreated wastewater to another treatment works?

☐ Yes☒ No

**FACILITY NAME AND PERMIT NUMBER:****Newport Wastewater Treatment Plant WA-0022322**

If yes, describe the mean(s) by which the wastewater from the treatment works is discharged or transported to the other treatment works (e.g., tank truck, pipe).

If transport is by a party other than the applicant, provide:

Transporter Name N/A

Mailing Address \_\_\_\_\_

Contact Person \_\_\_\_\_

Title \_\_\_\_\_

Telephone Number (\_\_\_\_) \_\_\_\_\_

For each treatment works that receives this discharge, provide the following:

Name N/A

Mailing Address \_\_\_\_\_

Contact Person \_\_\_\_\_

Title \_\_\_\_\_

Telephone Number (\_\_\_\_) \_\_\_\_\_

If known, provide the NPDES permit number of the treatment works that receives this discharge N/A

Provide the average daily flow rate from the treatment works into the receiving facility. \_\_\_\_\_ mgd

- e. Does the treatment works discharge or dispose of its wastewater in a manner not included in A.8. through A.8.d above (e.g., underground percolation, well injection): ☐ Yes ☐ No

If yes, provide the following for each disposal method:

Description of method (including location and size of site(s) if applicable):

Annual daily volume disposed by this method: \_\_\_\_\_

Is disposal through this method ☐ continuous or ☐ intermittent?

**FACILITY NAME AND PERMIT NUMBER:**

Newport Wastewater Treatment Plant WA-0022322

**WASTEWATER DISCHARGES:**

If you answered "yes" to question A.8.a, complete questions A.9 through A.12 **once for each outfall** (including bypass points) through which effluent is discharged. Do not include information on combined sewer overflows in this section. If you answered "no" to question A.8.a, go to Part B, "Additional Application Information for Applicants with a Design Flow Greater than or Equal to 0.1 mgd."

**A.9. Description of Outfall.**

- a. Outfall number DNR No. 51-078914
- b. Location 801 N Union, Newport, WA 99156  
(City or town, if applicable) (Zip Code)  
Pend Oreille Washington  
(County) (State)  
48 11' 25" N 117 02' 25" W  
(Latitude) Provide these as decimal degrees (NAD83/WGS84) (Longitude)
- c. Distance from shore (if applicable) 89 ft.
- d. Depth below surface (if applicable) 24 ft.
- e. Average daily flow rate .263 mgd
- f. Does this outfall have either an intermittent or a periodic discharge? ☐ Yes ☒ No (go to A.9.g.)
- If yes, provide the following information:
- Number f times per year discharge occurs: \_\_\_\_\_
- Average duration of each discharge: \_\_\_\_\_
- Average flow per discharge: \_\_\_\_\_ mgd
- Months in which discharge occurs: \_\_\_\_\_
- g. Is outfall equipped with a diffuser? ☒ Yes ☐ No

**A.10. Description of Receiving Waters.**

- a. Name of receiving water Pend Oreille River (WA-62-1020)
- b. Name of watershed (if known) WIRA 62 Pend Oreille  
United States Soil Conservation Service 14-digit watershed code (if known): UNK
- c. Name of State Management/River Basin (if known): Columbia River Basin  
United States Geological Survey 8-digit hydrologic cataloging unit code (if known): 17010216
- d. Critical low flow of receiving stream (if applicable)  
acute 7,700 cfs chronic 8,500 cfs
- e. Total hardness of receiving stream at critical low flow (if applicable): 18.8 mg/l of CaCO<sub>3</sub>

## FACILITY NAME AND PERMIT NUMBER:

Newport Wastewater Treatment Plant WA-0022322

## A.11. Description of Treatment

- a. What level of treatment are provided? Check all that apply.

☒ Primary☒ Secondary☐ Advanced☐ Other. Describe: \_\_\_\_\_

- b. Indicate the following removal rates (as applicable):

Design BOD5 removal or Design CBOD5 removal 90 %Design SS removal 90 %

Design P removal \_\_\_\_\_ %

Design N removal \_\_\_\_\_ %

Other \_\_\_\_\_ %

- c. What type of disinfection is used for the effluent from this outfall? If disinfection varies by season, please describe:

Chlorination 0.5 mg/L monthly 0.75 mg/L Weekly

If disinfection is by chlorination is dechlorination used for this outfall?

☐ Yes☒ No

- d. Does the treatment plant have post aeration?

☐ Yes☒ No

**A.12 Effluent Testing Information.** All Applicants that discharge to waters of the US must provide effluent testing data for the following parameters. Provide the indicated effluent testing required by the permitting authority for each outfall through which effluent is discharged. Do not include information on combined sewer overflows in this section. All information reported must be based on data collected through analysis conducted using 40 CFR Part 136 methods. In addition, this data must comply with QA/QC requirements of 40 CFR Part 136 and other appropriate QA/QC requirements for standard methods for analytes not addressed by 40 CFR Part 136. At a minimum, effluent testing data must be based on at least three samples and must be no more than one and one-half years apart.

Outfall number:

DNR No. 51-078914

PARAMETER	MAXIMUM DAILY VALUE		AVERAGE DAILY VALUE				
	Value	Units	Value	Units	Number of Samples		
pH (Minimum)	6.7	s.u.					
pH (Maximum)	7.7	s.u.					
Flow Rate	1.0	mgd	0.5	mgd	Continuous		
Temperature (Winter)	9	°C	13	°C	once a day		
Temperature (Summer)	18	°C	16	°C	once a day		
* For pH please report a minimum and a maximum daily value							
POLLUTANT	MAXIMUM DAILY DISCHARGE		AVERAGE DAILY DISCHARGE			ANALYTICAL METHOD	ML/MDL
	Conc.	Units	Conc.	Units	Number of Samples		

## CONVENTIONAL AND NON CONVENTIONAL COMPOUNDS

BIOCHEMICAL OXYGEN DEMAND (Report one)	BOD5	30/40	mg/L	5.6	mg/L	2	*5210B	mL
	CBOD5							
FECAL COLIFORM		200/400	100 mL	11	100 mL	4	*922D	mL
TOTAL SUSPENDED SOLIDS (TSS)		30/40	mg/L	4.5	mg/L	2	*922D	mL

END OF PART A.

**REFER TO THE APPLICATION OVERVIEW TO DETERMINE WHICH OTHER PARTS OF FORM 2A YOU MUST COMPLETE**

FACILITY NAME AND PERMIT NUMBER:

Newport Wastewater Treatment Plant WA-0022322

## BASIC APPLICATION INFORMATION

### PART B. ADDITIONAL APPLICATION INFORMATION FOR APPLICANTS WITH A DESIGN FLOW GREATER THAN OR EQUAL TO 0.1 MGD (100,000 gallons per day).

All applicants with a design flow rate  $\geq 0.1$  mgd must answer questions B.1 through B.6. All others go to Part C (Certification).

B.1. Inflow and Infiltration. Estimate the average number of gallons per day that flow into the treatment works from inflow and/or infiltration.

100 gpd

Briefly explain any steps underway or planned to minimize inflow and infiltration.

Sealed manhole cover, storm water system & repair and/or sewer main replacement as required

B.2. **Topographic Map.** Attach to this application a topographic map of the area extending at least one mile beyond facility property boundaries. This map must show the outline of the facility and the following information. (You may submit more than one map if one map does not show the entire area.)

- The area surrounding the treatment plant, including all unit processes.
- The major pipes or other structures through which wastewater enters the treatment works and the pipes or other structures through which treated wastewater is discharged from the treatment plant. Include outfalls from bypass piping, if applicable.
- Each well where wastewater from the treatment plant is injected underground.
- Wells, springs, other surface water bodies, and drinking water wells that are: 1) within  $\frac{1}{4}$  mile of the property boundaries of the treatment works, and 2) listed in public record or otherwise known to the applicant.
- Any areas where the sewage sludge produced by the treatment works is stored, treated, or disposed.
- If the treatment works receives waste that is classified as hazardous under the Resource Conservation and Recovery Act (RCRA) by truck, rail, or special pipe, show on the map where the hazardous waste enters the treatment works and where it is treated, stored, and/or disposed.

B.3. **Process Flow Diagram or Schematic.** Provide a diagram showing the processes of the treatment plant, including all bypass piping and all backup power sources or redundancy in the system. Also provide a water balance showing all treatment units, including disinfection (e.g., chlorination and dechlorination). The water balance must show daily average flow rates at influent and discharge points and approximate daily flow rates between treatment units. Include a brief narrative description of the diagram.

B.4. Operation/Maintenance Performed by Contractor(s).

Are any operational or maintenance aspects (related to wastewater treatment and effluent quality) of the treatment works the responsibility of a contractor? ☐ Yes ☒ No

If yes, list the name, address, telephone number, and status of each contractor and describe the contractor's responsibilities (attach additional pages if necessary).

Name: \_\_\_\_\_

Mailing Address: \_\_\_\_\_

Telephone Number: (\_\_\_\_) \_\_\_\_\_

Responsibilities of Contractor: \_\_\_\_\_

B.5. **Scheduled improvements and Schedules of Implementation.** Provide information on any uncompleted implementation schedule or uncompleted plans for improvements that will affect the wastewater treatment, effluent quality, or design capacity of the treatment works. If the treatment works has several different implementation schedules or is planning several improvements, submit separate responses to question B.5 for each. (If none, go to question B.6.)

- a. List the outfall number (assigned in question A.9) for each outfall that is covered by this implementation schedule.

DNR N. 51-078914

- b. Indicate whether the planned improvements or implementation schedule are required by local, State, or Federal agencies.

☐ Yes ☒ No

**FACILITY NAME AND PERMIT NUMBER:****Newport Wastewater Treatment Plant WA-0022322**

- c. If the answer to B.5.b is "Yes," briefly describe, including new maximum daily inflow rate (if applicable).

- d. Provide dates imposed by any compliance schedule or any actual dates of completion for the implementation steps listed below, as applicable. For improvements planned independently of local, State, or Federal agencies, indicate planned or actual completion dates, as applicable. Indicate dates as accurately as possible.

Implementation Stage	Schedule MM/DD/YYYY	Actual Completion MM/DD/YYYY
- Begin Construction	<u>      /      /      </u>	<u>      /      /      </u>
- End Construction	<u>      /      /      </u>	<u>      /      /      </u>
- Begin Discharge	<u>      /      /      </u>	<u>      /      /      </u>
- Attain Operational Level	<u>      /      /      </u>	<u>      /      /      </u>

- e. Have appropriate permits/clearances concerning other Federal/State requirements been obtained? ☐ Yes ☐ No

Describe briefly: \_\_\_\_\_

**B.6. EFFLUENT TESTING DATA (GREATER THAN 0.1 MGD ONLY).**

Applicants that discharge to waters of the US must provide effluent testing data for the following parameters. Provide the indicated effluent testing required by the permitting authority for each outfall through which effluent is discharged. Do not include information on combined sewer overflows in this section. All information reported must be based on data collected through analysis conducted using 40 CFR Part 136 methods (See attachment A). In addition, this data must comply with QA/QC requirements of 40 CFR Part 136 and other appropriate QA/QC requirements for standard methods for analytes not addressed by 40 CFR Part 136. At a minimum effluent testing data must be based on at least three pollutant scans and must be no more than four and on-half years old.

Outfall Number: **DNR No. 51-078914**

POLLUTANT	MAXIMUM DAILY DISCHARGE		AVERAGE DAILY DISCHARGE			ANALYTICAL METHOD	ML/MDL
	Conc.	Units	Conc.	Units	Number of Samples		
CONVENTIONAL AND NON CONVENTIONAL COMPOUNDS    WWTP Poll Scan #1 10-14-08							
AMMONIA (as N)	ND	Mg/L	ND	Mg/L	3	SM4500 NH3G	PQL 0.05
CHLORINE (TOTAL RESIDUAL, TRC)	0.55	Mg/L	0.50	Mg/L	3	SM4500-CL-G	PQL 0.01
DISSOLVED OXYGEN	8.30	Mg/L	0.001	Mg/L	3	SM4500 OG	PQL 0.001
TOTAL KJELDAHL NITROGEN (TKN)	1.16	Mg/L	1.16	Mg/L	3	SM4500 NORGC	PQL 0.1
NITRATE PLUS NITRITE NITROGEN	6.72	Mg/L	6.72	Mg/L	3	E{A 300.0	PQL 0.1
OIL and GREASE	ND	Mg/L	ND	Mg/L	3	EPA 1664 A	PQL 1
PHOSPHORUS (Total)	3.64	Mg/L	3.64	Mg/L	3	SM4500 PF	PQL 0.01
TOTAL DISSOLVED SOLIDS (TDS)	628	Mg/L	628	Mg/L	3	EPA 160.1	PQL 10
OTHER							

**END OF PART B.**

**REFER TO THE APPLICATION OVERVIEW TO DETERMINE WHICH OTHER PARTS OF FORM 2A YOU MUST COMPLETE**

**FACILITY NAME AND PERMIT NUMBER:****Newport Wastewater Treatment Plant WA-0022322****BASIC APPLICATION INFORMATION****PART C. CERTIFICATION**

All applicants must complete the Certification Section. Refer to instructions to determine who is an officer for the purposes of this certification. All applicants must complete all applicable sections of Form 2A, as explained in the Application Overview. Indicate below which parts of Form 2A you have completed and are submitting. By signing this certification statement, applicants confirm that they have reviewed Form 2A and have completed all sections that apply to the facility for which this application is submitted.

**Indicate which parts of Form 2A you have completed and are submitting:**☒ Basic Application Information packet

Supplemental Application Information packet:

☐ Part D (Expanded Effluent Testing Data)☐ Part E (Toxicity Testing: Biomonitoring Data)☐ Part F (Industrial User Discharges and RCRA/CERCLA Wastes)☐ Part G (Combined Sewer Systems)**ALL APPLICANTS MUST COMPLETE THE FOLLOWING CERTIFICATION.**

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Name and official title **Shirley Sands, Mayor**

Signature \_\_\_\_\_

Telephone number **(509) 447-5611**Date signed **10/26/2012**

Upon request of the permitting authority, you must submit any other information necessary to assure wastewater treatment practices at the treatment works or identify appropriate permitting requirements.

**SEND COMPLETED FORMS TO:**

FACILITY NAME AND PERMIT NUMBER:

Newport Wastewater Treatment Plant WA-0022322

## SUPPLEMENTAL APPLICATION INFORMATION

## PART D. EXPANDED EFFLUENT TESTING DATA

Refer to the directions on the cover page to determine whether this section applies to the treatment works.

**Effluent Testing: 1.0 mgd and Pretreatment Works.** If the treatment works has a design flow greater than or equal to 1.0 mgd or it has (or is required to have) a pretreatment program, or is otherwise required by the permitting authority to provide the data, then provide effluent testing data for the following pollutants. Provide the indicated effluent testing information and any other information required by the permitting authority for each outfall through which effluent is discharged. Do not include information on combined sewer overflows in this section. All information reported must be based on data collected through analyses conducted using 40 CFR Part 136 methods. In addition, these data must comply with QA/QC requirements of 40 CFR Part 136 and other appropriate QA/QC requirements for standard methods for analytes not addressed by 40 CFR Part 136. Indicate in the blank rows provided below any data you may have on pollutants not specifically listed in this form. At a minimum, effluent testing data must be based on at least three pollutant scans and must be no more than four and one-half years old. The applicant should also review Attachment A.

Outfall number: \_\_\_\_\_ (Complete once for each outfall discharging effluent to waters of the United States.)

POLLUTANT	MAXIMUM DAILY DISCHARGE				AVERAGE DAILY DISCHARGE					ANALYTICAL METHOD	ML/MDL
	Conc.	Units	Mass	Units	Conc.	Units	Mass	Units	Number of Samples		
METALS (TOTAL RECOVERABLE), CYANIDE, PHENOLS, AND HARDNESS.											
ANTIMONY											
ARSENIC											
BERYLLIUM											
CADMIUM											
CHROMIUM											
COPPER											
LEAD											
MERCURY											
NICKEL											
SELENIUM											
SILVER											
THALLIUM											
ZINC											
CYANIDE											
TOTAL PHENOLIC COMPOUNDS											
HARDNESS (AS CaCO3)											
Use this space (or a separate sheet) to provide information on other metals requested by the permit writer											

## FACILITY NAME AND PERMIT NUMBER:

Newport Wastewater Treatment Plant WA-0022322

Outfall number: \_\_\_\_\_ (Complete once for each outfall discharging effluent to waters of the United States.)

POLLUTANT	MAXIMUM DAILY DISCHARGE				AVERAGE DAILY DISCHARGE					ANALYTICAL METHOD	ML/MDL
	Conc.	Units	Mass	Units	Conc.	Units	Mass	Units	Number of Samples		
VOLATILE ORGANIC COMPOUNDS											
ACROLEIN											
ACRYLONITRILE											
BENZENE											
BROMOFORM											
CARBON TETRACHLORIDE											
CHLOROBENZENE											
CHLOROBIDBROMO-METHANE											
CHLOROETHANE											
2-CHLORO-ETHYLVINYL ETHER											
CHOLOROFORM											
DICHLOROBROMO-METHANE											
1,1-DICHLOROETHANE											
1,2-DICHLOROETHANE											
1,2-DICHLOROETHYLENE											
TRANS-1,2-DICHLORO-ETHYLENE											
1,1-DICHLOROETHYLENE											
1,2-DICHLOROPROPANE											
1,3-DICHLOROPROPYLENE											
ETHYLBENZENE											
METHYL BROMIDE											
METHYL CHLORIDE											
METHYLENE CHLORIDE											
1,1,2,2-TETRACHLORO-ETHANE											

## FACILITY NAME AND PERMIT NUMBER:

Newport Wastewater Treatment Plant WA-0022322

Outfall number: \_\_\_\_\_ (Complete once for each outfall discharging effluent to waters of the United States.)

POLLUTANT	MAXIMUM DAILY DISCHARGE				AVERAGE DAILY DISCHARGE					ANALYTICAL METHOD	ML/MDL
	Conc.	Units	Mass	Units	Conc.	Units	Mass	Units	Number of Samples		
TETRACHLORO-ETHYLENE											
TOLUENE											
1,1,1-TRICHLOROETHANE											
1,1,2-TRICHLOROETHANE											
TRICHLOROETHYLENE											
VINYL CHLORIDE											

Use this space (or a separate sheet) to provide information on other metals requested by the permit writer

--	--	--	--	--	--	--	--	--	--	--	--

## ACID-EXTRACTABLE COMPOUNDS

P-CHLORO-M-CRESOL											
2-CHLOROPHENOL											
2,4-DICHLOROPHENOL											
2,4-DIMETHYLPHENOL											
4,6-DINITRO-O-CRESOL											
2,4-DINITROPHENOL											
2-NITROPHENOL											
4-NITROPHENOL											
PENTA CHLOROPHENOL											
PHENOL											
2,4,6-TRICHLORO PHENOL											

Use this space (or a separate sheet) to provide information on other metals requested by the permit writer

--	--	--	--	--	--	--	--	--	--	--	--

## BASE-NEUTRAL COMPOUNDS

ACENAPHTHENE											
ACENAPHTYLENE											
ANTHRACENE											
BENZIDINE											

## FACILITY NAME AND PERMIT NUMBER:

Newport Wastewater Treatment Plant WA-0022322

Outfall number: \_\_\_\_\_ (Complete once for each outfall discharging effluent to waters of the United States.)

POLLUTANT	MAXIMUM DAILY DISCHARGE				AVERAGE DAILY DISCHARGE					ANALYTICAL METHOD	ML/MDL
	Conc.	Units	Mass	Units	Conc.	Units	Mass	Units	Number of Samples		
BENZO(A) ANTHRACENE											
BENZO(J)FLUORANTHENE											
BENZO(r,s,t)PENTAPHENE											
BENZO(A)PYRENE											
3,4 BENZO-FLUORANTHENE											
BENZO(GHI)PERYLENE											
BENZO(K)FLUORANTHENE											
BIS (2-CHLOROETHOXY) METHANE											
BIS (2-CHLOROETHYL)-ETHER											
BIS (2-CHLOROISOPROPYL) ETHER											
BIS (2-ETHYLHEXYL) PHTHALATE											
4-BROMOPHENYL PHENYL ETHER											
BUTYL BENZYL PHTHALATE											
2-CHLORO NAPHTHALENE											
4-CHLORPHENYL PHENYL ETHER											
CHRYSENE											
DIBENZO(a,j)ACRIDINE											
DIBENZO(a,h)ACRIDINE											
DI-N-BUTYL PHTHALATE											
DI-N-OCTYL PHTHALATE											
DIBENZO(A,H) ANTHRACENE											
1,2-DICHLORO BENZENE											
1,3-DICHLORO BENZENE											

## FACILITY NAME AND PERMIT NUMBER:

Newport Wastewater Treatment Plant WA-0022322

Outfall number: \_\_\_\_\_ (Complete once for each outfall discharging effluent to waters of the United States.)

POLLUTANT	MAXIMUM DAILY DISCHARGE				AVERAGE DAILY DISCHARGE					ANALYTICAL METHOD	ML/MDL
	Conc.	Units	Mass	Units	Conc.	Units	Mass	Units	Number of Samples		
1,4-DICHLORO BENZENE											
3,3-DICHLORO BENZIDINE											
DIETHYL PHTHALATE											
DIMETHYL PHTHALATE											
2,4-DINITROTOLUENE											
2,6-DINITROTOLUENE											
1,2-DIPHENYLHYDRAZINE											
FLUORANTHENE											
FLUORENE											
HEXACHLORO BENZENE											
HEXACHLOROBUT ADIENE											
HEXACHLOROCYCLO-PENTADIENE											
HEXA CHLOROETHANE											
INDENO(1,2,3-CD) PYRENE											
ISOPHORONE											
3-METHYL CHOLANTHRENE											
NAPHTHALENE											
NITROBENZENE											
N-NITROSODI-N-PROPYLAMINE											
N-NITROSODI-METHYLAMINE											
N-NITROSODI-PHENYLAMINE											
PERYLENE											
PHENANTHRENE											
PYRENE											
1,2,4-TRICHLOROBENZENE											
Use this space (or a separate sheet) to provide information on other metals requested by the permit writer											

**FACILITY NAME AND PERMIT NUMBER:****Newport Wastewater Treatment Plant WA-0022322**

Outfall number: \_\_\_\_\_ (Complete once for each outfall discharging effluent to waters of the United States.)

POLLUTANT	MAXIMUM DAILY DISCHARGE				AVERAGE DAILY DISCHARGE					ANALYTICAL METHOD	ML/MDL
	Conc.	Units	Mass	Units	Conc.	Units	Mass	Units	Number of Samples		

Use this space (or a separate sheet) to provide information on other metals requested by the permit writer

--	--	--	--	--	--	--	--	--	--	--	--

**END OF PART D.****REFER TO THE APPLICATION OVERVIEW TO DETERMINE WHICH OTHER PARTS OF FORM 2A YOU MUST COMPLETE**

**FACILITY NAME AND PERMIT NUMBER:**

Newport Wastewater Treatment Plant WA-0022322

**SUPPLEMENTAL APPLICATION INFORMATION****PART E. TOXICITY TESTING DATA**

POTWs meeting one or more of the following criteria must provide the results of whole effluent toxicity tests for acute or chronic toxicity for each of the facility's discharge points: 1) POTWs with a design flow rate greater than or equal to 1.0 mgd; 2) POTWs with a pretreatment program (or those that are required to have one under 40 CFR Part 403); or 3) POTWs required by the permitting authority to submit data for these parameters.

- At a minimum, these results must include quarterly testing for a 12-month period within the past 1 year using multiple species (minimum of two species), or the results from four tests performed at least annually in the four and one-half years prior to the application, provided the results show no appreciable toxicity, and testing for acute and/or chronic toxicity, depending on the range of receiving water dilution. Do not include information on combined sewer overflows in this section. All information reported must be based on data collected through analysis conducted using 40 CFR Part 136 methods. In addition, this data must comply with QA/QC requirements of 40 CFR Part 136 and other appropriate QA/QC requirements for standard methods for analytes not addressed by 40 CFR Part 136.
- In addition, submit the results of any other whole effluent toxicity tests from the past four and one-half years. If a whole effluent toxicity test conducted during the past four and one-half years revealed toxicity, provide any information on the cause of the toxicity or any results of a toxicity reduction evaluation, if one was conducted.
- If you have already submitted any of the information requested in Part E, you need not submit it again. Rather, provide the information requested in question E.4 for previously submitted information. If EPA methods were not used, report the reasons for using alternate methods. If test summaries are available that contain all of the information requested below, they may be submitted in place of Part E.

If no biomonitoring data is required, do not complete Part E. Refer to the Application Overview for directions on which other sections of the form to complete.

**E.1. Required Tests.**

Indicate the number of whole effluent toxicity tests conducted in the past four and one-half years.

☐ chronic☐ acute**E.2. Individual Test Data.** Complete the following chart for each whole effluent toxicity test conducted in the last four and one-half years. Allow one column per test (where each species constitutes a test). Copy this page if more than three tests are being reported.

Test number: \_\_\_\_\_

Test number: \_\_\_\_\_

Test number: \_\_\_\_\_

**a. Test information.**

Test Species & test method number			
Age at initiation of test			
Outfall number			
Dates sample collected			
Date test started			
Duration			

**b. Give toxicity test methods followed.**

Manual title			
Edition number and year of publication			
Page number(s)			

**c. Give the sample collection method(s) used. For multiple grab samples, indicate the number of grab samples used.**

24-Hour composite			
Grab			

**d. Indicate where the sample was taken in relation to disinfection. (Check all that apply for each.)**

Before disinfection			
After disinfection			
After dechlorination			

**FACILITY NAME AND PERMIT NUMBER:****Newport Wastewater Treatment Plant WA-0022322**

Test number: \_\_\_\_\_

Test number: \_\_\_\_\_

Test number: \_\_\_\_\_

e. Describe the point in the treatment process at which the sample was collected.

Sample was collected:

f. For each test, include whether the test was intended to assess chronic toxicity, acute toxicity, or both

Chronic toxicity

Acute toxicity

g. Provide the type of test performed.

Static

Static-renewal

Flow-through

h. Source of dilution water. If laboratory water, specify type; if receiving water, specify source.

Laboratory water

Receiving water

i. Type of dilution water. If salt water, specify "natural" or type of artificial sea salts or brine used.

Fresh water

Salt water

j. Give the percentage effluent used for all concentrations in the test series.

k. Parameters measured during the test. (State whether parameter meets test method specifications)

pH

Salinity

Temperature

Ammonia

Dissolved oxygen

l. Test Results.

Acute:

Percent survival in 100% effluent

%

%

%

LC<sub>50</sub>

95% C.I.

%

%

%

Control percent survival

%

%

%

Other (describe)

**FACILITY NAME AND PERMIT NUMBER:****Newport Wastewater Treatment Plant WA-0022322**

Chronic:

NOEC	%	%	%
IC <sub>25</sub>	%	%	%
Control percent survival	%	%	%
Other (describe)			

m. Quality Control/Quality Assurance.

Is reference toxicant data available?			
Was reference toxicant test within acceptable bounds?			
What date was reference toxicant test run (MM/DD/YYYY)?	/ /	/ /	/ /
Other (describe)			

**E.3. Toxicity Reduction Evaluation.** Is the treatment works involved in a Toxicity Reduction Evaluation?☐ Yes ☐ No

If yes, describe: \_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_**E.4. Summary of Submitted Biomonitoring Test Information.** If you have submitted biomonitoring test information, or information regarding the cause of toxicity, within the past four and one-half years, provide the dates the information was submitted to the permitting authority and a summary of the results.

Date submitted: \_\_\_\_/\_\_\_\_/\_\_\_\_ (MM/DD/YYYY)

Summary of results: (see instructions)

\_\_\_\_\_  
\_\_\_\_\_

**END OF PART E.**  
**REFER TO THE APPLICATION OVERVIEW TO DETERMINE WHICH OTHER PARTS OF FORM 2A YOU MUST COMPLETE.**

FACILITY NAME AND PERMIT NUMBER:

Newport Wastewater Treatment Plant WA-0022322

## SUPPLEMENTAL APPLICATION INFORMATION

### PART F. INDUSTRIAL USER DISCHARGES AND RCRA/CERCLA WASTES

All treatment works receiving discharges from significant industrial users or which receive RCRA, CERCLA, or other remedial wastes must complete part F.

#### GENERAL INFORMATION:

**F.1. Pretreatment program.** Does the treatment works have, or is subject to, an approved pretreatment program?

☐ Yes ☐ No

**F.2. Number of Significant Industrial Users (SIUs) and Categorical Industrial Users (CIUs).** Provide the number of each of the following types of industrial users that discharge to the treatment works.

a. Number of non-categorical SIUs. \_\_\_\_\_

b. Number of CIUs. \_\_\_\_\_

#### SIGNIFICANT INDUSTRIAL USER INFORMATION:

Supply the following information for each SIU. If more than one SIU discharges to the treatment works, copy questions F.3 through F.8 and provide the information requested for each SIU.

**F.3. Significant Industrial User Information.** Provide the name and address of each SIU discharging to the treatment works. Submit additional pages as necessary.

Name: \_\_\_\_\_

Mailing Address: \_\_\_\_\_

**F.4. Industrial Processes.** Describe all the industrial processes that affect or contribute to the SIU's discharge.

**F.5. Principal Product(s) and Raw Material(s).** Describe all of the principal processes and raw materials that affect or contribute to the SIU's discharge.

Principal product(s): \_\_\_\_\_

Raw material(s): \_\_\_\_\_

**F.6. Flow Rate.**

a. Process wastewater flow rate. Indicate the average daily volume of process wastewater discharge into the collection system in gallons per day (gpd) and whether the discharge is continuous or intermittent.

\_\_\_\_\_ gpd ( \_\_\_\_\_ continuous or \_\_\_\_\_ intermittent)

b. Non-process wastewater flow rate. Indicate the average daily volume of non-process wastewater flow discharged into the collection system in gallons per day (gpd) and whether the discharge is continuous or intermittent.

\_\_\_\_\_ gpd ( \_\_\_\_\_ continuous or \_\_\_\_\_ intermittent)

**F.7. Pretreatment Standards.** Indicate whether the SIU is subject to the following:

a. Local limits ☐ Yes ☐ No

b. Categorical pretreatment standards ☐ Yes ☐ No

If subject to categorical pretreatment standards, which category and subcategory?

**FACILITY NAME AND PERMIT NUMBER:**

Newport Wastewater Treatment Plant WA-0022322

**F.8. Problems at the Treatment Works Attributed to Waste Discharge by the SIU.** Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years?

☐ Yes ☐ No

If yes, describe each episode.

**RCRA HAZARDOUS WASTE RECEIVED BY TRUCK, RAIL, OR DEDICATED PIPELINE:**

**F.9. RCRA Waste.** Does the treatment works receive or has it in the past three years received RCRA hazardous waste by truck, rail or dedicated pipe?

☐ Yes ☐ No (go to F.12)

**F.10 Waste transport.** Method by which RCRA waste is received (check all that apply):

☐ Truck ☐ Rail ☐ Dedicated Pipe

**F.11 Waste Description.** Give EPA hazardous waste number and amount (volume or mass, specify units).

EPA Hazardous Waste NumberAmountUnits**CERCLA (SUPERFUND) WASTEWATER, RCRA REMEDIATION/CORRECTIVE ACTION WASTEWATER, AND OTHER REMEDIAL ACTIVITY WASTEWATER:**

**F.12 Remediation Waste.** Does the treatment works currently (or has it been notified that it will) receive waste from remedial activities?

☐ Yes (complete F.13 through F.15.) ☐ No

**F.13 Waste Origin.** Describe the site and type of facility at which the CERCLA/RCRA/or other remedial waste originates (or is expected to originate in the next five years).

**F.14 Pollutants.** List the hazardous constituents that are received (or are expected to be received). Include data on volume and concentration, if known. (Attach additional sheets if necessary.)

**F.15 Waste Treatment.**

a. Is this waste treated (or will be treated) prior to entering the treatment works?

☐ Yes ☐ No

If yes, describe the treatment (provide information about the removal efficiency):

b. Is the discharge (or will the discharge be) continuous or intermittent?

☐ Continuous☐ Intermittent

If intermittent, describe discharge schedule.

**END OF PART F.**

**REFER TO THE APPLICATION OVERVIEW TO DETERMINE WHICH OTHER PARTS OF FORM 2A YOU MUST COMPLETE**

**FACILITY NAME AND PERMIT NUMBER:**

Newport Wastewater Treatment Plant WA-002322

**SUPPLEMENTAL APPLICATION INFORMATION****PART G. COMBINED SEWER SYSTEMS****If the treatment works has a combined sewer system, complete Part G.****G.1. System Map.** Provide a map indicating the following: (may be included with Basic Application Information)

- All CSO discharge points.
- Sensitive use areas potentially affected by CSOs (e.g., beaches, drinking water supplies, shellfish beds, sensitive aquatic ecosystems, and outstanding natural resource waters).
- Waters that support threatened and endangered species potentially affected by CSOs.

**G.2. System Diagram.** Provide a diagram, either in the map provided in G.1 or on a separate drawing, of the combined sewer collection system that includes the following information.

- Location of major sewer trunk lines, both combined and separate sanitary.
- Locations of points where separate sanitary sewers feed into the combined sewer system.
- Locations of in-line and off-line storage structures.
- Locations of flow-regulating devices.
- Locations of pump stations.

**CSO OUTFALLS:****Complete questions G.3 through G.6 once for each CSO discharge point.****G.3 Description of Outfall.**

- Outfall number \_\_\_\_\_
- Location \_\_\_\_\_  
(city or town, if applicable) (Zip Code)  
\_\_\_\_\_  
(County) (State)  
\_\_\_\_\_  
(Latitude) (Longitude)
- Distance from shore (if applicable) \_\_\_\_\_ ft.
- Depth below surface (if applicable) \_\_\_\_\_ ft.
- Which of the following were monitored during the last year for this CSO?  
☐ Rainfall ☐ CSO pollutant concentrations ☐ CSO frequency  
☐ CSO flow volume ☐ Receiving water quality
- How many storm events were monitored during the last year? \_\_\_\_\_

**G.4. CSO Events.**

- Give the number of CSO events in the last year.  
\_\_\_\_\_ events (☐ actual or ☐ approx.)
- Give the average duration per CSO event.  
\_\_\_\_\_ hours (☐ actual or ☐ approx.)

**FACILITY NAME AND PERMIT NUMBER:**

**Newport Wastewater Treatment Plant WA-0022322**

- c. Give the average volume per CSO event.  
\_\_\_\_\_ million gallons (☐ actual or ☐ approx.)
- d. Give the minimum rainfall that caused a CSO event in the last year  
\_\_\_\_\_ Inches of rainfall

**G.5. Description of Receiving Waters.**

- a. Name of receiving water: \_\_\_\_\_
- b. Name of watershed/river/stream system: \_\_\_\_\_  
United State Soil Conservation Service 14-digit watershed code (if known): \_\_\_\_\_
- c. Name of State Management/River Basin: \_\_\_\_\_  
United States Geological Survey 8-digit hydrologic cataloging unit code (if known): \_\_\_\_\_

**G.6. CSO Operations.**

Describe any known water quality impacts on the receiving water caused by this CSO (e.g., permanent or intermittent beach closings, permanent or intermittent shell fish bed closings, fish kills, fish advisories, other recreational loss, or violation of any applicable State water quality standard).

\_\_\_\_\_  
\_\_\_\_\_

**END OF PART G.**

**REFER TO THE APPLICATION OVERVIEW TO DETERMINE WHICH OTHER PARTS OF FORM 2A YOU MUST COMPLETE.**

Additional information, if provided, will appear on the following pages.

## Attachment A

### EFFLUENT CHARACTERIZATION FOR POLLUTANTS

**THIS LIST INCLUDES USEPA REQUIRED POLLUTANTS (PRIORITY POLLUTANTS) AND SOME ECOLOGY PRIORITY TOXIC CHEMICALS (PBTs)**

Permittees should use the following table with analytical methods and levels for effluent characterization in permit applications, and applications for permit renewal. This attachment is used in conjunction with Section V, Parts A, B, and C of EPA Application Form 2C, Parts A.12, B.6, and D of EPA application form 2A. Washington State permit applications for state permits include methods on the specific form. This attachment specifies effluent characterization requirements of the Department of Ecology. For a new application, analyze your wastewater for all parameters required by the application and any additional pollutants or groups of pollutants with an X in the left column. Existing Permittees should compile the data from last year's data for parameters routinely measured. If you are a primary industry category with effluent guidelines you may have mandatory testing requirements (see Table 2C-2 of Form 2C). If you are a municipal POTW, EPA has identified mandatory testing requirements, which depend upon the design flow (see EPA form 2A).

The objectives are to reduce the number of analytical "non-detects" in applications and to measure effluent concentrations near or below criteria values where possible at a reasonable cost. If an applicant or Permittee knows that an alternate method from 40 CFR Part 136 is sufficient to produce measurable results in its effluent, then it may use that method for analysis. If the applicant uses an alternative method, as allowed above, it must report the test method, DL, and QL with the application.

Ecology PBTs are noted in bold font.

	<b>Pollutant &amp; CAS No. (if available)</b>	<b>Recommended Analytical Protocol</b>	<b>Detection (DL)<sup>2</sup> µg/L unless specified</b>	<b>Quantitation Level (QL)<sup>3</sup> µg/L unless specified</b>
<sup>1</sup>	<b>CONVENTIONALS</b>			
X	Biochemical Oxygen Demand	SM5210-B		2 mg/L
	Chemical Oxygen Demand	SM5220-D		10 mg/L
	Total Organic Carbon	SM5310-B/C/D		1 mg/L
X	Total Suspended Solids	SM2540-D		5 mg/L
X	Total Ammonia (as N)	SM4500-NH3- GH		0.3 mg/L
X	Flow	Calibrated device		
X	Dissolved oxygen	4500-OC/OG		0.2 mg/L
X	Temperature (max. 7-day avg.)	Analog recorder or Use micro- recording devices known as thermistors		0.2° C
X	pH	SM4500-H <sup>+</sup> B	N/A	N/A
<sup>1</sup>	<b>NONCONVENTIONALS</b>			
	Total Alkalinity	SM2320-B		5 mg/L as CaCo3
X	Chlorine, Total Residual	4500 Cl G		50.0
	Color	SM2120 B/C/E		10 color unit
X	Fecal Coliform	SM 9221D/E, 9222	N/A	N/A
	Fluoride (16984-48-8)	SM4500-F E	25	100
X	Nitrate-Nitrite (as N)	4500-NO3- E/F/H		100
X	Nitrogen, Total Kjeldahl (as N)	4500-NH3-C/E/FG		300
	Ortho-Phosphate (PO <sub>4</sub> as P)	4500- PE/PF	3	10
X	Phosphorus, Total (as P)	4500-PE/PF	3	10
X	Oil and Grease (HEM)	1664A	1,400	5,000
	Salinity	SM2520-B		3 PSS
	Settleable Solids	SM2540 -F		100
	Sulfate (as mg/L SO <sub>4</sub> )	SM4110-B		200
	Sulfide (as mg/L S)	4500-S <sup>2</sup> F/D/E/G		200

	Pollutant & CAS No. (if available)	Recommended Analytical Protocol	Detection (DL) <sup>2</sup> µg/L unless specified	Quantitation Level (QL) <sup>3</sup> µg/L unless specified
	Sulfite (as mg/L SO <sub>3</sub> )	SM4500-SO3B		2000
X	Total dissolved solids	SM2540 C		20 mg/L
X	Total Hardness	2340B		200 as CaCO <sub>3</sub>
	Aluminum, Total (7429-90-5)	200.8	2.0	10
	Barium Total (7440-39-3)	200.8	0.5	2.0
	BTEX (benzene +toluene + ethylbenzene + m,o,p xylenes)	EPA SW 846 8021/8260	1	2
	Boron Total (7440-42-8)	200.8	2.0	10.0
	Cobalt, Total (7440-48-4)	200.8	0.05	0.25
	Iron, Total (7439-89-6)	200.7	12.5	50
	Magnesium, Total (7439-95-4)	200.7	10	50
	Molybdenum, Total (7439-98-7)	200.8	0.1	0.5
	Manganese, Total (7439-96-5)	200.8	0.1	0.5
	NWTPH Dx <sup>4</sup>	Ecology NWTPH Dx	250	250
	NWTPH Gx <sup>5</sup>	Ecology NWTPH Gx	250	250
	Tin, Total (7440-31-5)	200.8	0.3	1.5
	Titanium, Total (7440-32-6)	200.8	0.5	2.5
1	<b>METALS, CYANIDE &amp; TOTAL PHENOLS</b>			
	Antimony, Total (7440-36-0)	200.8	0.3	1.0
	Arsenic, Total (7440-38-2)	200.8	0.1	0.5
	Beryllium, Total (7440-41-7)	200.8	0.1	0.5
	Cadmium, Total (7440-43-9)	200.8	0.05	0.25
	Chromium (hex) dissolved (18540-29-9)	SM3500-Cr EC	0.3	1.2
	Chromium, Total (7440-47-3)	200.8	0.2	1.0
	Copper, Total (7440-50-8)	200.8	0.4	2.0
	Lead, Total (7439-92-1)	200.8	0.1	0.5
	Mercury, Total (7439-97-6)	1631E	0.0002	0.0005
	Nickel, Total (7440-02-0)	200.8	0.1	0.5
	Selenium, Total (7782-49-2)	200.8	1.0	1.0
	Silver, Total (7440-22-4)	200.8	0.04	0.2
	Thallium, Total (7440-28-0)	200.8	0.09	0.36
	Zinc, Total (7440-66-6)	200.8	0.5	2.5
	Cyanide, Total (57-12-5)	335.4	2	10
	Cyanide, Weak Acid Dissociable	SM4500-CN I	2	10
	Cyanide, Free Amenable to Chlorination (Available Cyanide)	SM4500-CN G	5	10
	Phenols, Total	EPA 420.1		50
	<b>DIOXIN</b>			
	2,3,7,8-Tetra-Chlorodibenzo-P-Dioxin (176-40-16)	1613B	1.3 pg/L	5 pg/L
1	<b>VOLATILE COMPOUNDS</b>			
	Acrolein (107-02-8)	624	5	10
	Acrylonitrile (107-13-1)	624	1.0	2.0
	Benzene (71-43-2)	624	1.0	2.0
	Bromoform (75-25-2)	624	1.0	2.0
	Carbon tetrachloride (56-23-5)	624/601 or SM6230B	1.0	2.0
	Chlorobenzene (108-90-7)	624	1.0	2.0

	Pollutant & CAS No. (if available)	Recommended Analytical Protocol	Detection (DL) <sup>2</sup> µg/L unless specified	Quantitation Level (QL) <sup>3</sup> µg/L unless specified
	Chloroethane (75-00-3)	624/601	1.0	2.0
	2-Chloroethylvinyl Ether (110-75-8)	624	1.0	2.0
	Chloroform (67-66-3)	624 or SM6210B	1.0	2.0
	Dibromochloromethane (124-48-1)	624	1.0	2.0
	1,2-Dichlorobenzene (95-50-1)	624	1.9	7.6
	1,3-Dichlorobenzene (541-73-1)	624	1.9	7.6
	1,4-Dichlorobenzene (106-46-7)	624	4.4	17.6
	Dichlorobromomethane (75-27-4)	624	1.0	2.0
	1,1-Dichloroethane (75-34-3)	624	1.0	2.0
	1,2-Dichloroethane (107-06-2)	624	1.0	2.0
	1,1-Dichloroethylene (75-35-4)	624	1.0	2.0
	1,2-Dichloropropane (78-87-5)	624	1.0	2.0
	1,3-dichloropropylene (mixed isomers) (542-75-6) <sup>6</sup>	624	1.0	2.0
	Ethylbenzene (100-41-4)	624	1.0	2.0
	Methyl bromide (74-83-9) (Bromomethane)	624/601	5.0	10.0
	Methyl chloride (74-87-3) (Chloromethane)	624	1.0	2.0
	Methylene chloride (75-09-2)	624	5.0	10.0
	1,1,2,2-Tetrachloroethane (79-34-5)	624	1.9	2.0
	Tetrachloroethylene (127-18-4)	624	1.0	2.0
	Toulene (108-88-3)	624	1.0	2.0
	1,2-Trans-Dichloroethylene (156-60-5) (Ethylene dichloride)	624	1.0	2.0
	1,1,1-Trichloroethane (71-55-6)	624	1.0	2.0
	1,1,2-Trichloroethane (79-00-5)	624	1.0	2.0
	Trichloroethylene (79-01-6)	624	1.0	2.0
	Vinyl chloride (75-01-4)	624/SM6200B	1.0	2.0
	<b>ACID COMPOUNDS</b>			
	2-Chlorophenol (95-57-8)	625	1.0	2.0
	2,4-Dichlorophenol (120-83-2)	625	0.5	1.0
	2,4-Dimethylphenol (105-67-9)	625	0.5	1.0
	4,6-dinitro-o-cresol (534-52-1) (2-methyl-4,6,-dinitrophenol)	625/1625B	1.0	2.0
	2,4 dinitrophenol (51-28-5)	625	1.0	2.0
	2-Nitrophenol (88-75-5)	625	0.5	1.0
	4-nitrophenol (100-02-7)	625	0.5	1.0
	Parachlorometa cresol (59-50-7) (4-chloro-3-methylphenol)	625	1.0	2.0
	Pentachlorophenol (87-86-5)	625	0.5	1.0
	Phenol (108-95-2)	625	2.0	4.0
	2,4,6-Trichlorophenol (88-06-2)	625	2.0	4.0
	<b>BASE/NEUTRAL COMPOUNDS (compounds in bold are Ecology PBTs)</b>			
	Acenaphthene (83-32-9)	625	0.2	0.4
	Acenaphthylene (208-96-8)	625	0.3	0.6
	Anthracene (120-12-7)	625	0.3	0.6
	Benzidine (92-87-5)	625	12	24
	Benzyl butyl phthalate (85-68-7)	625	0.3	0.6
	Benzo(a)anthracene (56-55-3)	625	0.3	0.6
	Benzo(b)fluoranthene (3,4-benzofluoranthene) (205-99-2) <sup>7</sup>	610/625	0.8	1.6
	<b>Benzo(j)fluoranthene (205-82-3)<sup>7</sup></b>	625	0.5	1.0

	Pollutant & CAS No. (if available)	Recommended Analytical Protocol	Detection (DL) <sup>2</sup> µg/L unless specified	Quantitation Level (QL) <sup>3</sup> µg/L unless specified
	Benzo(k)fluoranthene (11,12-benzofluoranthene) (207-08-9) <sup>7</sup>	610/625	0.8	1.6
	<b>Benzo(r,s,t)pentaphene (189-55-9)</b>	625	0.5	1.0
	Benzo(a)pyrene (50-32-8)	610/625	0.5	1.0
	Benzo(ghi)Perylene (191-24-2)	610/625	0.5	1.0
	Bis(2-chloroethoxy)methane (111-91-1)	625	5.3	21.2
	Bis(2-chloroethyl)ether (111-44-4)	611/625	0.3	1.0
	Bis(2-chloroisopropyl)ether (39638-32-9)	625	0.3	0.6
	Bis(2-ethylhexyl)phthalate (117-81-7)	625	0.1	0.5
	4-Bromophenyl phenyl ether (101-55-3)	625	0.2	0.4
	2-Chloronaphthalene (91-58-7)	625	0.3	0.6
	4-Chlorophenyl phenyl ether (7005-72-3)	625	0.3	0.5
	Chrysene (218-01-9)	610/625	0.3	0.6
	<b>Dibenzo (a,j)acridine (224-42-0)</b>	610M/625M	2.5	10.0
	<b>Dibenzo (a,h)acridine (226-36-8)</b>	610M/625M	2.5	10.0
	Dibenzo(a-h)anthracene (53-70-3)(1,2,5,6-dibenzanthracene)	625	0.8	1.6
	Dibenzo(a,e)pyrene (192-65-4)	610M/625M	2.5	10.0
	Dibenzo(a,h)pyrene (189-64-0)	625M	2.5	10.0
	3,3-Dichlorobenzidine (91-94-1)	605/625	0.5	1.0
	Diethyl phthalate (84-66-2)	625	1.9	7.6
	Dimethyl phthalate (131-11-3)	625	1.6	6.4
	Di-n-butyl phthalate (84-74-2)	625	0.5	1.0
	2,4-dinitrotoluene (121-14-2)	609/625	0.2	0.4
	2,6-dinitrotoluene (606-20-2)	609/625	0.2	0.4
	Di-n-octyl phthalate (117-84-0)	625	0.3	0.6
	1,2-Diphenylhydrazine (as Azobenzene) (103-33-3)	1625B	5.0	20
	Fluoranthene (206-44-0)	625	0.3	0.6
	Fluorene (86-73-7)	625	0.3	0.6
	Hexachlorobenzene (118-74-1)	612/625	0.3	0.6
	Hexachlorobutadiene (87-68-3)	625	0.5	1.0
	Hexachlorocyclopentadiene (77-47-4)	1625B/625	0.5	1.0
	Hexachloroethane (67-72-1)	625	0.5	1.0
	Indeno(1,2,3-cd)Pyrene (193-39-5)	610/625	0.5	1.0
	Isophorone (78-59-1)	625	0.5	1.0
	<b>3-Methyl cholanthrene (56-49-5)</b>	625	2.0	8.0
	Naphthalene (91-20-3)	625	0.3	0.6
	Nitrobenzene (98-95-3)	625	0.5	1.0
	N-Nitrosodimethylamine (62-75-9)	607/625	2.0	4.0
	N-Nitrosodi-n-propylamine (621-64-7)	607/625	0.5	1.0
	N-Nitrosodiphenylamine (86-30-6)	625	0.5	1.0
	<b>Perylene (198-55-0)</b>	625	1.9	7.6
	Phenanthrene (85-01-8)	625	0.3	0.6
	Pyrene (129-00-0)	625	0.3	0.6
	1,2,4-Trichlorobenzene (120-82-1)	625	0.3	0.6
1	<b>PESTICIDES/PCBs</b>			
	Aldrin (309-00-2)	608	0.025	0.05
	alpha-BHC (319-84-6)	608	0.025	0.05

	<b>Pollutant &amp; CAS No. (if available)</b>	<b>Recommended Analytical Protocol</b>	<b>Detection (DL)<sup>2</sup> µg/L unless specified</b>	<b>Quantitation Level (QL)<sup>3</sup> µg/L unless specified</b>
	beta-BHC (319-85-7)	608	0.025	0.05
	gamma-BHC (58-89-9)	608	0.025	0.05
	delta-BHC (319-86-8)	608	0.025	0.05
	Chlordane (57-74-9) <sup>8</sup>	608	0.025	0.05
	4,4'-DDT (50-29-3)	608	0.025	0.05
	4,4'-DDE (72-55-9)	608	0.025	0.05
	4,4' DDD (72-54-8)	608	0.025	0.05
	Dieldrin (60-57-1)	608	0.025	0.05
	alpha-Endosulfan (959-98-8)	608	0.025	0.05
	beta-Endosulfan (33213-65-9)	608	0.025	0.05
	Endosulfan Sulfate (1031-07-8)	608	0.025	0.05
	Endrin (72-20-8)	608	0.025	0.05
	Endrin Aldehyde (7421-93-4)	608	0.025	0.05
	Heptachlor (76-44-8)	608	0.025	0.05
	Heptachlor Epoxide (1024-57-3)	608	0.025	0.05
	PCB-1242 (53469-21-9) <sup>9</sup>	608	0.25	0.5
	PCB-1254 (11097-69-1)	608	0.25	0.5
	PCB-1221 (11104-28-2)	608	0.25	0.5
	PCB-1232 (11141-16-5)	608	0.25	0.5
	PCB-1248 (12672-29-6)	608	0.25	0.5
	PCB-1260 (11096-82-5)	608	0.13	0.5
	PCB-1016 (12674-11-2) <sup>9</sup>	608	0.13	0.5
	Toxaphene (8001-35-2)	608	0.24	0.5

1. An X placed in this box means you must analyze for all pollutants in the group. This may be in addition to NPDES application requirements.
2. Detection level (DL) or detection limit means the minimum concentration of an analyte (substance) that can be measured and reported with a 99% confidence that the analyte concentration is greater than zero as determined by the procedure given in 40 CFR part 136, Appendix B.
3. QUANTITATION LEVEL (QL) also known as Minimum Level of Quantitation (ML) – The lowest level at which the entire analytical system must give a recognizable signal and acceptable calibration point for the analyte. It is equivalent to the concentration of the lowest calibration standard, assuming that all method-specified sample weights, volumes, and cleanup procedures have been employed. The QL is calculated by multiplying the MDL by 3.18 and rounding the result to the number nearest to (1,2,or 5) x 10<sup>n</sup>, where n is an integer. (64 FR 30417).  
ALSO GIVEN AS:  
The smallest detectable concentration of analyte greater than the Detection Limit (DL) where the accuracy (precision & bias) achieves the objectives of the intended purpose. (Report of the Federal Advisory Committee on Detection and Quantitation Approaches and Uses in Clean Water Act Programs Submitted to the US Environmental Protection Agency December 2007).
4. NWTPH Dx - Northwest Total Petroleum Hydrocarbons Diesel Extended Range – see <http://aww.ecology/programs/eap/Documents/labmanual.pdf>
5. NWTPH Gx - Northwest Total Petroleum Hydrocarbons Gasoline Extended Range – see <http://aww.ecology/programs/eap/Documents/labmanual.pdf>
6. 1, 3-dichloropropylene (mixed isomers) You may report this parameter as two separate parameters: cis-1, 3-dichloropropene (10061-01-5) and trans-1, 3-dichloropropene (10061-02-6).
7. Total Benzo(a)fluoranthenes - Because Benzo(b)fluoranthene, Benzo(j)fluoranthene and Benzo(k)fluoranthene co-elute you may report these three isomers as total benzo(a)fluoranthenes.
8. Chlordane – You may report alpha-chlordane (5103-71-9) and gamma-chlordane (5103-74-2) in place of chlordane (57-74-9). If you report alpha and gamma-chlordane, the DL/PQLs that apply are 0.025/0.050.
9. PCB 1016 & PCB 1242 – You may report these two PCB compounds as one parameter called PCB 1016/1242.