



WA LEAK TESTING CHECKLIST FOR UNDERGROUND STORAGE TANKS (USTS)

UST ID #: 100434
County: Benton

This checklist certifies testing activities conducted in accordance with
Chapter 173-360A WAC. Read instructions on pages 4-7.

<input type="checkbox"/> PASS - All Section VI services performed have passing results.		DATE TESTS CONDUCTED: 03/22/2021
<input checked="" type="checkbox"/> FAIL - One or more components tested in Section VI require repair and re-testing.		
I. UST FACILITY		II. CERTIFIED SERVICE PROVIDER
Facility Compliance Tag #: A0981	Service Provider Name: Keith Lawty	
UST ID #: 100434	Company Name: Northwest Tank & Environmental Services, Inc.	
Site Name: Richland Yacht Club	Address: 21120 Hwy 9 SE	
Site Address: 350 Columbia Point Drive	City: Woodinville	State: WA Zip: 98072
City: Richland	Phone: (800) 742-9620	Email: info@nwtank.com
County: Benton	ICC Certification Type: Tightness Testing ICBO- U3	
Site Phone: 509-430-8094	ICC Cert. #: 8589-U3	Exp. Date: 10/12/2022
III. UST OWNER/OPERATOR		
Name: Richland Yacht Club Phone: 509-943-6133 Email: roykeck@charter.net		
IV. UST SYSTEM INFORMATION Observations on test day.		
1. Tank ID #, as registered with Ecology or identified on ATG	1	
2. Tank Status. OP (Operational); TC (Temporary Closure)	OP	
3. Product stored, including % of alternative fuels	Regular	
4. Tank or compartment capacity (gallons)	1990	
5. Product pumping/flow method. Note as: P (Pressurized); NS (Non-safe Suction); SS (Safe Suction); Si (Siphon); GR (Gravity Fed)	Pressure	
Abbreviations for lines 5 and 6 below: Steel (ST); Fiberglass (FRP); Clad Steel (CLAD); Flexible (FLEX); Double Wall (DW); Single Wall (SW); Not Visible (NV)		
6. Tank material and construction observed	CLD	
7. Pipe material and construction observed	SWS	
V. REASON FOR SERVICES PERFORMED (Check all that apply)		
<input checked="" type="checkbox"/> Annual testing	<input type="checkbox"/> Test after install/repair	<input type="checkbox"/> Other (explain):
<input checked="" type="checkbox"/> 3-year testing	<input type="checkbox"/> Return UST system to operation	

VI. SERVICES PERFORMED			
Required: Include verification for each test performed.			
		#	
#PASS	#FAIL	REPAIRED&	PASSING
SERVICES:		DESCRIPTIONS REQUIRED: (SEE INSTRUCTIONS P. 4-7)	
ALLD Test (attach data) <div> Test method used: LDT 890 Test method cert.exp.date:10/28/2022 </div>		1	See notes in LLD testing section. Testing performed as per RP1200 standards.
Line Tightness Test (attach data) <div> Test method used: Acurite Test method cert.exp.date: 8/9/2022 </div>		1	See notes in Line Tightness testing section.
Electronic Monitoring System Tests <div> Controller.mfr/model:V-R TLS 350 Controller cert.exp.date: 11/9/2022 Monitor/controller <div>1</div> Probe <div>1</div> Sump Sensor Functionality Tank Annular Sensor Functionality </div>			See notes in Monitor Insp. section. Testing performed as per RP1200 standards. . See notes in Monitor Insp. section. Testing performed as per RP1200 standards. See notes in Monitor Insp. section. Testing performed as per RP1200 standards.
OverfillEquipment Test <div> <input type="checkbox"/> Auto shutoff <input checked="" type="checkbox"/> Ball float valve <input type="checkbox"/> Overfill alarm </div>		1	See notes in Job Log, attached form. Testing performed as per RP1200 standards.
Fill/Spill Bucket Test (attach data)		1	See notes in Sump Test testing section. Testing performed as per RP1200 standards.
Tank-Top or Transition Sump Test (attach data)			
UDC Sump Test (attach data)			
Tank Tightness Test (attach data) <div> 3rd-party certified test: Test method used: N/A Test method cert.exp.date: </div>			
Other			
VII. EXPLANATIONS/PROBLEMS ENCOUNTERED:			
Provide additional test information. Explain irregularities. Describe problems encountered and how addressed..			
Leak Detector: Comments - Line Leak Detector testing performed as per RP1200 standards. Performed LLD testing for sole grade/tank at single dispenser on boat dock. Line Test: Comments - Line Tightness testing performed at functional element on turbine. Sump Test: Comments - Hydrostatic testing of Fill Spill Bucket performed as per RP1200 standards.			

Cleaned bucket after testing.

Tank Monitor:

--Tank_monitors--

#1: 3/22/2021:

Testing of all monitoring equipment performed as per RP1200 standards.

Removed one ATG probe to clean, inspect, and test; working.

Verified the following alarms for 1 ATG probe:

- High Water Warning
- High Water Alarm
- Overfill Alarm
- High Product Alarm


Battery tested; within spec.

No sensors on site.

Compared manual fuel level reading with that from the monitor.

VIII. UST SITE AND SYSTEM DIAGRAM

Diagram required. Include North arrow.



PERSONS SUBMITTING FALSE INFORMATION ARE SUBJECT TO FORMAL ENFORCEMENT AND/OR PENALTIES UNDER CHAPTER 173-360A WAC.

IX. FINAL CHECK

Mark the following:

YES NO N/A

1. All checked services tested per recommended practices, code and/or manufacturer's requirements, and in accordance with state regulations.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2. Owner/operator provided with copy of the checklist and testing results.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3. Any faulty equipment or necessary repairs explained to owner/operator or site contact.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

X. REQUIRED SIGNATURES

03/22/2021

Keith Lawty

Keith Lawty - Tech

Date

Signature of Certified Service Provider

Print or Type Name

Kim DeTienne

Kim DeTienne

03/22/2021

Date

Signature of Tank Owner or Authorized Representative

Print or Type Name

Monitoring System Certification

This form must be used to document testing and servicing of monitoring equipment. A separate certification or report must be prepared for each monitoring system control panel by the technician who performs the work. A copy of this form must be provided to the tank system owner/operator. The owner/operator must submit a copy of this form to the local agency regulating UST systems within 30 days of test date.

A. General Information

Facility Contact Person: Kim Detienne

Make / Model Monitoring System: V-R TLS 300

Company Name: Richland Yacht Club

Site Address: 350 Columbia Point Drive

UST Site ID: 100434

Date Of Testing: 03/22/2021

Site Name: Richland Yacht Club

City, State, ZIP: Richland, WA 99352-4370

Facility Phone Number: 509-430-8094

Serial #: F11178195805001

B. Inventory of Equipment Tested/Certified

Tank #: 1 Regular	
In-Tank Gauging Probe	Mag 1 Probe
Annular Space or Vault Sensor:	N/A
Piping Sump / Trench Sensor:	N/A
Fill Sump Sensor:	N/A
Mechanical Line Leak Detector:	FX1V
Electronic Line Leak Detector:	N/A
Tank Overfill / High Level Sensor:	OPW BF
Other:	

Dispenser ID:	1
Dispenser Containment Sensors Model:	N/A
Shear Valves: Yes	Floats & Chains: No

C. Certification

I certify that the equipment identified in this document was inspected/serviced in accordance with the manufacturers' guidelines. Attached to this certification is information (e.g. manufacturers' checklists) necessary to verify that this information is correct and a Plot Plan showing the layout of monitoring equipment. For any equipment capable of generating such reports, I have also attached a copy of the report (check all that apply):

Technician Name: Keith Lawty

Certification Number:

Expiration Date:

Signature:



Testing Company Name: Northwest Tank & Environmental Services, Inc.

Address: 21120 Hwy 9 SE Woodinville, WA 98072

Date of Testing: 03/22/2021

D. Results of Testing/Service

Yes	Is the audible alarm operational?
Yes	Is the visual alarm operational?
Yes	Were all sensors visually inspected, functionally tested, and confirmed operational?
N/A	If alarms are relayed to a remote monitoring station, is all communications equipment operational?
N/A	For pressurized piping systems, does the turbine automatically shut down if the piping secondary containment monitoring system detects a leak, fails to operate, or is electrically disconnected?
N/A	If yes: which sensors initiate positive shut-down?
N/A	Did you confirm positive shut-down due to leaks and sensor failure/disconnection?
N/A	For tank systems that utilize the monitoring system as the primary tank overfill warning device (i.e. no mechanical overfill prevention valve is installed), is the overfill warning alarm visible and audible at the tank fill point(s) and operating properly?
N/A	If so, at what percent of tank capacity does the alarm trigger?
No	Was any monitoring equipment replaced? If yes, identify specific sensors, probes or other equipment replaced and list the manufacturer name and model for all replacement parts in Section E below.
No	Was liquid found in any secondary containment systems designed as dry systems?
N/A	If yes, what type of liquid?
Yes	Was monitoring system set-up reviewed to ensure proper settings? Attach setup reports, if applicable.
Yes	Is all monitoring equipment operational per manufacturers specifications?

In section E. below, describe how and when these deficiencies were or will be corrected.

E. Comments

3/22/2021: Testing of all monitoring equipment performed as per RP1200 standards. Removed one ATG probe to clean, inspect, and test; working. Verified the following alarms for 1 ATG probe: -High Water Warning -High Water Alarm -Overfill Alarm -High Product Alarm Battery tested; within spec. No sensors on site. Compared manual fuel level reading with that from the monitor.

State Tank ID	Product	Manual Stick Readings(inches)	Gauge Readings(inches)	Difference
1	Regular	55.75	55.68	.07

F. In-Tank Gauging / SIR Equipment

This section must be completed if in-tank gauging equipment is used to perform leak detection monitoring.

Yes	Has all input wiring been inspected for proper entry and termination, including testing for ground faults?
Yes	Were all tank gauging probes visually inspected for damage and residue buildup?
Yes	Was accuracy of system product level readings tested?
Yes	Was accuracy of system water level readings tested?
Yes	Were all probes reinstalled properly?
Yes	Were all items on the equipment manufacturer's maintenance checklist completed?

G. Line Leak Detectors (LLD):

Yes	For equipment startup or annual equipment certification, was leak simulated to verify LLD performance?
3 GPH	Leak Rate
Yes	Were all LLDs confirmed operational and accurate within regulatory requirements?
Yes	Was the testing apparatus properly calibrated?
Yes	For mechanical LLDs, does the LLD restrict product flow if it detects a leak?
N/A	For electronic LLDs, does the turbine automatically shut off if the LLD detects a leak?
N/A	For electronic LLDs, does the turbine automatically shut off if any portion of the monitoring system is disabled or disconnected?
N/A	For electronic LLDs, does the turbine automatically shut off if any portion of the monitoring system malfunctions or fails a test?
N/A	For electronic LLDs, have all accessible wiring connections been visually inspected?
Yes	Were all items on the equipment manufacturer's maintenance checklist completed?

Automatic Line Leak Detector Test Results

Company Name: Richland Yacht Club
Site Name: Richland Yacht Club
Address: 350 Columbia Point Drive Richland, WA 99352-4370
UST Site ID: 100434
Test Date/Time: 03/22/2021 07:53:34 am

Job ID Number: 98374
Technician Name: Keith Lawty
License Number: 8589-U3
Expiration Date: 10/12/2022

Product: Regular	Make: Red Jacket	Operating Pressure: 29	Result: Pass
Tank ID: 1	Model: FX1V	Holding Pressure: 28	
LD Type: Mechanical	Serial#: 5910	Bleedback (ml): 975	
Additional Data For Mechanical Leak Detectors Only			
Metering Pressure: 13			
Step Through Time: 5			

Leak detector testing conducted in accordance with the procedures and limitations of the LDT 890 leak detector tester. A leak is simulated at the highest point in the line using the LDT 890 calibrated to 3 gph at a metering pressure of 10 psi. The owner or operator of the UST system is required to ensure any failed leak detector is replaced before placing the line back in service.

The results of any sampling, testing, or monitoring shall be maintained for at least five years, or for another reasonable period of time determined by the department or delegated agency, except that the results of tank tightness testing conducted in accordance with CFR 40 Part 280.44 shall be retained until the next test is conducted.

Comments: Line Leak Detector testing performed as per RP1200 standards. Performed LLD testing for sole grade/tank at single dispenser on boat dock.

Technician Name: Keith Lawty
Signature:



Date: 03/22/2021

Line Tightness Test Results

Company Name: Richland Yacht Club
Site Name: Richland Yacht Club
Address: 350 Columbia Point Drive Richland, WA 99352-4370
UST Site ID: 100434
Test Date: 03/22/2021

Job ID Number: 98374
Technician Name: Keith Lawty
License Number: 8589-U3
Expiration Date: 10/12/2022

Line Tightness Test Data

Product:	Regular	Tank ID:	1	Start Time:	09:28
Approx Length:	300	STP MFG:	FE Petro 3/4 HP	End Time:	09:58
Size:	1.5	Operating Pressure:	29	Total Test Time:	30mins
Line Material:	SWS	Test Pressure:	44	Final Leak Rate:	.00000
Wall Type:	SW	Isolation Dispenser:	Impact Valve	Impact Valves Operational:	Yes
Boot Back:	N/A	Isolation Pump:	Check Valve	Check Valve Location:	N/A
Line Type:	Pressure	Initial Cylinder Level:	0.0750	Result:	Pass
		Final Cylinder Level:	0.0750		

Line tightness testing conducted in accordance with the procedures and limitations of the Acurite pipeline tester. A consistent leak rate of .01 gph or higher at 150% of normal operating pressure is considered a failure. The owner or operator of the UST system is required to report all failures to the appropriate agency within 24 hours.

The results of any sampling, testing, or monitoring shall be maintained for at least five years, or for another reasonable period of time determined by the department or delegated agency, except that the results of tank tightness testing conducted in accordance with CFR 40 Part 280.44 shall be retained until the next test is conducted.

Comments: Line Tightness testing performed at functional element on turbine.

Technician Name: Keith Lawty

Signature:



Date: 03/22/2021

Certificate Of Precision Containment Sump Testing

Company Name: Richland Yacht Club
Site Name: Richland Yacht Club
Address: 350 Columbia Point Drive Richland, WA
99352-4370
Test Date/Time: 03/22/2021 04:00:00 pm
Service Order#: 98374
Customer PO#: COD
Test Method: Hydrostatic
UST Site ID: 100434

Testing Company Name: Northwest Tank & Environmental Services, Inc.
Address: 21120 Hwy 9 SE
City/State/Zip: Woodinville, WA 98072
PH: (800) 742-9620 FAX: (425) 645-7881
<http://www.nwtank.com>

Test #	Component Location	MFR	Start Time	End Time	Start Test (inches)	End Test (inches)	Sump Type	SW or DW Sump/Bucket	DW or SW Lines	Measured Loss	Results
1	T1(Unl.)	EBW	08:32:00	09:32:00	11:00	11:00	Fill Spill Bucket	SW	SW	0	Pass

Comments:

Hydrostatic testing of Fill Spill Bucket performed as per RP1200 standards. Cleaned bucket after testing.

Testing performed by: Keith Lawty

Signature:



Date: 03/22/2021

UST OVERFILL EQUIPMENT INSPECTION AUTOMATIC SHUTOFF DEVICE AND BALL FLOAT VALVE

Facility Name: <u>Richland Yacht Club</u>	Owner:
Address: <u>350 Columbia Pt. Dr.</u>	Address:
City, State, Zip Code: <u>Richland, WA 99352</u>	City, State, Zip Code:
Facility I.D. #:	Phone #:
Testing Company: <u>Northwest Tank</u>	Phone #: <u> </u> Date: <u> </u>

This data sheet is for inspecting automatic shutoff devices and ball float valves. See PEI/RP1200, Section 7 for inspection procedures.

Product Grade	<u>NE-92</u>					
Tank Number	<u>1</u>					
Tank Volume, gallons	<u>1990</u>					
Tank Diameter, inches	<u>64"</u>					
Overfill Prevention Device Brand	<u>OPW BF</u>					
Type	<input type="checkbox"/> Automatic Shutoff Device <input checked="" type="checkbox"/> Ball Float Valve	<input type="checkbox"/> Automatic Shutoff Device <input type="checkbox"/> Ball Float Valve	<input type="checkbox"/> Automatic Shutoff Device <input type="checkbox"/> Ball Float Valve	<input type="checkbox"/> Automatic Shutoff Device <input type="checkbox"/> Ball Float Valve	<input type="checkbox"/> Automatic Shutoff Device <input type="checkbox"/> Ball Float Valve	<input type="checkbox"/> Automatic Shutoff Device <input type="checkbox"/> Ball Float Valve

AUTOMATIC SHUTOFF DEVICE INSPECTION

1. Drop tube removed from tank?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
2. Drop tube and float mechanisms are free of debris?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
3. Float moves freely without binding and poppet moves into flow path?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
4. Bypass valve in the drop tube is open and free of blockage (if present)?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Not Present	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Not Present	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Not Present	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Not Present	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Not Present	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Not Present
5. Flapper is adjusted to shut off flow at 95% capacity?*	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No

A "No" to any item in Lines 1-5 indicates a test failure.

BALL FLOAT VALVE INSPECTION

1. Tank top fittings are vapor-tight and leak-free?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
2. Ball float cage free of debris?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
3. Ball is free of holes and cracks and moves freely in cage?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
4. Vent hole in pipe is open and near top of tank?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
5. Ball float pipe is proper length to restrict flow at 90% capacity?*	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No

A "No" to any item in Lines 1-5 indicates a test failure.

Test Results	<input type="checkbox"/> Pass <input checked="" type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail
--------------	--	---	---	---	---	---

* Use manufacturer's suggested procedure for determining if automatic shutoff device will shut off flow at 95% capacity.

** Use manufacturer's suggested procedure for determining if flow restriction device will restrict flow at 90% capacity.

Comments: Shutoff occurs after 90%.

Tester's Name Keith Lowly Tester's Signature [Signature]