



GALVANIC CATHODIC PROTECTION EVALUATION CHECKLIST

UST ID #: 97436

County : Whatcom

FOR Underground Storage Tanks

This checklist certifies that cathodic protection testing activities were performed and conducted in accordance with Chapter 173-360 WAC.

I. UST FACILITY		II. CERTIFIED CATHODIC PROTECTION TESTER				
Facility Compliance Tag #:A3508		Service Provider Name: Tyler Hardy				
UST ID #: 97436		Company Name: Northwest Tank & Environmental Services, Inc.				
Site Name: Parkway Shell		Address: 21120 Hwy 9 SE				
Site Address: 3124 Old Fairhaven Parkway		City: Woodinville	State: WA	Zipcode: 98072		
City: Bellingham		Phone: (800) 742-9620	Email: info@nwtank.com			
Site Phone: 360-734-9360		Certification Type: STI Cathodic Protection ICBO U4				
County: Whatcom						
III. RESULTS OF EVALUATION (which include results of both continuity system surveys)						
<input checked="" type="checkbox"/> PASS The criteria, used to evaluate whether cathodic protection is adequate, were in accordance with a code of practice developed by a nationally recognized association (e.g. NACE), as required by <input type="checkbox"/> FAIL the Washington State Underground Storage Tank Regulations.						
Date CP Evaluation Performed: 06/28/2021						
IV. CRITERIA APPLICABLE TO EVALUATION						
Continuity Survey:		<input checked="" type="checkbox"/> PASS - continuity data is passing and no action is needed. <input type="checkbox"/> FAIL - continuity data is failing and the system requires a repair or retrofit.				
System Survey		#TANKS	#PIPE RUNS	#STP SFCs ¹	#DISP SFCs ²	
Neg. 850 mV ON	<input checked="" type="checkbox"/> PASS	3				A negative (cathodic) potential of at least -850 mV with the cathodic protection applied. This potential is with respect to a saturated copper-copper sulfate reference electrode containing electrolyte.
	<input type="checkbox"/> FAIL					
Neg. 850 mV Instant Off	<input type="checkbox"/> PASS					A negative polarized potential of at least 850 mV relative to a saturated copper-copper sulfate reference electrode ("Instant Off" Potential).
	<input type="checkbox"/> FAIL					
100 mV Polarization	<input type="checkbox"/> PASS					A minimum of 100 mV of cathodic polarization between the structure surface and a stable reference electrode contacting the electrolyte.
	<input type="checkbox"/> FAIL					

V. ACTION REQUIRED AS A RESULT OF THIS EVALUATION (check one box and explain further in comment box below).	
<input checked="" type="checkbox"/> NONE	The cathodic protection system is adequately providing protection. No further action is necessary at this time. System must be tested in three years unless more immediate attention is required.
<input type="checkbox"/> RETEST	The cathodic protection system may not be adequately protecting steel from corrosion. Retesting is necessary
<input type="checkbox"/> RETROFIT/REPAIR	The cathodic protection system is not adequately providing protection. Retrofitting or repairing is necessary.
<input type="checkbox"/> RETEST AFTER RETROFIT/REPAIR	The cathodic protection system has been retrofitted or repaired and tested at time of the retrofit/repair. A re-test is required within one to six months of retrofit or repair.
Comments (include type of testing gear used, steel components tested, etc.):	

- 1.If no submersible turbine pump (STP) is present, these steel flex connectors (SFC) are on the tank end of piping.
2.If no dispenser is installed, these SFCs are on the non-tank end of piping.

VIII. REMARKS (describe any modifications made to the CP system)								
IX . CONTINUITY SURVEY								
Structure "A"	Structure "B"	Point "A" to Point "B" or Fixed Cell Location >30'	Structure "A" Fixed Voltage >30'	Structure "B" Fixed Voltage >30'	Point-to-Point or Fixed Voltage Difference	Continuous	Isolated	Method and Standards Used (e.g. RP-0285, R051)
1 (Tank)	2 (Tank)					<input type="checkbox"/>	<input checked="" type="checkbox"/>	Pt to Pt RP-0285
1 (Tank)	3 (Tank)					<input type="checkbox"/>	<input checked="" type="checkbox"/>	Pt to Pt RP-0285
2 (Tank)	3 (Tank)					<input type="checkbox"/>	<input checked="" type="checkbox"/>	Pt to Pt RP-0285

X . SYSTEM SURVEY										
Structure	Contact Point	Half Cell Location	Local Voltage "ON"	Local Voltage "Instant Off"	Local Voltage (Depolarized)	Voltage Change	Remote Voltage(On) > 30	PASS	FAIL	Method and Standards Used
1 (Tank)	Inside of Tank	1	-1540					<input checked="" type="checkbox"/>	<input type="checkbox"/>	-850 on R051
1 (Tank)	Inside of Tank	2	-1578					<input checked="" type="checkbox"/>	<input type="checkbox"/>	-850 on R051
1 (Tank)	Inside of Tank	3	-1569					<input checked="" type="checkbox"/>	<input type="checkbox"/>	-850 on R051
1 (Tank)	Inside of Tank	Remote					-1650	<input checked="" type="checkbox"/>	<input type="checkbox"/>	-850 on R051
2 (Tank)	Inside of Tank	4	-1422					<input checked="" type="checkbox"/>	<input type="checkbox"/>	-850 on R051
2 (Tank)	Inside of Tank	5	-1681					<input checked="" type="checkbox"/>	<input type="checkbox"/>	-850 on R051
2 (Tank)	Inside of Tank	6	-1544					<input checked="" type="checkbox"/>	<input type="checkbox"/>	-850 on R051
2 (Tank)	Inside of Tank	Remote					-1541	<input checked="" type="checkbox"/>	<input type="checkbox"/>	-850 on R051
3 (Tank)	Inside of Tank	7	-1452					<input checked="" type="checkbox"/>	<input type="checkbox"/>	-850 on R051
3 (Tank)	Inside of Tank	8	-1551					<input checked="" type="checkbox"/>	<input type="checkbox"/>	-850 on R051
3 (Tank)	Inside of Tank	9	-1606					<input checked="" type="checkbox"/>	<input type="checkbox"/>	-850 on R051
3 (Tank)	Inside of Tank	Remote					-1655	<input checked="" type="checkbox"/>	<input type="checkbox"/>	-850 on R051

XI . UST SITE PLAN

Customer Name: Parkway Shell **Site Name:** Parkway Shell

Site Address: 3124 Old Fairhaven Parkway, Bellingham

Job Number: 102082




Diagram the UST System, including tanks, piping, and dispenser locations, approximate scale, and any other notable structures/physical features. Indicate north with arrow. On the map below, include the half cell locations used during testing. All test points must be easily identifiable, so that testing can be reproduced and your results verified.

XIII . RETROFIT OR REPAIR DESIGN (if applicable)

All retrofitting or repairs to CP systems shall be designed by a Corrosion Expert. I certify that I am a Corrosion Expert qualified to engage in the practice of corrosion control on buried or submerged metal piping systems and metal tanks. I have attached copies of the retrofit/repair design and of the Underground Storage Tank Retrofit and Repair Checklist

Corrosion Expert's Name:

National Recognized Organization:

Corrosion Expert's Name:

Certification Number:

Corrosion Expert's Signature:

Date:


Site Map

Customer Name: Parkway Shell **Site Name:** Parkway Shell

Site Address: 3124 Old Fairhaven Parkway, Bellingham

Job Number: 102082

UST Site ID: 97436



* Remote

XIII . REQUIRED SIGNATURES

The service provider certifies the criteria used to evaluate whether cathodic protection is adequate were in accordance with a code of practice developed by a nationally recognized association (e.g. NACE), as required by the Washington State Underground Storage Tank Regulations

06/28/2021




Tyler Hardy - Tech

Date

Signature of Certified Cathodic Protection Tester

Print or Type Name



Brad Gablehouse

Date

Signature of Tank Owner or Authorized Representative

Print or Type Name