



## INITIAL INVESTIGATION FIELD REPORT

LUST ID: 2269

FS ID: 98788752

Site ID: 9743

SITE NAME M A Segale Inc-Tukwila Asphalt Plant

### SITE LOCATION INFORMATION

Contact Person Name	Title	Phone Number	
<hr/>			
Mailing Address	City	Zip + 4	
18500 Southcenter Parkway	Tukwila	98188	
Site Location	Closest City	County	
18500 Southcenter Parkway	Tukwila		
Quarter-Quarter	Section	Township	Range
Latitude:	Degree	Minute	Second
Longitude:	Degree	Minute	Second

### INSPECTION INFORMATION

Inspection Date	Inspection Time	Type of Entry Notice
Photographs Yes No	Weather: Clear	Partly Cloudy Overcast
Videotape Yes No	Precipitation	Temperature
Samples Yes No	Wind Direction	Wind Speed

### RECOMMENDATION

No Further Action:

Yes

Release or threatened release does not pose a threat

Site Hazard Assessment

No release or threatened release

Interim Action

Educational Mailing

Emergency Action Plan

Refer to another program/agency

Independent Cleanup Action

In Progress

Completed

### CONTAMINANT(S) (See Page 3 for details)

Soil	Yes	
Groundwater	Yes	Diesel, WO, heating oil, gas, BTEX

### DEPARTMENT REVIEW

Investigator	Date
Approved by	
Unit Supervisor <i>RED</i>	Date <i>4/11/16</i>
Section Manager	Date

### COMMENTS

Four USTs were removed from this site in 1991. PCS was found in the first diesel UST excavation. Overexcavation was completed until confirmation samples were below MTCA Method A cleanup levels. GW was encountered and had TPH above MTCA. Further GW was pumped out and TPH was not detected in the water sample analyzed by the lab. PCS was also found in the second diesel UST excavation. Again, overexcavation was completed until confirmation samples indicated no elevated conc. of TPH. PCS was found in the WO UST excavation. Additional excavations were done until confirmation

HCID: 478



## INITIAL INVESTIGATION FIELD REPORT

---

LUST ID: 2269

FS ID: 98788752

Site ID: 9743

**SITE NAME** M A Segale Inc-Tukwila Asphalt Plant

---

samples showed no TPH conc. above MTCA cleanup levels. This final soil sample was also analyzed for metals, PCBs & VOCs, all of which were detected below MTCA. A total of 310 cy of overexcavated PCS was stockpiled onsite. Approx 180 cy of the stockpiled material was clean, therefore it was used in the asphalt plant operations. The remaining 130 cy of PCS was disposed off-site.

---