Tuesday, November 24, 2020

Jacksons Food Stores 3450 East Commercial Court Meridian, ID 83642

627 15 East Sunset Way Issaquah, WA 98027

RE: Job ID 96000

Dear Valued Customer:

The **Official Report** including all test results and any supporting documentation are enclosed. The test data covered in this report are specific to each test conducted. For your convenience, a summary of testing conducted is provided on the report cover page.

Unless stated otherwise, all compliance testing data must be maintained on site for a minimum of **5 years**. Instructions for specific test types may follow.

Please call if you have any questions or require additional information.

Sincerely,

Rose M. Claen



WA LEAK TESTING CHECKLIST FOR UNDERGROUND STORAGE TANKS (USTS)

UST ID #: County:

King

7691

This checklist certifies testing activities conducted in accordance with Chapter 173-360A WAC. Read instructions on pages 4-7.

✓ PASS - All Section VI services performance ► FAIL - One or more components tes	•			CONDUCTED:	11/18/2020		
and re-testing.	equire repair						
I. UST FACILITY	II. CERT	II. CERTIFIED SERVICE PROVIDER					
Facility Compliance Tag #: A0500		Service I	Service Provider Name: Juan Carrillo				
UST ID #: 7691		Compan	Company Name: Northwest Tank & Environmental Services, Inc.				
Site Name: 627		Address	Address: 17407 59th Ave SE				
Site Address: 15 East Sunset Way		City: Sno	City: Snohomish State: WA Zip: 98296				
City: Issaquah		Phone: (a	Phone: (800) 742-9620 Email: info@nwtank.com				
County: King		ICC Cert	ification Ty	pe: Tightr	ness Testing ICB	O- U3	
Site Phone: 425-427-2744		ICC Cert	ICC Cert. #: 8217074 - U3 Exp. Date: 08/29/2021				
III. UST OWNER/OPERATOR							
Name: Jacksons Food Stores Phone: 208-888-6061 Email: richard.wright@jacksonsfoodstores.com							
IV. UST SYSTEM INFORMATION Observations on test day.							
1. Tank ID #, as registered with Ecology or identified on AT G				2			
2. Tank Status. OP (Operational); TC (Temporary Closure)			Р			OP	
3. Product stored, including % of alternative fuels			nium		R	egular	
4. Tank or compartment capacity (gallons)			000		20000		
5. Product pumping/flow method. Note as NS (Non-safe Suction); SS (Safe Suction) (Gravity Fed)	Pres	Pressure		Pi	Pressure		
Abbreviations for lines 5 and 6 below: Steel (ST); Fiberglass (FRP); Clad Steel (CLAD); Flexible (FLEX); Double Wall (DW); Single Wall (SW); Not Visible (NV)							
6. Tank material and construction observed			DWF		DWF		
7. Pipe material and construction observed			DWF		DWF		
V. REASON FOR SERVICES PERFORMED (Check all that apply)							
Annual testing	Test after ins	tall/repair			or (ovplaip):		
✓ 3-year testing	🗖 Return UST :		☐ Other (explain):				

VI. SERVICES PERFORMED Required: Include verification for each test performed.								
	#PASS	#FAIL	# REPAIRED & PASSING					
SERVICES:				DESCRIPTIONS REQUIRED: (SEE INSTRUCTIONS P. 4-7)				
ALLD Test (attach data)								
Test method used: N/A								
Test method cert.exp.date:								
Line Tightness Test (attach data								
Test method used: N/A								
Test method cert.exp.date:								
Electronic Monitoring System Tests								
Controller.mfr/model: Array								
Controller cert.exp.date:								
Monitor/controller Probe								
Sump Sensor Functionality								
Tank Annular Sensor Functionality								
OverfillEquipmen								
t Test	2			test per rp1200				
Fill/Spill Bucket Test (attach data)	2			fill buckets test per rp1200				
Tank-Top or Transition Sump Te st (attach data)								
UDC Sump Test (attach data)								
Tank Tightness Test (attach dat								
a) 3rd-party certified test:								
Test method used: N/A								
Test method cert.exp.date:								
Other								
Provide additional test i				DBLEMS ENCOUNTERED: s. Describe problems encountered and how addressed				
Sump Test: Comments - Fill Spill buckets pass all buckets are in a sump that has	5							

VIII. UST SITE AND SYSTEM DIAGRAM Diagram required. Include North arrow.								
PERSONS SUBMITTING FALSE INFORMATION ARE SUBJECT TO FORMAL EN /OR PENALTIES UNDER CHAPTER 173-360A WAC.	FORCEMEN	II AND						
IX. FINAL CHECK								
Mark the following:	YES	NO	N/A					
1. All checked services tested per recommended practices, code and/or manufacturer's require ments, and in accordance with state regulations.								
2. Owner/operator provided with copy of the checklist and testing results.								
3. Any faulty equipment or necessary repairs explained to owner/operator or site contact.								
X. REQUIRED SIGNATURES								
11/18/2020 Carte 200		Juan Carrillo - Tech						
Date Signature of Certified Service Provider	Print or Ty	pe Name						
Anh Mi- 11/18/2020	Andrew Mar	vin						

Certificate Of Precision Containment Sump Testing

Company Name: Site Name:	Jacksons Food Stores 627	Testing Company Name	Northwest Tank & Environmental Services, Inc.
• • •	15 East Sunset Way Issaquah, WA 9802	Address:	17407 59th Ave SE
Address:	7	City/State/Zip:	Snohomish, WA 98296
Test Date/Time:	11/18/2020 04:00:00 pm	PH: (800) 742-9620	FAX: (425) 645-7881
Service Order#:	96000		http://www.nwtank.com
Customer PO#:	Invoice		
Test Method:	Hydrostatic		
UST Site ID:	7691		

Test #	Component Location	MFR	Start Time	End Time	Start Test (inches)	End Test (inches)	Sump Type	SW or DW Sump/Bucket	DW or SW Lines	Measured Loss	Results
1	87	opw	03:21:32	04:21:53	11	11	Fill Spill Bucket	SW	DW	0	Pass
2	92	opw	03:21:32	04:21:53	11	11	Fill Spill Bucket	sw	DW	0	Pass

Comments:

Fill Spill buckets pass all buckets are in a sump that has a VR- sensor Testing performed by: Juan Carrillo Signature:

Date: 11/18/2020

NORTHWEST TANK & ENVIRONMENTAL SERVICES, INC.

OVERFILL ALARM OPERATION INSPECTION								
Facility Name: jfs #0627		Owner:						
Address: 15 E sunset way	Address:							
City, State, Zip Code: Issaquah WA.		City, State, Zip Cod	e:					
Facility I.D. #:		Phone #:						
Testing Company: Northwest Tank		Phone #:	Date: 1	1/18/2020				
This procedure is to determine whether the high level alarm is operational and will trigger when the tank is no more than 90% full. See PEI/RP1200, Section 7.3 for the inspection procedure. This procedure is applicable to tank level monitor stems that touch the bottom of the tank when in place.								
Tank Number	1	2						
Product Stored	92	87						
Tank Level Monitor Brand and Model	vr tls350	vr tls350						
1. Tank Volume, gallons	12000	20000						
2. Tank Diameter, inches	117.75	117.75						
3. Does the overfill alarm activate in the test mode at the console?	🗹 Yes 🗆 No	🗹 Yes 🗆 No	🗆 Yes 🛛 No	□Yes □No				
4. When activated, can the overfill alarm be heard or seen while delivering to the tank?	🗹 Yes 🗆 No	🗹 Yes 🗆 No	🗆 Yes 🛛 No	□Yes □No				
5. After removing the probe from the tank, has it been inspected and any damaged or missing parts replaced?	🗹 Yes 🗆 No	Yes 🗆 No	□Yes □No	□Yes □No				
6. Float moves freely on the stem without binding?	🗹 Yes 🗆 No	⊈ Yes □ No	□Yes □No	□ Yes □ No				
7. Does moving product level float up the stem trigger alarm?	🗹 Yes 🗆 No	⊈ ∕ Yes □ No	🗆 Yes 🔲 No	□Yes □No				
8. Inch level from bottom of stem when 90% alarm is triggered.	99	99 1/8						
9. Tank volume at inch level in Line 8.	10640	17800						
10. Calculate (Line 9 / Line 1) x 100	88.66666666666	89	NaN	NaN				
11. Is Line 10 less than 90%?	🗹 Yes 🛛 No	⊡∕ Yes □ No	🗆 Yes 🗆 No	□Yes □No				
12. Does the fuel float level on the console agree with the gauge stick reading?	🛱 Yes 🛛 No	⊡∕ Yes □ No	🗆 Yes 🛛 No	□Yes No				
13. Does the overfill alarm activate at any product level above 90% tank capacity?	🗆 Yes 🗔 🖓 Vo	🗆 Yes 🛛 🗸 No	🗆 Yes 🛛 No	□Yes □No				
If any answers in Lines 3, 4, 5, 6, 7 or 11 are "No", or Line 13 is "Yes", the system has failed the test.								
Test Results	🗹 Pass 🛛 Fail	🖬 Pass 🛛 Fail	🗆 Pass 🛛 Fail	🗆 Pass 🛛 Fail				
Comments:								