

Washington State Department of Ecology
Underground Storage Tank (UST) Program
NOTICE OF NON-COMPLIANCE

UST ID: 100694
Issue Date: 4/11/2023

This action does not limit the Department from other enforcement actions as deemed necessary.

Site Name: AMERISTAR # 20	Contact Name: Brandon Christensen
Site Address: 101 MERLOT DR	Contact Phone: 509-830-3706
City: Prosser	Contact Cell: 509-830-3706
Responsible Party: Christensen Inc	Contact Email: Brandon@christensenusa.com

Violations Descriptions, Observations, and Actions Required **Due Date**

173-360A-0460 - Failure to conduct periodic testing on spill prevention equipment **5/12/2023**

Observations & Actions Required: **Spill bucket testing is almost 1 month overdue. Have a service provider do the required testing and submit documents to ecology.**

173-360A-0450 - Failure to conduct periodic testing on containment sumps used for interstitial monitoring of piping **5/12/2023**

Observations & Actions Required: **Containment sumps that are associated with the two diesel tanks that were installed in 2014 were required to be tested by 10/1/2020 have not been tested. Have a service provider test all containment sumps that are connected to the 2014 installed tanks and submit documents to ecology.**

Instructions **Request Extension By: 4/25/2023**

- You must complete the actions identified above by the due date to resolve the UST violations listed.
 - To request an extension, submit a written request to the Ecology inspector by the request extension date. The request must include:
 - Reason extension is requested.
 - Steps already taken and a description of the work that remains to be completed.
 - Anticipated completion date of remaining work.
- A Notice of Non-Compliance (NONC) is not an appealable enforcement action.
 - If a Field Penalty or Notice of Delivery Prohibition accompanies a NONC, **the Field Penalty and/or Notice of Delivery Prohibition are appealable.**
 - Failure to comply with requirements set forth in a NONC may result in further enforcement actions.

Submit required documentation via mail, fax, or email.

Regional Office: Central	Inspector Name: Webb, Mike
Address: 1250 W Alder St Union Gap, WA 98903	Inspector Email: mweb461@ecy.wa.gov
Phone/Fax: 509-575-2490 / 509-575-2809	Inspector Phone: 509-406-6572

I personally investigated or observed the violation(s) noted above.

Signature of UST Inspector




Date 4/17/2023

I acknowledge receipt of this action. My signature does not imply agreement.

Printed Name of Responsible Party or Site Contact **Brandon Christensen**

Signature of Responsible Party or Site Contact



Date 4/17/2023

If you need this document in an alternative format call the Toxics Cleanup Program at (360)407-7170. Persons with hearing loss, call 711 for the Washington Relay Service. Persons with a speech disability, call 877-833-6341.