



WA LEAK TESTING CHECKLIST FOR UNDERGROUND STORAGE TANKS (USTS)

UST ID #: 100434
County: Benton

This checklist certifies testing activities conducted in accordance with Chapter 173-360A WAC. Read instructions on pages 4-7.

<input checked="" type="checkbox"/> PASS - All Section VI services performed have passing results. <input type="checkbox"/> FAIL - One or more components tested in Section VI require repair and re-testing.		DATE TESTS CONDUCTED: 05/05/2023
I. UST FACILITY		
Facility Compliance Tag #: <u>A0981</u>	Service Provider Name: Keith Lawty	
UST ID #: 100434	Company Name: Northwest Tank & Environmental Services, Inc.	
Site Name: Richland Yacht Club	Address: 21120 Hwy 9 SE	
Site Address: 350 Columbia Point Drive	City: Woodinville	State: WA Zip: 98072
City: Richland	Phone: (800) 742-9620	Email: info@nwtank.com
County: Benton	ICC Certification Type: Tightness Testing ICBO- U3	
Site Phone: 509-531-5658	ICC Cert. #: 8589-U3	Exp. Date: 10/06/2024
III. UST OWNER/OPERATOR		
Name: Richland Yacht Club	Phone: 509-943-6133	Email: roykeck@charter.net
IV. UST SYSTEM INFORMATION Observations on test day.		
1. Tank ID #, as registered with Ecology or identified on ATG	1	
2. Tank Status. OP (Operational); TC (Temporary Closure)	OP	
3. Product stored, including % of alternative fuels	Non Ethanol Premium	
4. Tank or compartment capacity (gallons)	1990	
5. Product pumping/flow method. Note as: P (Pressurized); NS (Non-safe Suction); SS (Safe Suction); Si (Siphon); GR (Gravity Fed)	Pressure	
Abbreviations for lines 5 and 6 below: Steel (ST); Fiberglass (FRP); Clad Steel (CLAD); Flexible (FLEX); Double Wall (DW); Single Wall (SW); Not Visible (NV)		
6. Tank material and construction observed	CLD	
7. Pipe material and construction observed	SWS	
V. REASON FOR SERVICES PERFORMED (Check all that apply)		
<input checked="" type="checkbox"/> Annual testing <input type="checkbox"/> 3-year testing	<input type="checkbox"/> Test after install/repair <input type="checkbox"/> Return UST system to operation	<input type="checkbox"/> Other (explain):

VI. SERVICES PERFORMED
Required: Include verification for each test performed.

		#	
#PASS	#FAIL	REPAIRED& PASSING	
SERVICES:	DESCRIPTIONS REQUIRED: (SEE INSTRUCTIONS P. 4-7)		
ALLD Test (attach data) Test method used: LDT 890 Test method cert.exp.date: 11/28/2024	1		See notes in LLD testing section. Testing performed as per RP1200 standards.
Line Tightness Test (attach data) Test method used: Acurite Test method cert.exp.date: 7/19/2024	1		See notes in Line Tightness testing section.
Electronic Monitoring System Tests Controller.mfr/model: V-R TLS 350 Controller cert.exp.date: 10/6/2024 Monitor/controller Probe Sump Sensor Functionality Tank Annular Sensor Functionality	1 1		See notes in Monitor Insp. section. Testing performed as per RP1200 standards. . See notes in Monitor Insp. section. Testing performed as per RP1200 standards. See notes in Monitor Insp. section. Testing performed as per RP1200 standards.
Overfill Equipment Test <input type="checkbox"/> Auto shutoff <input type="checkbox"/> Ball float valve <input type="checkbox"/> Overfill alarm			
Fill/Spill Bucket Test (attach data)			
Tank-Top or Transition Sump Test (attach data)			
UDC Sump Test (attach data)			
Tank Tightness Test (attach data) 3rd-party certified test: Test method used: N/A Test method cert.exp.date:			
Other			

VII. EXPLANATIONS/PROBLEMS ENCOUNTERED:

Provide additional test information. Explain irregularities. Describe problems encountered and how addressed..

Leak Detector:
 Comments - Automatic Line Leak Detector testing performed as per RP1200 standards.

Mechanical LLD testing for T1(NE_Prem) performed from sole dispenser located on dock.

Line Test:
 Comments - Line Tightness testing performed through isolation plug at turbine.

Use of isolation plug needed as check valve does not hold pressure.

Tank Monitor:

--Tank_monitors--

#1: 5/05/2023:

Testing/inspection of monitoring equipment performed as per RP1200 standards.

Removed 1 ATG probe to clean, inspect, and test.

Verified the following alarms to sole ATG probe:

- High Water Warning
- High Water Alarm
- Overfill Alarm
- High Product Alarm


Backup battery inspected; functional, within spec.

No sensors on site.

Compared manual fuel level readings with that from the monitor.

VIII. UST SITE AND SYSTEM DIAGRAM

Diagram required. Include North arrow.



PERSONS SUBMITTING FALSE INFORMATION ARE SUBJECT TO FORMAL ENFORCEMENT AND/OR PENALTIES UNDER CHAPTER 173-360A WAC.

IX. FINAL CHECK

Mark the following:

	YES	NO	N/A
1. All checked services tested per recommended practices, code and/or manufacturer's requirements, and in accordance with state regulations.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2. Owner/operator provided with copy of the checklist and testing results.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3. Any faulty equipment or necessary repairs explained to owner/operator or site contact.	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

X. REQUIRED SIGNATURES

05/05/2023		Keith Lawty - Tech
Date	Signature of Certified Service Provider	Print or Type Name
05/05/2023		Bryan Bobbett - Manager
Date	Signature of Tank Owner or Authorized Representative	Print or Type Name

Automatic Line Leak Detector Test Results

Company Name: Richland Yacht Club
Site Name: Richland Yacht Club
Address: 350 Columbia Point Drive Richland, WA 99352-4370
UST Site ID: 100434
Test Date/Time: 05/05/2023 08:55:54 am

Job ID Number: 117896
Technician Name: Keith Lawty
License Number: 8589-U3
Expiration Date: 10/06/2024

Product: Non Ethanol Premium	Make: Red Jacket	Operating Pressure: 28	Result: Pass
Tank ID: 1	Model: FX1V	Holding Pressure: 27	
LD Type: Mechanical	Serial#: 5910	Bleedback (ml): 900	
Additional Data For Mechanical Leak Detectors Only			
Metering Pressure: 13			
Step Through Time: 6			

Leak detector testing conducted in accordance with the procedures and limitations of the LDT 890 leak detector tester. A leak is simulated at the highest point in the line using the LDT 890 calibrated to 3 gph at a metering pressure of 10 psi. The owner or operator of the UST system is required to ensure any failed leak detector is replaced before placing the line back in service.

The results of any sampling, testing, or monitoring shall be maintained for at least five years, or for another reasonable period of time determined by the department or delegated agency, except that the results of tank tightness testing conducted in accordance with CFR 40 Part 280.44 shall be retained until the next test is conducted.

Comments: Automatic Line Leak Detector testing performed as per RP1200 standards. Mechanical LLD testing for T1(NE_Prem) performed from sole dispenser located on dock.

Technician Name: Keith Lawty
Signature:



Date: 05/05/2023

Line Tightness Test Results

Company Name: Richland Yacht Club
Site Name: Richland Yacht Club
Address: 350 Columbia Point Drive Richland, WA 99352-4370
UST Site ID: 100434
Test Date: 05/05/2023

Job ID Number: 117896
Technician Name: Keith Lawty
License Number: 8589-U3
Expiration Date: 10/06/2024

Line Tightness Test Data

Product:	Regular	Tank ID:	1	Start Time:	09:58
Approx Length:	300	STP MFG:	FE Petro 3/4 HP	End Time:	10:28
Size:	1.5	Operating Pressure:	28	Total Test Time:	30mins
Line Material:	SWS	Test Pressure:	42	Final Leak Rate:	.00000
Wall Type:	SW	Isolation Dispenser:	Impact Valve	Impact Valves Operational:	Yes
Boot Back:	N/A	Isolation Pump:	Isolation Plug	Check Valve Location:	N/A
Line Type:	Pressure	Initial Cylinder Level:	0.090	Result:	Pass
		Final Cylinder Level:	0.090		

Line tightness testing conducted in accordance with the procedures and limitations of the Acurite pipeline tester. A consistent leak rate of .01 gph or higher at 150% of normal operating pressure is considered a failure. The owner or operator of the UST system is required to report all failures to the appropriate agency within 24 hours.

The results of any sampling, testing, or monitoring shall be maintained for at least five years, or for another reasonable period of time determined by the department or delegated agency, except that the results of tank tightness testing conducted in accordance with CFR 40 Part 280.44 shall be retained until the next test is conducted.

Comments: Line Tightness testing performed through isolation plug at turbine. Use of isolation plug needed as check valve does not hold pressure.

Technician Name: Keith Lawty

Signature:



Date: 05/05/2023

Monitoring System Certification

This form must be used to document testing and servicing of monitoring equipment. A separate certification or report must be prepared for each monitoring system control panel by the technician who performs the work. A copy of this form must be provided to the tank system owner/operator. The owner/operator must submit a copy of this form to the local agency regulating UST systems within 30 days of test date.

A. General Information

Facility Contact Person: Brian Bobbett
Make / Model Monitoring System: V-R TLS 300

Company Name: Richland Yacht Club
Site Address: 350 Columbia Point Drive
UST Site ID: 100434

Date Of Testing: 05/05/2023
Site Name: Richland Yacht Club
City, State, ZIP: Richland, WA 99352-4370
Facility Phone Number: 509-531-5658
Serial #: F11178195805001

B. Inventory of Equipment Tested/Certified

Tank #: 1 Non Ethanol Premium	
In-Tank Gauging Probe	Mag 1 Probe
Annular Space or Vault Sensor:	N/A
Piping Sump / Trench Sensor:	N/A
Fill Sump Sensor:	N/A
Mechanical Line Leak Detector:	FX1V
Electronic Line Leak Detector:	N/A
Tank Overfill / High Level Sensor:	OPW BF
Other:	

Dispenser ID:	1
Dispenser Containment Sensors Model:	N/A
Shear Valves: Yes	Floats & Chains: No

C. Certification

I certify that the equipment identified in this document was inspected/serviced in accordance with the manufacturers' guidelines. Attached to this certification is information (e.g. manufacturers' checklists) necessary to verify that this information is correct and a Plot Plan showing the layout of monitoring equipment. For any equipment capable of generating such reports, I have also attached a copy of the report (check all that apply):

Technician Name: Keith Lawty
 Certification Number:
 Expiration Date:
 Signature:



Testing Company Name: Northwest Tank & Environmental Services, Inc.
 Address: 21120 Hwy 9 SE Woodinville, WA 98072
 Date of Testing: 05/05/2023

D. Results of Testing/Service

Yes	Is the audible alarm operational?
Yes	Is the visual alarm operational?
N/A	Were all sensors visually inspected, functionally tested, and confirmed operational?
Yes	If alarms are relayed to a remote monitoring station, is all communications equipment operational?
No	For pressurized piping systems, does the turbine automatically shut down if the piping secondary containment monitoring system detects a leak, fails to operate, or is electrically disconnected?
N/A	If yes: which sensors initiate positive shut-down?
N/A	Did you confirm positive shut-down due to leaks and sensor failure/disconnection?
N/A	For tank systems that utilize the monitoring system as the primary tank overflow warning device (i.e. no mechanical overflow prevention valve is installed), is the overflow warning alarm visible and audible at the tank fill point(s) and operating properly?
N/A	If so, at what percent of tank capacity does the alarm trigger?
No	Was any monitoring equipment replaced? If yes, identify specific sensors, probes or other equipment replaced and list the manufacturer name and model for all replacement parts in Section E below.
No	Was liquid found in any secondary containment systems designed as dry systems?
N/A	If yes, what type of liquid?
Yes	Was monitoring system set-up reviewed to ensure proper settings? Attach setup reports, if applicable.
Yes	Is all monitoring equipment operational per manufacturers specifications?

In section E. below, describe how and when these deficiencies were or will be corrected.

E. Comments

5/05/2023: Testing/inspection of monitoring equipment performed as per RP1200 standards. Removed 1 ATG probe to clean, inspect, and test. Verified the following alarms to sole ATG probe: -High Water Warning -High Water Alarm -Overflow Alarm -High Product Alarm Backup battery inspected; functional, within spec. No sensors on site. Compared manual fuel level readings with that from the monitor.

State Tank ID	Product	Manual Stick Readings(inches)	Gauge Readings(inches)	Difference
1	Non Ethanol Premium	30.5	30.36	.14

F. In-Tank Gauging / SIR Equipment

This section must be completed if in-tank gauging equipment is used to perform leak detection monitoring.

Yes	Has all input wiring been inspected for proper entry and termination, including testing for ground faults?
Yes	Were all tank gauging probes visually inspected for damage and residue buildup?
Yes	Was accuracy of system product level readings tested?
Yes	Was accuracy of system water level readings tested?
Yes	Were all probes reinstalled properly?
Yes	Were all items on the equipment manufacturer's maintenance checklist completed?

G. Line Leak Detectors (LLD):

Yes	For equipment startup or annual equipment certification, was leak simulated to verify LLD performance?
3 GPH	Leak Rate
Yes	Were all LLDs confirmed operational and accurate within regulatory requirements?
Yes	Was the testing apparatus properly calibrated?
Yes	For mechanical LLDs, does the LLD restrict product flow if it detects a leak?
N/A	For electronic LLDs, does the turbine automatically shut off if the LLD detects a leak?
N/A	For electronic LLDs, does the turbine automatically shut off if any portion of the monitoring system is disabled or disconnected?
N/A	For electronic LLDs, does the turbine automatically shut off if any portion of the monitoring system malfunctions or fails a test?
N/A	For electronic LLDs, have all accessible wiring connections been visually inspected?
Yes	Were all items on the equipment manufacturer's maintenance checklist completed?



UST WALKTHROUGH INSPECTIONS CHECKLIST

Site Name: Richard Yeart Club Site Address: 550 Columbia Pl. Dr. Richard, IA Tag #: A0981

- Initial each box to indicate the equipment was inspected, as described. Use NA if the equipment inspection does not apply to the site.
- Take action for any alarms, damaged equipment and non-normal operating conditions; note actions taken on page 2
- NOTE: Petroleum found in a sump or interstice must be reported to Ecology within 24 hours.

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
REQUIRED MONTHLY												

Spill bucket(s) checked for damage and cracks*. Liquid and/or debris removed.

Fill pipe(s) checked for obstructions. Removed, if found.

Fill cap(s) securely fitted on fill pipe(s).

Tank monitor equipment checked for alarms and normal operating condition.

Leak detection records are reviewed for non-leaking results and kept for three years. Suspected leaks were reported.

REQUIRED ANNUALLY

Containment sump(s) checked for damage and presence of liquid. Liquid and/or debris removed.

If using **manual tank gauging**, checked condition of tank gauge stick is good (e.g. readable at 1/8" increments throughout).

RECOMMENDED ACTIVITIES

Emergency spill response supplies inventoried and restocked if low.

Inspected supplies for deterioration.

Inspected loose fitting, deterioration, obvious signs of leaks and improper function of **dispenser hoses, nozzles and breakaways**.

*If a tank receives deliveries at intervals greater than 30 days, the spill bucket check may instead be conducted prior to each delivery. To be eligible for this option, include a copy of each delivery receipt with this form.

Note: This checklist doesn't include the requirement to inspect hydrant pits and piping vaults at airport hydrant systems at least every 30 days.

