

# Anatek Labs, Inc.

1282 Alturas Drive - Moscow, ID 83843 - (208) 883-2839 - email moscow@anateklabs.com  
504 E Sprague Ste. D - Spokane, WA 99202 - (509) 838-3999 - email spokane@anateklabs.com

**Client:** Hannah Heights  
**Address:** P.O. Box 1536  
Friday Harbor, WA 98250  
**Attn:** Paul Hart

**Work Order:** MDE0252  
**Project:** Friday Harbor Sampling  
**Reported:** 5/24/2023 14:38

## Analytical Results Report

System ID# 30850 System Name: Hannah Heights  
Reference Number: MDE0252-01 Collect Date: 05/03/23 09:20 DOH Source #: 02  
Multiple Source Nos: Sample Type: Before County: San Juan  
Date Received: 05/05/23 10:50 Sample Purpose: O - Other  
Sample Location: Pitless Adaptor  
Matrix: Drinking Water

Lab/Sample Number: 125-25201

### Per- and Polyfluoroalkyl Substances (PFAS)

DOH #	Analyte	Result	Units	LRL	SDRL	SAL	MCL	Analyzed	Analyst	Method	Qualifier
0436	PFDA Perfluorodecanoic acid	4.02	ng/L	2.00	2	--		5/11/23 20:21	MER	EPA 533	
0437	PFUnA Perfluoroundecanoic acid	ND	ng/L	2.00	2	--		5/11/23 20:21	MER	EPA 533	
0438	PFDoA Perfluorododecanoic acid	ND	ng/L	2.00	2	--		5/11/23 20:21	MER	EPA 533	
0445	ADONA 4,8-Dioxa-3H-perfluorononanoic acid	ND	ng/L	2.00	2	--		5/11/23 20:21	MER	EPA 533	
0446	9Cl-PF3ONS	ND	ng/L	2.00	2	--		5/11/23 20:21	MER	EPA 533	
0447	HFPO-DA Hexafluoropropylene oxide dimer acid	ND	ng/L	2.00	2	--		5/11/23 20:21	MER	EPA 533	
0448	11Cl-PF3OUdS	ND	ng/L	2.00	2	--		5/11/23 20:21	MER	EPA 533	
0450	4:2FTS 1H,1H,2H,2H-Perfluorohexane sulfonic acid	ND	ng/L	2.00	2	--		5/11/23 20:21	MER	EPA 533	
0451	6:2FTS 1H,1H,2H,2H-Perfluorooctane sulfonic acid	112	ng/L	2.00	2	--		5/11/23 20:21	MER	EPA 533	
0452	8:2FTS 1H,1H,2H,2H-Perfluorodecane sulfonic acid	7.05	ng/L	2.00	2	--		5/11/23 20:21	MER	EPA 533	
0453	NFDHA Nonafluoro-3,6-dioxaheptanoic acid	ND	ng/L	2.00	2	--		5/11/23 20:21	MER	EPA 533	
0456	PFMBA Perfluoro-4-methoxybutanoic acid	ND	ng/L	2.00	2	--		5/11/23 20:21	MER	EPA 533	
0457	PFMPA Perfluoro-3-methoxypropanoic acid	ND	ng/L	2.00	2	--		5/11/23 20:21	MER	EPA 533	
0460	PFEESA Perfluoro(2-ethoxyethane) sulfonic acid	ND	ng/L	2.00	2	--		5/11/23 20:21	MER	EPA 533	

# Anatek Labs, Inc.

1282 Alturas Drive - Moscow, ID 83843 - (208) 883-2839 - email moscow@anateklabs.com  
504 E Sprague Ste. D - Spokane, WA 99202 - (509) 838-3999 - email spokane@anateklabs.com

**Client:** Hannah Heights  
**Address:** P.O. Box 1536  
Friday Harbor, WA 98250  
**Attn:** Paul Hart

**Work Order:** MDE0252  
**Project:** Friday Harbor Sampling  
**Reported:** 5/24/2023 14:38

## Analytical Results Report

System ID# 30850 System Name: Hannah Heights  
Reference Number: MDE0252-01 Collect Date: 05/03/23 09:20 DOH Source #: 02  
Multiple Source Nos: Sample Type: Before County: San Juan  
Date Received: 05/05/23 10:50 Sample Purpose: O - Other  
Sample Location: Pitless Adaptor  
Matrix: Drinking Water

Lab/Sample Number: 125-25201

### Per- and Polyfluoroalkyl Substances (PFAS)

DOH #	Analyte	Result	Units	LRL	SDRL	SAL	MCL	Analyzed	Analyst	Method	Qualifier
0434	PFOA Perfluorooctanoic acid	306	ng/L	2.00	2	10		5/17/23 3:00	MER	EPA 533	
0433	PFOS Perfluorooctanesulfonic acid	6750	ng/L	2.00	2	15		5/17/23 3:00	MER	EPA 533	
0431	PFHxS Perfluorohexanesulfonic acid	6800	ng/L	2.00	2	65		5/17/23 3:00	MER	EPA 533	
0432	PFNA Perfluorononanoic acid	423	ng/L	2.00	2	9		5/17/23 3:00	MER	EPA 533	
0429	PFBS Perfluorobutanesulfonic acid	1030	ng/L	2.00	2	345		5/17/23 3:00	MER	EPA 533	
0430	PFHpA Perfluoroheptanoic acid	141	ng/L	2.00	2	--		5/17/23 3:00	MER	EPA 533	
0435	PFHxA Perfluorohexanoic acid	530	ng/L	2.00	2	--		5/17/23 3:00	MER	EPA 533	
0454	PFBA Perfluorobutanoic acid	105	ng/L	2.00	2	--		5/17/23 3:00	MER	EPA 533	
0455	PFHpS Perfluoroheptanesulfonic acid	245	ng/L	2.00	2	--		5/17/23 3:00	MER	EPA 533	
0458	PFPeA Perfluoropentanoic acid	278	ng/L	2.00	2	--		5/17/23 3:00	MER	EPA 533	
0459	PFPeS Perfluoropentanesulfonic acid	1020	ng/L	2.00	2	--		5/17/23 3:00	MER	EPA 533	

# Anatek Labs, Inc.

1282 Alturas Drive - Moscow, ID 83843 - (208) 883-2839 - email moscow@anateklabs.com  
504 E Sprague Ste. D - Spokane, WA 99202 - (509) 838-3999 - email spokane@anateklabs.com

**Client:** Hannah Heights  
**Address:** P.O. Box 1536  
Friday Harbor, WA 98250  
**Attn:** Paul Hart

**Work Order:** MDE0252  
**Project:** Friday Harbor Sampling  
**Reported:** 5/24/2023 14:38

## Analytical Results Report

System ID# 30850 System Name: Hannah Heights  
Reference Number: MDE0252-02 Collect Date: 05/03/23 09:30 DOH Source #: 02  
Multiple Source Nos: Sample Type: Before County: San Juan  
Date Received: 05/05/23 10:50 Sample Purpose: O - Other  
Sample Location: Upper Fracture Seep  
Matrix: Drinking Water

**Lab/Sample Number: 125-25202**

### Per- and Polyfluoroalkyl Substances (PFAS)

DOH #	Analyte	Result	Units	LRL	SDRL	SAL	MCL	Analyzed	Analyst	Method	Qualifier
0436	PFDA Perfluorodecanoic acid	13.1	ng/L	2.00	2	--		5/11/23 20:47	MER	EPA 533	
0437	PFUnA Perfluoroundecanoic acid	ND	ng/L	2.00	2	--		5/11/23 20:47	MER	EPA 533	
0438	PFDoA Perfluorododecanoic acid	ND	ng/L	2.00	2	--		5/11/23 20:47	MER	EPA 533	
0445	ADONA 4,8-Dioxa-3H-perfluorononanoic acid	ND	ng/L	2.00	2	--		5/11/23 20:47	MER	EPA 533	
0446	9Cl-PF3ONS	ND	ng/L	2.00	2	--		5/11/23 20:47	MER	EPA 533	
0447	HFPO-DA Hexafluoropropylene oxide dimer acid	ND	ng/L	2.00	2	--		5/11/23 20:47	MER	EPA 533	
0448	11Cl-PF3OUdS	ND	ng/L	2.00	2	--		5/11/23 20:47	MER	EPA 533	
0450	4:2FTS 1H,1H,2H,2H-Perfluorohexane sulfonic acid	2.23	ng/L	2.00	2	--		5/11/23 20:47	MER	EPA 533	
0452	8:2FTS 1H,1H,2H,2H-Perfluorodecane sulfonic acid	21.2	ng/L	2.00	2	--		5/11/23 20:47	MER	EPA 533	
0453	NFDHA Nonafluoro-3,6-dioxaheptanoic acid	ND	ng/L	2.00	2	--		5/11/23 20:47	MER	EPA 533	
0456	PFMBA Perfluoro-4-methoxybutanoic acid	ND	ng/L	2.00	2	--		5/11/23 20:47	MER	EPA 533	
0457	PFMPA Perfluoro-3-methoxypropanoic acid	ND	ng/L	2.00	2	--		5/11/23 20:47	MER	EPA 533	
0460	PFEESA Perfluoro(2-ethoxyethane) sulfonic acid	ND	ng/L	2.00	2	--		5/11/23 20:47	MER	EPA 533	

# Anatek Labs, Inc.

1282 Alturas Drive - Moscow, ID 83843 - (208) 883-2839 - email moscow@anateklabs.com  
504 E Sprague Ste. D - Spokane, WA 99202 - (509) 838-3999 - email spokane@anateklabs.com

**Client:** Hannah Heights  
**Address:** P.O. Box 1536  
Friday Harbor, WA 98250  
**Attn:** Paul Hart

**Work Order:** MDE0252  
**Project:** Friday Harbor Sampling  
**Reported:** 5/24/2023 14:38

## Analytical Results Report

System ID# 30850 System Name: Hannah Heights  
Reference Number: MDE0252-02 Collect Date: 05/03/23 09:30 DOH Source #: 02  
Multiple Source Nos: Sample Type: Before County: San Juan  
Date Received: 05/05/23 10:50 Sample Purpose: O - Other  
Sample Location: Upper Fracture Seep  
Matrix: Drinking Water

**Lab/Sample Number: 125-25202**

### Per- and Polyfluoroalkyl Substances (PFAS)

DOH #	Analyte	Result	Units	LRL	SDRL	SAL	MCL	Analyzed	Analyst	Method	Qualifier
0434	PFOA Perfluorooctanoic acid	373	ng/L	2.00	2	10		5/17/23 3:26	MER	EPA 533	
0433	PFOS Perfluorooctanesulfonic acid	9400	ng/L	2.00	2	15		5/17/23 3:26	MER	EPA 533	
0431	PFHxS Perfluorohexanesulfonic acid	7550	ng/L	2.00	2	65		5/17/23 3:26	MER	EPA 533	
0432	PFNA Perfluorononanoic acid	785	ng/L	2.00	2	9		5/17/23 3:26	MER	EPA 533	
0429	PFBS Perfluorobutanesulfonic acid	1110	ng/L	2.00	2	345		5/17/23 3:26	MER	EPA 533	
0430	PFHpA Perfluoroheptanoic acid	189	ng/L	2.00	2	--		5/17/23 3:26	MER	EPA 533	
0435	PFHxA Perfluorohexanoic acid	660	ng/L	2.00	2	--		5/17/23 3:26	MER	EPA 533	
0454	PFBA Perfluorobutanoic acid	138	ng/L	2.00	2	--		5/17/23 3:26	MER	EPA 533	
0455	PFHpS Perfluoroheptanesulfonic acid	293	ng/L	2.00	2	--		5/17/23 3:26	MER	EPA 533	
0458	PFPeA Perfluoropentanoic acid	323	ng/L	2.00	2	--		5/17/23 3:26	MER	EPA 533	
0459	PFPeS Perfluoropentanesulfonic acid	1180	ng/L	2.00	2	--		5/17/23 3:26	MER	EPA 533	

# Anatek Labs, Inc.

1282 Alturas Drive - Moscow, ID 83843 - (208) 883-2839 - email moscow@anateklabs.com  
504 E Sprague Ste. D - Spokane, WA 99202 - (509) 838-3999 - email spokane@anateklabs.com

**Client:** Hannah Heights  
**Address:** P.O. Box 1536  
Friday Harbor, WA 98250  
**Attn:** Paul Hart

**Work Order:** MDE0252  
**Project:** Friday Harbor Sampling  
**Reported:** 5/24/2023 14:38

## Analytical Results Report

System ID# 30850 System Name: Hannah Heights  
Reference Number: MDE0252-03 Collect Date: 05/03/23 09:20 DOH Source #: 02  
Multiple Source Nos: Sample Type: FRB County: San Juan  
Date Received: 05/05/23 10:50 Sample Purpose: O - Other  
Sample Location: Pitless Adaptor Field Blank  
Matrix: Drinking Water

Lab/Sample Number: 125-25203

### Per- and Polyfluoroalkyl Substances (PFAS)

DOH #	Analyte	Result	Units	LRL	SDRL	SAL	MCL	Analyzed	Analyst	Method	Qualifier
0434	PFOA Perfluorooctanoic acid	ND	ng/L	2.00	2	10		5/12/23 8:46	MER	EPA 533	
0433	PFOS Perfluorooctanesulfonic acid	ND	ng/L	2.00	2	15		5/12/23 8:46	MER	EPA 533	
0431	PFHxS Perfluorohexanesulfonic acid	ND	ng/L	2.00	2	65		5/12/23 8:46	MER	EPA 533	
0432	PFNA Perfluorononanoic acid	ND	ng/L	2.00	2	9		5/12/23 8:46	MER	EPA 533	
0429	PFBS Perfluorobutanesulfonic acid	ND	ng/L	2.00	2	345		5/12/23 8:46	MER	EPA 533	
0430	PFHpA Perfluoroheptanoic acid	ND	ng/L	2.00	2	--		5/12/23 8:46	MER	EPA 533	
0435	PFHxA Perfluorohexanoic acid	ND	ng/L	2.00	2	--		5/12/23 8:46	MER	EPA 533	
0436	PFDA Perfluorodecanoic acid	ND	ng/L	2.00	2	--		5/12/23 8:46	MER	EPA 533	
0437	PFUnA Perfluoroundecanoic acid	ND	ng/L	2.00	2	--		5/12/23 8:46	MER	EPA 533	
0438	PFDoA Perfluorododecanoic acid	ND	ng/L	2.00	2	--		5/12/23 8:46	MER	EPA 533	
0445	ADONA 4,8-Dioxa-3H-perfluorononanoic acid	ND	ng/L	2.00	2	--		5/12/23 8:46	MER	EPA 533	
0446	9Cl-PF3ONS	ND	ng/L	2.00	2	--		5/12/23 8:46	MER	EPA 533	
0447	HFPO-DA Hexafluoropropylene oxide dimer acid	ND	ng/L	2.00	2	--		5/12/23 8:46	MER	EPA 533	
0448	11Cl-PF3OUdS	ND	ng/L	2.00	2	--		5/12/23 8:46	MER	EPA 533	
0450	4:2FTS 1H,1H,2H,2H-Perfluorohexane sulfonic acid	ND	ng/L	2.00	2	--		5/12/23 8:46	MER	EPA 533	
0451	6:2FTS 1H,1H,2H,2H-Perfluorooctane sulfonic acid	ND	ng/L	2.00	2	--		5/12/23 8:46	MER	EPA 533	
0452	8:2FTS 1H,1H,2H,2H-Perfluorodecane sulfonic acid	ND	ng/L	2.00	2	--		5/12/23 8:46	MER	EPA 533	
0453	NFDHA Nonafluoro-3,6-dioxaheptanoic acid	ND	ng/L	2.00	2	--		5/12/23 8:46	MER	EPA 533	
0454	PFBA Perfluorobutanoic acid	ND	ng/L	2.00	2	--		5/12/23 8:46	MER	EPA 533	

# Anatek Labs, Inc.

1282 Alturas Drive - Moscow, ID 83843 - (208) 883-2839 - email moscow@anateklabs.com  
504 E Sprague Ste. D - Spokane, WA 99202 - (509) 838-3999 - email spokane@anateklabs.com

**Client:** Hannah Heights  
**Address:** P.O. Box 1536  
Friday Harbor, WA 98250  
**Attn:** Paul Hart

**Work Order:** MDE0252  
**Project:** Friday Harbor Sampling  
**Reported:** 5/24/2023 14:38

## Analytical Results Report

System ID# 30850 System Name: Hannah Heights  
Reference Number: MDE0252-03 Collect Date: 05/03/23 09:20 DOH Source #: 02  
Multiple Source Nos: Sample Type: FRB County: San Juan  
Date Received: 05/05/23 10:50 Sample Purpose: O - Other  
Sample Location: Pitless Adaptor Field Blank  
Matrix: Drinking Water

**Lab/Sample Number: 125-25203**

### Per- and Polyfluoroalkyl Substances (PFAS)

DOH #	Analyte	Result	Units	LRL	SDRL	SAL	MCL	Analyzed	Analyst	Method	Qualifier
0455	PFHpS Perfluoroheptanesulfonic acid	ND	ng/L	2.00	2	--		5/12/23 8:46	MER	EPA 533	
0456	PFMBA Perfluoro-4-methoxybutanoic acid	ND	ng/L	2.00	2	--		5/12/23 8:46	MER	EPA 533	
0457	PFMPA Perfluoro-3-methoxypropionic acid	ND	ng/L	2.00	2	--		5/12/23 8:46	MER	EPA 533	
0458	PFPeA Perfluoropentanoic acid	ND	ng/L	2.00	2	--		5/12/23 8:46	MER	EPA 533	
0459	PFPeS Perfluoropentanesulfonic acid	ND	ng/L	2.00	2	--		5/12/23 8:46	MER	EPA 533	
0460	PFEESA Perfluoro(2-ethoxyethane)sulfonic acid	ND	ng/L	2.00	2	--		5/12/23 8:46	MER	EPA 533	

# Anatek Labs, Inc.

1282 Alturas Drive - Moscow, ID 83843 - (208) 883-2839 - email moscow@anateklabs.com  
504 E Sprague Ste. D - Spokane, WA 99202 - (509) 838-3999 - email spokane@anateklabs.com

**Client:** Hannah Heights  
**Address:** P.O. Box 1536  
Friday Harbor, WA 98250  
**Attn:** Paul Hart

**Work Order:** MDE0252  
**Project:** Friday Harbor Sampling  
**Reported:** 5/24/2023 14:38

## Analytical Results Report

System ID# 30850 System Name: Hannah Heights  
Reference Number: MDE0252-04 Collect Date: 05/03/23 09:30 DOH Source #: 02  
Multiple Source Nos: Sample Type: FRB County: San Juan  
Date Received: 05/05/23 10:50 Sample Purpose: O - Other  
Sample Location: Upper Fracture Seep Field Blank  
Matrix: Drinking Water

**Lab/Sample Number: 125-25204**

### Per- and Polyfluoroalkyl Substances (PFAS)

DOH #	Analyte	Result	Units	LRL	SDRL	SAL	MCL	Analyzed	Analyst	Method	Qualifier
0434	PFOA Perfluorooctanoic acid	ND	ng/L	2.00	2	10		5/12/23 9:12	MER	EPA 533	
0433	PFOS Perfluorooctanesulfonic acid	ND	ng/L	2.00	2	15		5/12/23 9:12	MER	EPA 533	
0431	PFHxS Perfluorohexanesulfonic acid	ND	ng/L	2.00	2	65		5/12/23 9:12	MER	EPA 533	
0432	PFNA Perfluorononanoic acid	ND	ng/L	2.00	2	9		5/12/23 9:12	MER	EPA 533	
0429	PFBS Perfluorobutanesulfonic acid	ND	ng/L	2.00	2	345		5/12/23 9:12	MER	EPA 533	
0430	PFHpA Perfluoroheptanoic acid	ND	ng/L	2.00	2	--		5/12/23 9:12	MER	EPA 533	
0435	PFHxA Perfluorohexanoic acid	ND	ng/L	2.00	2	--		5/12/23 9:12	MER	EPA 533	
0436	PFDA Perfluorodecanoic acid	ND	ng/L	2.00	2	--		5/12/23 9:12	MER	EPA 533	
0437	PFUnA Perfluoroundecanoic acid	ND	ng/L	2.00	2	--		5/12/23 9:12	MER	EPA 533	
0438	PFDoA Perfluorododecanoic acid	ND	ng/L	2.00	2	--		5/12/23 9:12	MER	EPA 533	
0445	ADONA 4,8-Dioxa-3H-perfluorononanoic acid	ND	ng/L	2.00	2	--		5/12/23 9:12	MER	EPA 533	
0446	9Cl-PF3ONS	ND	ng/L	2.00	2	--		5/12/23 9:12	MER	EPA 533	
0447	HFPO-DA Hexafluoropropylene oxide dimer acid	ND	ng/L	2.00	2	--		5/12/23 9:12	MER	EPA 533	
0448	11Cl-PF3OUdS	ND	ng/L	2.00	2	--		5/12/23 9:12	MER	EPA 533	
0450	4:2FTS 1H,1H,2H,2H-Perfluorohexane sulfonic acid	ND	ng/L	2.00	2	--		5/12/23 9:12	MER	EPA 533	
0451	6:2FTS 1H,1H,2H,2H-Perfluorooctane sulfonic acid	ND	ng/L	2.00	2	--		5/12/23 9:12	MER	EPA 533	
0452	8:2FTS 1H,1H,2H,2H-Perfluorodecane sulfonic acid	ND	ng/L	2.00	2	--		5/12/23 9:12	MER	EPA 533	
0453	NFDHA Nonafluoro-3,6-dioxaheptanoic acid	ND	ng/L	2.00	2	--		5/12/23 9:12	MER	EPA 533	
0454	PFBA Perfluorobutanoic acid	ND	ng/L	2.00	2	--		5/12/23 9:12	MER	EPA 533	

# Anatek Labs, Inc.

1282 Alturas Drive - Moscow, ID 83843 - (208) 883-2839 - email moscow@anateklabs.com  
504 E Sprague Ste. D - Spokane, WA 99202 - (509) 838-3999 - email spokane@anateklabs.com

**Client:** Hannah Heights  
**Address:** P.O. Box 1536  
Friday Harbor, WA 98250  
**Attn:** Paul Hart

**Work Order:** MDE0252  
**Project:** Friday Harbor Sampling  
**Reported:** 5/24/2023 14:38

## Analytical Results Report

System ID# 30850 System Name: Hannah Heights  
Reference Number: MDE0252-04 Collect Date: 05/03/23 09:30 DOH Source #: 02  
Multiple Source Nos: Sample Type: FRB County: San Juan  
Date Received: 05/05/23 10:50 Sample Purpose: O - Other  
Sample Location: Upper Fracture Seep Field Blank  
Matrix: Drinking Water

**Lab/Sample Number: 125-25204**

### Per- and Polyfluoroalkyl Substances (PFAS)

DOH #	Analyte	Result	Units	LRL	SDRL	SAL	MCL	Analyzed	Analyst	Method	Qualifier
0455	PFHpS Perfluoroheptanesulfonic acid	ND	ng/L	2.00	2	--		5/12/23 9:12	MER	EPA 533	
0456	PFMBA Perfluoro-4-methoxybutanoic acid	ND	ng/L	2.00	2	--		5/12/23 9:12	MER	EPA 533	
0457	PFMPA Perfluoro-3-methoxypropionic acid	ND	ng/L	2.00	2	--		5/12/23 9:12	MER	EPA 533	
0458	PFPeA Perfluoropentanoic acid	ND	ng/L	2.00	2	--		5/12/23 9:12	MER	EPA 533	
0459	PFPeS Perfluoropentanesulfonic acid	ND	ng/L	2.00	2	--		5/12/23 9:12	MER	EPA 533	
0460	PFEESA Perfluoro(2-ethoxyethane)sulfonic acid	ND	ng/L	2.00	2	--		5/12/23 9:12	MER	EPA 533	

Authorized Signature,



Justin Doty For Todd Taruscio, Laboratory Manager

M12 Matrix spike recovery was low. Potential matrix effect.  
LRL Lab Reporting Limit  
SDRL State Detection Reporting Limit  
ND Not Detected  
MCL EPA's Maximum Contaminant Level  
Dry Sample results reported on a dry weight basis  
SAL State Action Level  
\* Not a certified analyte  
RPD Relative Percent Difference  
%REC Percent Recovery  
Source Sample that was spiked or duplicated.

This report shall not be reproduced except in full, without the written approval of the laboratory  
The results reported related only to the samples indicated.





# ANATEK LABS, INC - Multi-state Certified, NELAC Accredited

1282 Alturas Drive, Moscow ID 83843 208-883-2839 moscow@anateklabs.com EPA#  
 504 E Sprague Ste D, Spokane WA 99202 509-838-3999 spokane@anateklabs.com EPA#

MDE0252  
  
 Due: 05/19/23

## Washington Chain of Custody - Drinking Water Analysis

WATER SYSTEM	Hannah Heights Homeowners	Water System #	30850
SEND REPORT TO	Paul Hart	Phone Number	360.370.5350
ADDRESS	238 Straits View Dr	E-Mail	p.dudleyhart@gmail.com
CITY STATE ZIP	Friday Harbor, WA 98250	County	San Juan

<b>Sample Type</b> <input checked="" type="checkbox"/> Before (B) <input type="checkbox"/> After (A) <input type="checkbox"/> Unknown (U)	<b>Sample Purpose</b> <input type="checkbox"/> Compliance (C) <input checked="" type="checkbox"/> Investigative (I) <input type="checkbox"/> Other Purpose (B)	<b>Date &amp; Time Collected</b> 5/3/2023 0920
<b>Sampler Name:</b> Steve Hulsman		<b>Sampler Signature:</b> <i>Steve Hulsman</i>

Payment due with samples unless credit has been established

<b>Sample Location (required)</b>	pitless adaptor
<b>DOH Source # (Check one and fill in where necessary)</b>	
<input checked="" type="checkbox"/> Single Well Source Number:	502
<input type="checkbox"/> Flowing Distribution (92)	
<input type="checkbox"/> Composite Sampling (95) List source #'s	
<input type="checkbox"/> Blended Sample (96) List source #'s	

<b>Receiving Check List</b>	
<input type="checkbox"/> Received Intact	<input type="checkbox"/> No Headspace
<input type="checkbox"/> Labels & Chains Agree	<input type="checkbox"/> Temp: _____
<input type="checkbox"/> Ice/Ice-Packs Present: _____	
<input type="checkbox"/> Custody Seals Present: _____	
<input type="checkbox"/> Preservatives: _____	

### Check Desired Analyses

<b>IOCs</b> <input type="checkbox"/> Lead <input type="checkbox"/> Copper <input type="checkbox"/> Arsenic  <input type="checkbox"/> Nitrate  <input type="checkbox"/> Nitrite  <input type="checkbox"/> WA Complete IOC  <input type="checkbox"/> Asbestos	<b>VOCs &amp; DBPs</b> <input type="checkbox"/> VOC (VOC1) <input type="checkbox"/> TTHM <input type="checkbox"/> HAA5 <input type="checkbox"/> TOC <input type="checkbox"/> Alkalinity <b>RADs</b> <input type="checkbox"/> Gross Alpha <input type="checkbox"/> Gross Beta <input type="checkbox"/> RAD 226 <input type="checkbox"/> RAD 228 <input type="checkbox"/> Uranium	<b>SOCs</b> <input type="checkbox"/> Phase II SOC <input type="checkbox"/> Semivolatiles (PEST1) <input type="checkbox"/> Herbicides (HERB1) <input type="checkbox"/> Carbamates (INSECT1) <input type="checkbox"/> Pesticides (PEST1) <input type="checkbox"/> EDB <input type="checkbox"/> Phase V SOC <input type="checkbox"/> Diquat <input type="checkbox"/> Endothall <input type="checkbox"/> Glyphosate <input type="checkbox"/> Dioxin	<b>PFC/PFAS</b> <input checked="" type="checkbox"/> PFAS by EPA 533	<b>Other (specify):</b> Note - this sample likely has high levels of PFAS!
--	--	--	--	---

Customer Signature	<i>Steve Hulsman for Paul Hart</i>	Received By	<i>DA</i>
Shipping/Delivery Date	5/4/2023	Date/Time Rec'd	10:56 5/5/23

Samples submitted to Anatek Labs may be subcontracted to other accredited labs if necessary. This message serves as notice of this possibility. Subcontracted analyses will be clearly noted on the analytical report.



# ANATEK LABS, INC - Multi-state Certified, NELAC Accredited

1282 Alturas Drive, Moscow ID 83843 208-883-2839 moscow@anateklabs.com EPA# ID00013  
 504 E Sprague Ste D, Spokane WA 99202 509-838-3999 spokane@anateklabs.com EPA# WA00169

## Washington Chain of Custody - Drinking Water Analysis

WATER SYSTEM	Hannah Heights Homeowners	Water System #	30850
SEND REPORT TO	Paul Hart	Phone Number	360.370.5350
ADDRESS	238 Straits View Dr	E-Mail	pdudleyhart@gmail.com
CITY STATE ZIP	Friday Harbor, WA 98250	County	San Juan

<b>Sample Type</b> <input checked="" type="checkbox"/> Before (B) <input type="checkbox"/> After (A) <input type="checkbox"/> Unknown (U)	<b>Sample Purpose</b> <input type="checkbox"/> Compliance (C) <input type="checkbox"/> Investigative (I) <input checked="" type="checkbox"/> Other Purpose (B)	<b>Date &amp; Time Collected</b> 5/3/2023 0920-0935	Payment due with samples unless credit has been established
		<b>Sampler Name:</b> Steve Hulsman/Jim Mauldin	
		<b>Sampler Signature:</b> 	

<b>Sample Location (required)</b>	upper fracture seep
<b>DOH Source # (Check one and fill in where necessary)</b>	
<input checked="" type="checkbox"/> Single Well Source Number:	502
<input type="checkbox"/> Flowing Distribution (92)	
<input type="checkbox"/> Composite Sampling (95) List source #'s	
<input type="checkbox"/> Blended Sample (96) List source #'s	

<b>Receiving Check List</b>	
<input type="checkbox"/> Received Intact	<input type="checkbox"/> No Headspace
<input type="checkbox"/> Labels & Chains Agree	<input type="checkbox"/> Temp: _____
<input type="checkbox"/> Ice/Ice-Packs Present: _____	
<input type="checkbox"/> Custody Seals Present: _____	
<input type="checkbox"/> Preservatives: _____	

### Check Desired Analyses

<b>IOCs</b> <input type="checkbox"/> Lead <input type="checkbox"/> Copper <input type="checkbox"/> Arsenic <input type="checkbox"/> Nitrate <input type="checkbox"/> Nitrite <input type="checkbox"/> WA Complete IOC <input type="checkbox"/> Asbestos	<b>VOCs &amp; DBPs</b> <input type="checkbox"/> VOC (VOC1) <input type="checkbox"/> TTHM <input type="checkbox"/> HAA5 <input type="checkbox"/> TOC <input type="checkbox"/> Alkalinity <b>RADs</b> <input type="checkbox"/> Gross Alpha <input type="checkbox"/> Gross Beta <input type="checkbox"/> RAD 226 <input type="checkbox"/> RAD 228 <input type="checkbox"/> Uranium	<b>SOCs</b> <input type="checkbox"/> Phase II SOC <input type="checkbox"/> Semivolatiles (PEST1) <input type="checkbox"/> Herbicides (HERB1) <input type="checkbox"/> Carbamates (INSECT1) <input type="checkbox"/> Pesticides (PEST1) <input type="checkbox"/> EDB <input type="checkbox"/> Phase V SOC <input type="checkbox"/> Diquat <input type="checkbox"/> Endothall <input type="checkbox"/> Glyphosate <input type="checkbox"/> Dioxin	<b>PFC/PFAS</b> <input checked="" type="checkbox"/> PFAS by EPA 533	<b>Other (specify):</b> Note - this sample may have high levels of PFAS! This sample is labeled "Well 2-dip"
--	--	--	--	--

Customer Signature	Steve Hulsman for Paul Hart	Received By	JA
Shipping/Delivery Date	5/4/2023	Date/Time Rec'd	10:24 5/5/23

Samples submitted to Anatek Labs may be subcontracted to other accredited labs if necessary. This message serves as notice of this possibility. Subcontracted analyses will be clearly noted on the analytical report.



Sample Receipt and Preservation Form

Client Name: Hannah Heights

TAT: Normal RUSH: \_\_\_\_\_ days

Samples Received From: FedEx  UPS  USPS  Client  Courier  Other: \_\_\_\_\_

Custody Seal on Cooler/Box: Yes  No  Custody Seals Intact: Yes  No  N/A

Number of Coolers/Boxes: \_\_\_\_\_ Type of Ice: Wet Ice Ice Packs  Dry Ice  None

Packing Material: Bubble Wrap  Bags  Foam/Peanuts  Paper  None  Other: \_\_\_\_\_

Cooler Temp As Read (°C): 1.7 Cooler Temp Corrected (°C): \_\_\_\_\_ Thermometer Used: IR-S

Comments:

Samples Received Intact?	<input checked="" type="checkbox"/> Yes	No	N/A
Chain of Custody Present/Complete?	<input checked="" type="checkbox"/> Yes	No	N/A
Labels and Chains Agree?	<input checked="" type="checkbox"/> Yes	No	N/A
Samples Received Within Hold Time?	<input checked="" type="checkbox"/> Yes	No	N/A
Correct Containers Received?	<input checked="" type="checkbox"/> Yes	No	N/A
Anatek Bottles Used?	<input checked="" type="checkbox"/> Yes	No	Unknown

Total Number of Sample Bottles Received: 6 ZODAGIS


Samples Properly Preserved?  Yes No N/A

*If No, record preservation and pH-alter details*

VOC Vials Free of Headspace (<6mm)? Yes No N/A

VOC Trip Blanks Present? Yes No N/A

Initial pH: \_\_\_\_\_ pH Paper ID: \_\_\_\_\_

<2	or	

Record preservatives (and lot numbers, if known) for containers below:

P250 NH<sub>4</sub>Ac x 3 x 2

Notes, comments, etc. (also use this space if contacting the client - record names and date/time)

Received/Inspected By: [Signature] Date/Time: 10:24 5/5/23

Form F19.01 - Eff 1 Dec 2022