



WA LEAK TESTING CHECKLIST FOR UNDERGROUND STORAGE TANKS (USTS)

UST ID #: 7681
County: Grays Harbor

This checklist certifies testing activities conducted in accordance with Chapter 173-360A WAC. Read instructions on pages 4-7.

<input checked="" type="checkbox"/> PASS - All Section VI services performed have passing results. <input type="checkbox"/> FAIL - One or more components tested in Section VI require repair and re-testing.		DATE TESTS CONDUCTED: 05/03/2023
I. UST FACILITY		
Facility Compliance Tag #: <u>A4311</u>	II. CERTIFIED SERVICE PROVIDER	
UST ID #: 7681	Service Provider Name: Tyler Hardy	
Site Name: 2709660	Company Name: Northwest Tank & Environmental Services, Inc.	
Site Address: 220 Lincoln Street	Address: 21120 Hwy 9 SE	
City: Hoquiam	City: Woodinville	State: WA Zip: 98072
County: Grays Harbor	Phone: (800) 742-9620 Email: info@nwtank.com	
Site Phone: (602)728-8000 Ext 7233	ICC Certification Type: Tightness Testing ICBO- U3	
	ICC Cert. #: 8176598	Exp. Date: 12/22/2023
III. UST OWNER/OPERATOR		
Name: Circle K Stores Inc Phone: 951-270-5108 Email: yjones@circlek.com		
IV. UST SYSTEM INFORMATION Observations on test day.		
1. Tank ID #, as registered with Ecology or identified on ATG	1	2
2. Tank Status. OP (Operational); TC (Temporary Closure)	OP	OP
3. Product stored, including % of alternative fuels	Premium	Regular
4. Tank or compartment capacity (gallons)	7,841	14,976
5. Product pumping/flow method. Note as: P (Pressurized); NS (Non-safe Suction); SS (Safe Suction); Si (Siphon); GR (Gravity Fed)	Pressure	Pressure
Abbreviations for lines 5 and 6 below: Steel (ST); Fiberglass (FRP); Clad Steel (CLAD); Flexible (FLEX); Double Wall (DW); Single Wall (SW); Not Visible (NV)		
6. Tank material and construction observed	DWF	DWF
7. Pipe material and construction observed	DWF	DWF
V. REASON FOR SERVICES PERFORMED (Check all that apply)		
<input checked="" type="checkbox"/> Annual testing <input type="checkbox"/> 3-year testing	<input type="checkbox"/> Test after install/repair <input type="checkbox"/> Return UST system to operation	<input type="checkbox"/> Other (explain):

VI. SERVICES PERFORMED
Required: Include verification for each test performed.

		#
#PASS	#FAIL	REPAIRED& PASSING
SERVICES:	DESCRIPTIONS REQUIRED: (SEE INSTRUCTIONS P. 4-7)	
ALLD Test (attach data)	2	
Test method used: LDT 890		
Test method cert.exp.date: 5/3/2024		
Line Tightness Test (attach data)	2	
Test method used: Acurite		
Test method cert.exp.date: 5/3/2024		
Electronic Monitoring System Tests		
Controller.mfr/model: V-R TLS 350		
Controller cert.exp.date: 5/3/2024		
Monitor/controller	1	
Probe	2	
Sump Sensor Functionality	2	
Tank Annular Sensor Functionality	2	
Overfill Equipment Test		
<input type="checkbox"/> Auto shutoff <input type="checkbox"/> Ball float valve <input type="checkbox"/> Overfill alarm		
Fill/Spill Bucket Test (attach data)		
Tank-Top or Transition Sump Test (attach data)		
UDC Sump Test (attach data)		
Tank Tightness Test (attach data)		
3rd-party certified test:		
Test method used: N/A		
Test method cert.exp.date:		
Other		

VII. EXPLANATIONS/PROBLEMS ENCOUNTERED:

Provide additional test information. Explain irregularities. Describe problems encountered and how addressed..

Leak Detector:
 Comments - Tied into and tested from impacts in dispenser.
 All ALLDs passed the 3 GPH test in accordance with CFR 40 part 280.44.

Line Test:
 Comments - Tied into and tested from impacts in dispenser.
 All lines passed the 0.01 GPH test in accordance with CFR 40 part 280.44

Tank Monitor:
 --Tank_monitors--
 #1: TLS 350 was tested per RP 1200 standards.
 Probes were removed and tested for high product, overfill, high water warning, and high water alarm.

Liquid sensors were tested and confirmed operational to manufacturer specifications.

High level alarm was functionally tested to RP 1200 standards by raising the product floats to 90% capacity and was confirmed operational.

WA Leak Testing Checklist:

Comments - Leak Detector:

Comments - Tied into and tested from impacts in dispenser.

All ALLDs passed the 3 GPH test in accordance with CFR 40 part 280.44.

Line Test:

Comments - Tied into and tested from impacts in dispenser.

All lines passed the 0.01 GPH test in accordance with CFR 40 part 280.44

Tank Monitor:

--Tank_monitors--

#1: TLS 350 was tested per RP 1200 standards.


Probes were removed and tested for high product, overfill, high water warning, and high water alarm.

Liquid sensors were tested and confirmed operational to manufacturer specifications.

High level alarm was functionally tested to RP 1200 standards by raising the product floats to 90% capacity and was confirmed operational.

VIII. UST SITE AND SYSTEM DIAGRAM

Diagram required. Include North arrow.



ATG

PERSONS SUBMITTING FALSE INFORMATION ARE SUBJECT TO FORMAL ENFORCEMENT AND/OR PENALTIES UNDER CHAPTER 173-360A WAC.

IX. FINAL CHECK

Mark the following:	YES	NO	N/A
1. All checked services tested per recommended practices, code and/or manufacturer's requirements, and in accordance with state regulations.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2. Owner/operator provided with copy of the checklist and testing results.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3. Any faulty equipment or necessary repairs explained to owner/operator or site contact.	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

X. REQUIRED SIGNATURES

05/03/2023

Tyler Hardy - Tech

Date

Signature of Certified Service Provider

Print or Type Name

11/14/2023

Reyna Mendez

Date

Signature of Tank Owner or Authorized Representative

Print or Type Name

Automatic Line Leak Detector Test Results

Company Name: Circle K Stores Inc
Site Name: 2709660
Address: 220 Lincoln Street Hoquiam, WA 98550-1850
UST Site ID: 7681
Test Date/Time: 05/03/2023 09:00:10 am

Job ID Number: 116743
Technician Name: Tyler Hardy
License Number: 8176598
Expiration Date: 12/22/2023

Product: Premium Tank ID: 1 LD Type: Mechanical	Make: FE Petro Model: STP MLD Serial#:	Operating Pressure: 30 Holding Pressure: 20 Bleedback (ml): 150	Result: Pass
Additional Data For Mechanical Leak Detectors Only Metering Pressure: 10 Step Through Time: 2			
Product: Regular Tank ID: 2 LD Type: Mechanical	Make: VMI Model: LD2000 Serial#:	Operating Pressure: 30 Holding Pressure: 30 Bleedback (ml): 75	Result: Pass
Additional Data For Mechanical Leak Detectors Only Metering Pressure: 19 Step Through Time: 1			

Leak detector testing conducted in accordance with the procedures and limitations of the LDT 890 leak detector tester. A leak is simulated at the highest point in the line using the LDT 890 calibrated to 3 gph at a metering pressure of 10 psi. The owner or operator of the UST system is required to ensure any failed leak detector is replaced before placing the line back in service.

The results of any sampling, testing, or monitoring shall be maintained for at least five years, or for another reasonable period of time determined by the department or delegated agency, except that the results of tank tightness testing conducted in accordance with CFR 40 Part 280.44 shall be retained until the next test is conducted.

Comments: Tied into and tested from impacts in dispenser. All ALLDs passed the 3 GPH test in accordance with CFR 40 part 280.44.

Technician Name: Tyler Hardy
Signature:



Date: 05/03/2023

Line Tightness Test Results

Company Name: Circle K Stores Inc
 Site Name: 2709660
 Address: 220 Lincoln Street Hoquiam, WA 98550-1850
 UST Site ID: 7681
 Test Date: 05/03/2023

Job ID Number: 116743
 Technician Name: Tyler Hardy
 License Number: 8176598
 Expiration Date: 12/22/2023

Line Tightness Test Data

Product:	Premium	Tank ID:	1	Start Time:	10:07
Approx Length:		STP MFG:		End Time:	10:37
Size:		Operating Pressure:	30	Total Test Time:	30mins
Line Material:	FRP	Test Pressure:	45	Final Leak Rate:	.00500
Wall Type:	DW	Isolation Dispenser:	Impact Valve	Impact Valves Operational:	Yes
Boot Back:	Yes	Isolation Pump:	Ball Valve	Check Valve Location:	N/A
Line Type:	Pressure	Initial Cylinder Level:	.1	Result:	Pass
		Final Cylinder Level:	.0975		

Product:	Regular	Tank ID:	2	Start Time:	10:07
Approx Length:		STP MFG:		End Time:	10:37
Size:		Operating Pressure:	30	Total Test Time:	30mins
Line Material:	FRP	Test Pressure:	45	Final Leak Rate:	.00500
Wall Type:	DW	Isolation Dispenser:	Impact Valve	Impact Valves Operational:	Yes
Boot Back:	Yes	Isolation Pump:	Ball Valve	Check Valve Location:	N/A
Line Type:	Pressure	Initial Cylinder Level:	.1	Result:	Pass
		Final Cylinder Level:	.0975		

Line tightness testing conducted in accordance with the procedures and limitations of the Acurite pipeline tester. A consistent leak rate of .01 gph or higher at 150% of normal operating pressure is considered a failure. The owner or operator of the UST system is required to report all failures to the appropriate agency within 24 hours.

The results of any sampling, testing, or monitoring shall be maintained for at least five years, or for another reasonable period of time determined by the department or delegated agency, except that the results of tank tightness testing conducted in accordance with CFR 40 Part 280.44 shall be retained until the next test is conducted.

Comments: Tied into and tested from impacts in dispenser. All lines passed the 0.01 GPH test in accordance with CFR 40 part 280.44

Technician Name: Tyler Hardy

Signature:



Date: 05/03/2023

Monitoring System Certification

This form must be used to document testing and servicing of monitoring equipment. A separate certification or report must be prepared for each monitoring system control panel by the technician who performs the work. A copy of this form must be provided to the tank system owner/operator. The owner/operator must submit a copy of this form to the local agency regulating UST systems within 30 days of test date.

A. General Information

Facility Contact Person: Reyna Mendez
Make / Model Monitoring System: V-R TLS 350

Company Name: Circle K Stores Inc
Site Address: 220 Lincoln Street
UST Site ID: 7681
Date Of Testing: 05/03/2023
Site Name: 2709660
City, State, ZIP: Hoquiam, WA 98550-1850
Facility Phone Number: (602)728-8000 Ext 7233
Serial #: 40421402103001

B. Inventory of Equipment Tested/Certified

Tank #: 1 Premium		Tank #: 2 Regular	
In-Tank Gauging Probe	Mag 1 Probe	In-Tank Gauging Probe	Mag 1 Probe
Annular Space or Vault Sensor:	794380-301	Annular Space or Vault Sensor:	794380-301
Piping Sump / Trench Sensor:	794380-323	Piping Sump / Trench Sensor:	794380-323
Fill Sump Sensor:	N/A	Fill Sump Sensor:	N/A
Mechanical Line Leak Detector:	STP MLD	Mechanical Line Leak Detector:	LD2000
Electronic Line Leak Detector:	N/A	Electronic Line Leak Detector:	N/A
Tank Overfill / High Level Sensor:	VR-001	Tank Overfill / High Level Sensor:	VR-001
Other:		Other:	

C. Certification

I certify that the equipment identified in this document was inspected/serviced in accordance with the manufacturers' guidelines. Attached to this certification is information (e.g. manufacturers' checklists) necessary to verify that this information is correct and a Plot Plan showing the layout of monitoring equipment. For any equipment capable of generating such reports, I have also attached a copy of the report (check all that apply):

Technician Name: Tyler Hardy	Testing Company Name: Northwest Tank & Environmental Services, Inc.
Certification Number:	Address: 21120 Hwy 9 SE Woodinville, WA 98072
Expiration Date:	Date of Testing: 05/03/2023
Signature:	



D. Results of Testing/Service

Yes	Is the audible alarm operational?
Yes	Is the visual alarm operational?
Yes	Were all sensors visually inspected, functionally tested, and confirmed operational?
Yes	If alarms are relayed to a remote monitoring station, is all communications equipment operational?
No	For pressurized piping systems, does the turbine automatically shut down if the piping secondary containment monitoring system detects a leak, fails to operate, or is electrically disconnected?
N/A	If yes: which sensors initiate positive shut-down?
No	Did you confirm positive shut-down due to leaks and sensor failure/disconnection?
Yes	For tank systems that utilize the monitoring system as the primary tank overflow warning device (i.e. no mechanical overflow prevention valve is installed), is the overflow warning alarm visible and audible at the tank fill point(s) and operating properly?
90%	If so, at what percent of tank capacity does the alarm trigger?
No	Was any monitoring equipment replaced? If yes, identify specific sensors, probes or other equipment replaced and list the manufacturer name and model for all replacement parts in Section E below.
No	Was liquid found in any secondary containment systems designed as dry systems?
N/A	If yes, what type of liquid?
Yes	Was monitoring system set-up reviewed to ensure proper settings? Attach setup reports, if applicable.
Yes	Is all monitoring equipment operational per manufacturers specifications?

In section E. below, describe how and when these deficiencies were or will be corrected.

E. Comments

TLS 350 was tested per RP 1200 standards. Probes were removed and tested for high product, overflow, high water warning, and high water alarm. Liquid sensors were tested and confirmed operational to manufacturer specifications. High level alarm was functionally tested to RP 1200 standards by raising the product floats to 90% capacity and was confirmed operational.

State Tank ID	Product	Manual Stick Readings(inches)	Gauge Readings(inches)	Difference
1	Premium	37.5	37.48	.02
2	Regular	43	43.17	-.17

F. In-Tank Gauging / SIR Equipment

This section must be completed if in-tank gauging equipment is used to perform leak detection monitoring.

Yes	Has all input wiring been inspected for proper entry and termination, including testing for ground faults?
Yes	Were all tank gauging probes visually inspected for damage and residue buildup?
Yes	Was accuracy of system product level readings tested?
Yes	Was accuracy of system water level readings tested?
Yes	Were all probes reinstalled properly?
Yes	Were all items on the equipment manufacturer's maintenance checklist completed?

G. Line Leak Detectors (LLD):

Yes	For equipment startup or annual equipment certification, was leak simulated to verify LLD performance?
3 GPH	Leak Rate
Yes	Were all LLDs confirmed operational and accurate within regulatory requirements?
Yes	Was the testing apparatus properly calibrated?
Yes	For mechanical LLDs, does the LLD restrict product flow if it detects a leak?
N/A	For electronic LLDs, does the turbine automatically shut off if the LLD detects a leak?
N/A	For electronic LLDs, does the turbine automatically shut off if any portion of the monitoring system is disabled or disconnected?
N/A	For electronic LLDs, does the turbine automatically shut off if any portion of the monitoring system malfunctions or fails a test?
N/A	For electronic LLDs, have all accessible wiring connections been visually inspected?
Yes	Were all items on the equipment manufacturer's maintenance checklist completed?



DEPARTMENT OF
ECOLOGY

UST WALKTHROUGH INSPECTIONS CHECKLIST

Circle K 2709660

220 Lincoln Street, Hoquiam, WA

Site Name

Site Address

Tag #

- Initial each box to indicate the equipment was inspected, as described. Use NA if the equipment inspection does not apply to the site.
- Take action for any alarms, damaged equipment and non-normal operating conditions; note actions taken on page 2
- NOTE: Petroleum found in a sump or interstice must be reported to Ecology within 24 hours.

YEAR: 2023 _____	Date of Inspection →											
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
REQUIRED MONTHLY												
Spill bucket(s) checked for damage and cracks*. Liquid and/or debris removed.					HA							
Fill pipe(s) checked for obstructions. Removed, if found.					HA							
Fill cap(s) securely fitted on fill pipe(s).					HA							
Tank monitor equipment checked for alarms and normal operating condition.					HA							
Leak detection records are reviewed for non-leaking results and kept for three years. Suspected leaks were reported.					HA							
REQUIRED ANNUALLY												
Containment sump(s) checked for damage and presence of liquid. Liquid and/or debris removed.					HA							
If using manual tank gauging , checked condition of tank gauge stick is good (e.g. readable at 1/8" increments throughout).												
RECOMMENDED ACTIVITIES												
Emergency spill response supplies inventoried and restocked if low. Inspected supplies for deterioration.					HA							
Inspected loose fitting, deterioration, obvious signs of leaks and improper function of dispenser hoses, nozzles and breakaways.					HA							

*If a tank receives deliveries at intervals greater than 30 days, the spill bucket check may instead be conducted prior to each delivery. To be eligible for this option, include a copy of each delivery receipt with this form.

Note: This checklist doesn't include the requirement to inspect hydrant pits and piping vaults at airport hydrant systems at least every 30 days.

