

**DEPARTMENT OF ECOLOGY**  
**NORTHWEST REGIONAL OFFICE**  
*COVER SHEET / REQUEST FORM*

DATE: 09/29/98 TIME: 1615 NUMBER OF PAGES: 12  
TO: DAVE COOK FAX #: (206) 728-2732  
FROM: BOB WING - (425) 649-7235 Central Files FAX #: (425) 649-7098

DAVE,

I'M SENDING ALL RECORDS ON FILE PER YOUR REQUEST. THERE NO WELL LOGS FOR SECTIONS 19 AND 20. IF I CAN BE OF FURTHER HELP I CAN BE REACHED AT THE ABOVE NUMBER.

BOB

File Original and First Copy with  
Department of Ecology  
Second Copy — Owner's Copy  
Third Copy — Driller's Copy

# WATER WELL REPORT

## STATE OF WASHINGTON

Application No. \_\_\_\_\_

Permit No. \_\_\_\_\_

(1) OWNER: Name Seattle water Dept. Address 821 Second Ave Seattle  
(2) LOCATION OF WELL: County KING & SE & Sec 8 T. 24 N. R. 4E W. W  
Bearing and distance from section or subdivision corner water Dept. operations center Airport way

(3) PROPOSED USE: Domestic ☐ Industrial ☐ Municipal ☐  
Cathod well Irrigation ☐ Test Well ☐ Other ☒

(4) TYPE OF WORK: Owner's number of well (if more than one) 5  
New well ☒ Method: Dug ☐ Bored ☐  
Deepened ☐ Cable ☒ Driven ☐  
Reconditioned ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 8 inches.  
Drilled 300 ft. Depth of completed well 300 ft.

**(6) CONSTRUCTION DETAILS:**

Casing installed: 8 " Diam. from 41 ft. to 300 ft.  
Threaded ☐ " Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Welded ☒ " Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Perforations: Yes ☐ No ☒

Type of perforator used \_\_\_\_\_  
SIZE of perforations \_\_\_\_\_ in. by \_\_\_\_\_ in.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Screens: Yes ☐ No ☒

Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Gravel packed: Yes ☐ No ☒ Size of gravel \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Surface seal: Yes ☐ No ☒ To what depth? \_\_\_\_\_ ft.  
Material used in seal \_\_\_\_\_  
Did any strata contain unusable water? Yes ☐ No ☐  
Type of water? \_\_\_\_\_ Depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_

(7) PUMP: Manufacturer's Name N/A  
Type: \_\_\_\_\_ H.P. \_\_\_\_\_

(8) WATER LEVELS: Land-surface elevation above mean sea level \_\_\_\_\_ ft.  
Static level \_\_\_\_\_ ft. below top of well Date \_\_\_\_\_  
Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_  
Artesian water is controlled by \_\_\_\_\_ (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? Yes ☐ No ☐ If yes, by whom? \_\_\_\_\_  
Yield: \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

| Time | Water Level | Time | Water Level | Time | Water Level |
|------|-------------|------|-------------|------|-------------|
|      |             |      |             |      |             |

Date of test \_\_\_\_\_  
Bailer test \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Artesian flow \_\_\_\_\_ g.p.m. Date \_\_\_\_\_  
Temperature of water \_\_\_\_\_ Was a chemical analysis made? Yes ☐ No ☐

**(10) WELL LOG:**

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

| MATERIAL                          | FROM | TO  |
|-----------------------------------|------|-----|
| Dark Brown sand gravel clay       | 0    | 3   |
| Dark Brown sand clay rocks        | 3    | 10  |
| Brown sandy clay gravel rock      | 10   | 35  |
| Brown coarse sand clay rocks      | 35   | 80  |
| light gray sand clay gravel H.C.  | 80   | 106 |
| gray sand clay gravel H.C.        | 106  | 126 |
| gray silt. sand gravel rocks H.C. | 126  | 160 |
| gray sand silt. clay gravel H.C.  | 160  | 300 |

# RECEIVED

AUG 29 1983

# DEPT. OF ECOLOGY

Work started MAY 4 1983. Completed MAY 26 1983

**WELL DRILLER'S STATEMENT:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME B & J Drilling Co  
(Person, firm, or corporation) (Type or print)

Address 9026 38th Ave SW Seattle

[Signed] Danell Cannon R. J. Law  
(Well Driller)

License No. 0924 Date 8/28 1983

☒ 003/012

24/04/17M

File Original and First Copy with  
Department of Ecology  
Second Copy — Owner's Copy  
Third Copy — Driller's Copy

# WATER WELL REPORT

Application No. \_\_\_\_\_

STATE OF WASHINGTON

**Petunt No.** . . . . .

(1) OWNER: Name City of Seattle, Seattle City Light Address 1015 3rd Ave, Seattle, WA. 98104

(2) LOCATION OF WELL: County, King NW  $\frac{1}{4}$  SW  $\frac{1}{4}$  Sec. 17 T. 29 N. R. 45 W.

Bearing and distance from section or subdivision corner Seattle City Light Pole Yard, southeast corner

(3) **PROPOSED USE:** Domestic ☐ Industrial ☐ Municipal ☐  
Irrigation ☐ Test Well ☒ Other ☐

(4) TYPE OF WORK: Owner's number of well PW-1  
(if more than one) ...

|               |                                     |             |                                     |        |                          |
|---------------|-------------------------------------|-------------|-------------------------------------|--------|--------------------------|
| New well      | <input checked="" type="checkbox"/> | Method: Dug | <input type="checkbox"/>            | Bored  | <input type="checkbox"/> |
| Deepened      | <input type="checkbox"/>            | Cable       | <input checked="" type="checkbox"/> | Driven | <input type="checkbox"/> |
| Reconditioned | <input type="checkbox"/>            | Rotary      | <input type="checkbox"/>            | Jetted | <input type="checkbox"/> |

(5) **DIMENSIONS:** Diameter of well 4 inches.  
Drilled 20.5 ft. Depth of completed well 19.5 ft.

(6) CONSTRUCTION DETAILS: single piece

Casing installed: 34 Diam. from +2 ft. to -3 ft.

Threaded ☐ " Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Welded ☐ " Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**Perforations:** Yes ☐ No ☒  
 Type of perforator used \_\_\_\_\_  
 SIZE of perforations \_\_\_\_\_ in. by \_\_\_\_\_ in.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Screens: Yes ☒ No ☐

Manufacturer's Name \_\_\_\_\_

Type slot stainless Model No. \_\_\_\_\_

Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ from \_\_\_\_\_ to \_\_\_\_\_

Diam. 4 1/2" Slot size .01" from 14 to 18

Gravel packed: yes ☒ No ☐ Size of gravel: \_\_\_\_\_  
Gravel placed from 10.5 ft. to 20 ft.

Surface seal: Yes ☒ No ☐ To what depth? 3.5 & 10.5 m  
Material used in seal Concrete & Bentonite  
Did any strata contain unusable water? Yes ☐ No ☐  
N/A Type of water? \_\_\_\_\_ Depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_

(7) PUMP: Manufacturer's Name.....  
N/A Type: ..... HP.....

(8) **WATER LEVELS:** Land-surface elevation above mean sea level... ~10.5 ft.  
 Static level 12.052 ft. below top of well Date 30 Dec  
 Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_  
 Artesian water is controlled by \_\_\_\_\_ (Cap. valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? Yes ☐ No ☒ If yes, by whom? .....

Yield: \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs

|    |    |    |    |
|----|----|----|----|
| 11 | 41 | 31 | 21 |
| 22 | 42 | 32 | 22 |

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

| Time | Water Level | Time | Water Level | Time | Water Level |
|------|-------------|------|-------------|------|-------------|
|------|-------------|------|-------------|------|-------------|

=====

Date of test: 15 Dec

Bailer test: 3.9 gal./min. with 0 ft. drawdown after 0.1 hrs.

Artesian flow..... g.p.m. Date.....  
Temperature of water 15.35 °C Was a chemical analysis made? Yes ☒ No ☐

(10) WELL LOG: Monitor Well

**Formation:** Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

| MATERIAL | FROM | TO |
|----------|------|----|
| ASPHALT  | 0"   | 3" |

|                                                                                                       |    |    |
|-------------------------------------------------------------------------------------------------------|----|----|
| SILT: Dark gray, sandy, gritty<br>(to 3mm) silt; little or no clay;<br>sand and grit is multicolored. | 3" | 8' |
|-------------------------------------------------------------------------------------------------------|----|----|

|                                                                                                                                                                         |    |     |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----|-----|
| SAND: Green-gray, gritty, gravelly sand with grains up to 10 mm and angular to subrounded; some large (100 mm) fragments of brick, concrete, and small pieces of glass. | 8' | 14' |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----|-----|

|                                                                                                                                                              |     |     |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------|-----|-----|
| SILT: Very dark gray, clayey<br>silt, with common, brown,<br>woody fragments, and<br>angular to rounded rock<br>fragments up to 30mm.<br>This unit is moist. | 14' | 19' |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------|-----|-----|

|                                                              |     |       |
|--------------------------------------------------------------|-----|-------|
| SAND: Green-gray, silty, clean sand. This unit is saturated. | 19' | 20.5' |
|--------------------------------------------------------------|-----|-------|

## AQUIFERS :

Moist: from 14" to 19"  
Saturated: below 19"

Note: all units below asphalt are unconsolidated.

Work started 12-11, 1986 Completed 12-15, 1986

**WELL DRILLER'S STATEMENT:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Holt Drilling Co  
(Person, firm, or corporation) (Type or print)

Address. Puyallup WA

[Signed] (Jack)

License No. \_\_\_\_\_ Date \_\_\_\_\_ 19 \_\_\_\_\_

24/04/17M

File Original and First Copy with  
Department of Ecology  
Second Copy — Owner's Copy  
Third Copy — Driller's Copy

## WATER WELL REPORT

STATE OF WASHINGTON

Application No. ....

Permit No. ....

(1) OWNER: Name City of Seattle Seattle City Light Address 1015 3rd Ave, Seattle, WA 98104(2) LOCATION OF WELL: County King NW 1/4 SW 1/4 Sec. 17 T. 24 N. R. 4E W. M.Bearing and distance from section or subdivision corner Seattle City Light Pole Yard, Southwest corner(3) PROPOSED USE: Domestic ☐ Industrial ☐ Municipal ☐  
Irrigation ☐ Test Well ☒ Other ☐(4) TYPE OF WORK: Owner's number of well PW-2  
(If more than one) New well ☒ Method: Dug ☐ Bored ☐  
Deepened ☐ Cable ☒ Driven ☐  
Reconditioned ☐ Rotary ☐ Jetted ☐(5) DIMENSIONS: Diameter of well 8 1/4 inches.  
Drilled 25.5 ft. Depth of completed well 23.5 ft.(6) CONSTRUCTION DETAILS: single piece  
Casing installed: 8 1/4" Diam. from +1.2 ft. to -3.8 ft.  
Threaded ☐ " Diam. from " ft. to " ft.  
Welded ☐ " Diam. from " ft. to " ft.Perforations: Yes ☐ No ☒  
Type of perforator used .....  
SIZE of perforations ..... in. by ..... in.  
..... perforations from ..... ft. to ..... ft.  
..... perforations from ..... ft. to ..... ft.  
..... perforations from ..... ft. to ..... ft.Screens: Yes ☒ No ☐  
Manufacturer's Name .....  
Type Slotless stainless Model No. 18  
Diam. 4" Slot size .01" from ..... ft. to 23.5 ft.  
Diam. .... Slot size ..... from ..... ft. to ..... ft.Gravel packed: Yes ☒ No ☐ Size of gravel: .....  
Gravel placed from 16 ft. to 25 ft.Surface seal: Yes ☒ No ☐ To what depth? 3.5 ft. / 16 ft.  
Material used in seal concrete & bentonite  
Did any strata contain unusable water? Yes ☐ No ☒  
N/A Type of water? ..... Depth of strata .....  
Method of sealing strata off .....(7) PUMP: Manufacturer's Name .....  
N/A Type: ..... HP .....(8) WATER LEVELS: Land-surface elevation ~10.0 ft.  
above mean sea level. Static level 11.69 ft. below top of well Date 30 Dec  
Artesian pressure ..... lbs. per square inch Date .....  
Artesian water is controlled by ..... (Cap, valve, etc.)(9) WELL TESTS: Drawdown is amount water level is  
lowered below static levelWas a pump test made? Yes ☐ No ☒ If yes, by whom? .....  
Yield: ..... gal./min. with ..... ft. drawdown after ..... hrs.Recovery data (time taken as zero when pump turned off) (water level  
measured from well top to water level)

Time Water Level Time Water Level Time Water Level

Date of test 15 DecBailer test 3.9 gal./min. with 0 ft. drawdown after 0.1 hrs.Artesian flow 13.59% g.p.m. Date .....Temperature of water ..... Was a chemical analysis made? Yes ☒ No ☐(10) WELL LOG: Monitor WellFormation: Describe by color, character, size of material and structure, and  
show thickness of aquifers and the kind and nature of the material in each  
stratum penetrated, with at least one entry for each change of formation.

| MATERIAL                                                                                                                                                                                                   | FROM | TO    |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------|-------|
| SAND: Green-gray, gravelly,<br>slightly silty sand, rounded<br>gravel up to 40mm.                                                                                                                          | 0'   | 6'    |
| GRAVEL: Sandy gravel with<br>wood fragments. Gravel is<br>angular and up to 25mm.<br>Black petroliferous coating<br>on all material.                                                                       | 6'   | 12'   |
| SAND: Gravelly, silty sand<br>with woody fragments.<br>Black, oily material is common.<br>This unit is moist & oily.                                                                                       | 12'  | 14'   |
| GRAVEL & HARDWARE: Sandy<br>gravel with ~3-30mm<br>angular pebbles. Nails, screws,<br>strip metal, wire, etc. are<br>abundant. This unit is<br>slightly oily (brn-gray) and<br>becoming wetter with depth. | 14'  | 19'   |
| SAND: Green-gray, clean sand,<br>with very minor gravel and<br>woody fibers. This unit<br>is saturated.                                                                                                    | 19'  | 25.5' |

## AQUIFERS:

Moist: from 12' to 19'  
Saturated: below 19'

Note: all units are unconsolidated.

Work started 12-12, 19 86 Completed 12-15, 19 86

## WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is  
true to the best of my knowledge and belief.NAME Holt Drilling Co  
(Person, firm, or corporation) (Type or print)Address Puyallup WA[Signed] (Jack)  
(Well Driller)

License No. .... Date ..... 19 .....

**File Original and First Copy with  
Department of Ecology  
Second Copy — Owner's Copy  
Third Copy — Driller's Copy**

# WATER WELL REPORT

Application No.

Permit No.

(1) OWNER: Name City of Seattle, early city Address 1015 3rd Ave, Seattle, WA 98104  
(2) LOCATION OF WELL: County King - NW 1/4 SW 1/4 Sec 17 T. 24 N., R. 45 W.  
Bearing and distance from section or subdivision corner Seattle City Light Pole Yard, northwest corner

(3) **PROPOSED USE:** Domestic ☐ Industrial ☐ Municipal ☐  
Irrigation ☐ Test Well ☒ Other ☐

(4) TYPE OF WORK: Owner's number of well PW-3  
(if more than one).....

|               |                                     |             |                                     |        |                          |
|---------------|-------------------------------------|-------------|-------------------------------------|--------|--------------------------|
| New well      | <input checked="" type="checkbox"/> | Method: Dug | <input type="checkbox"/>            | Bored  | <input type="checkbox"/> |
| Deepened      | <input checked="" type="checkbox"/> | Cable       | <input checked="" type="checkbox"/> | Driven | <input type="checkbox"/> |
| Reconditioned | <input type="checkbox"/>            | Rotary      | <input type="checkbox"/>            | Jetted | <input type="checkbox"/> |

(5) **DIMENSIONS:** Diameter of well ..... 4 ..... inches.  
 Drilled ..... 25 ..... ft. Depth of completed well ..... 20 ..... ft.

(6) CONSTRUCTION DETAILS: *single piece*

Casing installed: *24* " Diam. from *+2.6* ft. to *-2.4* ft.

Threaded ☐ " Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Welded ☐ " Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**Perforations:** Yes ☐ No ☒

Type of perforator used \_\_\_\_\_

SIZE of perforations \_\_\_\_\_ in. by \_\_\_\_\_ in.

perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Screens: Yes ☒ No ☐

Manufacturer's Name \_\_\_\_\_  
Type Slotted stainless Model No. \_\_\_\_\_  
Diam. 4" Slot size 0.1" from 14.5 ft. to 20 ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Gravel packed: Yes ☒ No ☐ Size of gravel: 1/2" to 1/4"  
Gravel placed from 12.5 ft. to 21.5 ft.

Surface seal: Yes ☒ No ☐ To what depth? 2 ft. 12.5 m  
Material used in seal concrete & bentonite  
Did any strata contain unusable water? Yes ☐ No ☐  
N/A Type of water?..... Depth of strata.....  
Method of sealing strata off.....

(7) PUMP: Manufacturer's Name.....  
N/A Type: ..... HP.....

(8) **WATER LEVELS:** Land-surface elevation above mean sea level... 10.5 ft.  
 Static level 12.50 ft. below top of well Date 30 Dec  
 Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_  
 Artesian water is controlled by \_\_\_\_\_ (Cap. valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? Yes ☐ No ☒ If yes, by whom? .....

Yield: gal./min. with ft. drawdown after hrs

|    |    |    |
|----|----|----|
| 13 | 11 | 10 |
| 12 | 9  | 8  |

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

| Time  | Water Level | Time  | Water Level | Time  | Water Level |
|-------|-------------|-------|-------------|-------|-------------|
| ..... | .....       | ..... | .....       | ..... | .....       |
| ..... | .....       | ..... | .....       | ..... | .....       |

Date of test 15 Dec  
 Roller test 3.9 gal/min. with 0 ft. drawdown after 0.1 hrs

Artesian flow.....13.37°C.....g.p.m. Date.....  
Temperature of water..... Was a chemical analysis made? Yes ☒ No ☐

**(10) WELL LOG:**

**Formation:** Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

| MATERIAL | FROM | TO |
|----------|------|----|
| ASPHALT  | 0"   | 3" |

|                                                                                                                                                 |    |     |
|-------------------------------------------------------------------------------------------------------------------------------------------------|----|-----|
| SAND: Fairly clean, slightly<br>silty and gritty, green-gray<br>sand. Grains are multicolored<br>and angular, up to 4mm.<br>Below 10' is moist. | 3" | 13" |
|-------------------------------------------------------------------------------------------------------------------------------------------------|----|-----|

|                                                                                                                            |     |     |
|----------------------------------------------------------------------------------------------------------------------------|-----|-----|
| SILT and SAND: Sandy, clayey silt, with minor concrete fragments; grading down to cleaner, silty sand. This unit is moist. | 13' | 19' |
|----------------------------------------------------------------------------------------------------------------------------|-----|-----|

|                                                                       |     |     |
|-----------------------------------------------------------------------|-----|-----|
| SAND: green-gray, clean, slightly silty sand. This unit is saturated. | 19' | 25' |
|-----------------------------------------------------------------------|-----|-----|

## AQUIFERS:

Moist: From 10' to 19'

Saturated: Below 19'

Note: All units below asphalt are unconsolidated.

RECEIVED

DEPARTMENT OF ECOLOGY  
NORTHWEST REGION

Work started 12-12, 1986 Completed 12-15, 1986

**WELL DRILLER'S STATEMENT:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Holt Drilling Co  
(Person, firm, or corporation) (Type or print)

Address..... Payallup WA

[Signed] (Jack) (Well Driller)

License No. .... Date ....., 19....



File Original and First Copy with  
Department of EcologySecond Copy—Owner's Copy  
Third Copy—Driller's Copy**ENTERED WATER WELL REPORT**  
STATE OF WASHINGTONStart Card No. A 09302

UNIQUE WELL I.D. #

Water Right Permit No. 24/4E/17Q(1) OWNER: Name UPS Address \_\_\_\_\_(2) LOCATION OF WELL: County King(2a) STREET ADDRESS OF WELL (or nearest address) 4455 78th AVE SE Sec 56 T. 24 N. R. 4E W.M.(3) PROPOSED USE: ☐ Domestic ☐ Industrial ☐ Municipal ☐  
☐ Irrigation ☐ Test Well ☐ Other ☐  
☐ DeWater(4) TYPE OF WORK: Owner's number of well  
(If more than one)Abandoned ☒ New well ☐ Method: Dug ☐ Bored ☐  
Deepened ☐ Cable ☐ Driven ☐  
Reconditioned ☐ Rotary ☐ Jetted ☐(5) DIMENSIONS: Diameter of well \_\_\_\_\_ inches.  
Drilled \_\_\_\_\_ feet. Depth of completed well \_\_\_\_\_ ft.

(6) CONSTRUCTION DETAILS:

Casing installed: \_\_\_\_\_' Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Welded ☐ \_\_\_\_\_' Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Liner installed ☐ \_\_\_\_\_' Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Threaded ☐Perforations: Yes ☒ No ☒  
Type of perforator used puller casing  
Size of perforations \_\_\_\_\_ in. by \_\_\_\_\_ in.\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.Screens: Yes ☐ No ☐

Manufacturer's Name \_\_\_\_\_

Type \_\_\_\_\_ Model No. \_\_\_\_\_

Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Gravel packed: Yes ☐ No ☐ Size of gravel \_\_\_\_\_

Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Surface seal: Yes ☐ No ☐ To what depth? \_\_\_\_\_ ft.

Material used in seal \_\_\_\_\_

Did any strata contain unusable water? Yes ☐ No ☐

Type of water? \_\_\_\_\_ Depth of strata \_\_\_\_\_

Method of sealing strata off \_\_\_\_\_

(7) PUMP: Manufacturer's Name \_\_\_\_\_

Type: \_\_\_\_\_ H.P. \_\_\_\_\_

(8) WATER LEVELS: Land-surface elevation \_\_\_\_\_ ft.  
above mean sea level

Static level \_\_\_\_\_ ft. below top of well Date \_\_\_\_\_

Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

Artesian water is controlled by \_\_\_\_\_  
(Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? Yes ☐ No ☐ If yes, by whom? \_\_\_\_\_

Yield: \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.

" " " " " "

" " " " " "

Recovery data (time taken as zero when pump turned off) (water level measured  
from well top to water level)

Time Water Level Time Water Level Time Water Level

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Date of test \_\_\_\_\_

Bailer test \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.

Air test \_\_\_\_\_ gal./min. with stem seal \_\_\_\_\_ ft. for \_\_\_\_\_ hrs.

Artesian flow \_\_\_\_\_ g.p.m. Date \_\_\_\_\_

Temperature of water \_\_\_\_\_ Was a chemical analysis made? Yes ☐ No ☐

(10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTION

Formation: Describe by color, character, size of material and structure, and show  
thickness of aquifers and the kind and nature of the material in each stratum penetrated,  
with at least one entry for each change of information.

MATERIAL FROM TO

RECEIVED

JAN 11 1995

DEPT. OF ECOLOGY

**ENTERED**Work started 12-16 19. Completed 12-16 19 94

## WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well,  
and its compliance with all Washington well construction standards.  
Materials used and the information reported above are true to my best  
knowledge and belief.NAME RJR Drilling  
(PERSON, FIRM, OR CORPORATION) (TYPE OR PRINT)Address P.O. Box 555 Sumner, WA(Signed) Mr. h License No. 1772  
(WELL DRILLER)Contractor's  
Registration  
No. RJRTM8DL Date 12-16 19 94

(USE ADDITIONAL SHEETS IF NECESSARY)





File Original and First Copy with  
Department of EcologySecond Copy—Owner's Copy  
Third Copy—Driller's Copy**ENTERED WATER WELL REPORT**  
STATE OF WASHINGTONStart Card No. 40932Wright Well 10# 4  
24/4E/17Q

Water Right Permit No. \_\_\_\_\_

(1) OWNER: Name UPS Address \_\_\_\_\_(2) LOCATION OF WELL: County King SW 1/4 Sec 17 T 29 N. R 4 E W.M.(2a) STREET ADDRESS OF WELL (or nearest address) 4455 7th Ave SE(3) PROPOSED USE: ☐ Domestic ☐ Industrial ☐ Municipal ☐  
☐ Irrigation ☐ Test Well ☐ Other ☐  
☐ DeWater(4) TYPE OF WORK: Owner's number of well  
(if more than one) \_\_\_\_\_Abandoned ☒ New well ☐ Method: Dug ☐ Bored ☐  
Deepened ☐ Cable ☐ Driven ☐  
Reconditioned ☐ Rotary ☐ Jetted ☐(5) DIMENSIONS: Diameter of well 2 inches.  
Drilled \_\_\_\_\_ feet. Depth of completed well \_\_\_\_\_ ft.

## (6) CONSTRUCTION DETAILS:

Casing installed: \_\_\_\_\_ " Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Welded \_\_\_\_\_ " Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Liner installed ☐ Threaded ☐ \_\_\_\_\_ " Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.Perforations: Yes ☐ No ☒Type of perforator used pulled casing

SIZE of perforations \_\_\_\_\_ in. by \_\_\_\_\_ in.

\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Screens: Yes ☐ No ☐

Manufacturer's Name \_\_\_\_\_

Type \_\_\_\_\_ Model No. \_\_\_\_\_

Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Gravel packed: Yes ☐ No ☐ Size of gravel \_\_\_\_\_

Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Surface seal: Yes ☐ No ☐ To what depth? \_\_\_\_\_ ft.

Material used in seal \_\_\_\_\_

Did any strata contain unusable water? Yes ☐ No ☐

Type of water? \_\_\_\_\_ Depth of strata \_\_\_\_\_

Method of sealing strata off \_\_\_\_\_

(7) PUMP: Manufacturer's Name \_\_\_\_\_

Type: \_\_\_\_\_ H.P. \_\_\_\_\_

(8) WATER LEVELS: Land-surface elevation \_\_\_\_\_ ft.

Static level \_\_\_\_\_ ft. below top of well Date \_\_\_\_\_

Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

Artesian water is controlled by \_\_\_\_\_ (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? Yes ☐ No ☐ If yes, by whom? \_\_\_\_\_

Yield: \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.

" " " " " "

" " " " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time Water Level Time Water Level Time Water Level

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Date of test \_\_\_\_\_

Bailer test \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.

Airtest \_\_\_\_\_ gal./min. with stem set at \_\_\_\_\_ ft. for \_\_\_\_\_ hrs.

Artesian flow \_\_\_\_\_ g.p.m. Date \_\_\_\_\_

Temperature of water \_\_\_\_\_ Was a chemical analysis made? Yes ☐ No ☐

## (10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTION

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information.

MATERIAL FROM TO

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

RECEIVED

JAN 11 1995

DEPT. OF ECOLOGY

Work started 12-18 19. Completed 12-18 199

## WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME \_\_\_\_\_ (PERSON, FIRM, OR CORPORATION) (TYPE OR PRINT)

Address \_\_\_\_\_

(Signed) C. A. W. N. License No. 1772

(WELL DRILLER)

Contractor's Registration No. \_\_\_\_\_ Date \_\_\_\_\_ 19\_\_\_\_

(USE ADDITIONAL SHEETS IF NECESSARY)



24/04/17M

File Original and First Copy with  
Department of Ecology  
Second Copy - Owner's Copy  
Third Copy - Driller's Copy

# WATER WELL REPORT

## STATE OF WASHINGTON

Application No. ....

Permit No. ....

(1) OWNER: Name City of Seattle, Seattle City Light Address 1015 3rd Ave, Seattle, WA 98104  
(2) LOCATION OF WELL: County King NW 1/4 SW 1/4 Sec 17 T 24 N. R 4E W.M.  
Bearing and distance from section or subdivision corner Seattle City Light Pole Yard, northeast corner

(3) PROPOSED USE: Domestic ☐ Industrial ☐ Municipal ☐  
Irrigation ☐ Test Well ☒ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) ....  
New well ☒ Method: Dug ☐ Bored ☐  
Deepened ☐ Cable ☒ Driven ☐  
Reconditioned ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 8 1/4 inches.  
Drilled 24.5 ft. Depth of completed well 14 ft.

(6) CONSTRUCTION DETAILS: Single piece  
Casing installed: 8 1/4" Diam. from +2 ft. to -3 ft.  
Threaded ☐ " Diam. from ft. to ft.  
Welded ☐ " Diam. from ft. to ft.

Perforations: Yes ☐ No ☒

Type of perforator used .....  
SIZE of perforations in. by in.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

Screens: Yes ☒ No ☐

Manufacturer's Name .....  
Type Slotted stainless Model No. ....  
Diam. 4" Slot size .01" from 8.5 ft. to 14 ft.  
Diam. Slot size from ft. to ft.

Gravel packed: Yes ☒ No ☐ Size of gravel: .....  
Gravel placed from 16 ft. to 7 ft.

Surface seal: Yes ☒ No ☐ To what depth? 3 ft  
Material used in seal concrete & bentonite  
Did any strata contain unusable water? Yes ☐ No ☐  
Type of water? ..... Depth of strata .....  
Method of sealing strata off .....

(7) PUMP: Manufacturer's Name .....  
N/A Type: ..... HP

(8) WATER LEVELS: Land-surface elevation ~11.0 ft.  
above mean sea level .....  
Static level 11.42 ft. below top of well Date 30 Dec  
Artesian pressure lbs. per square inch Date .....  
Artesian water is controlled by ..... (Cap. valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level  
Was a pump test made? Yes ☐ No ☒ If yes, by whom? .....  
Yield: gal./min. with ft. drawdown after hrs.  
" " " " " "

Recovery data (Time taken as zero when pump turned off) (water level measured from well top to water level)

| Time | Water Level | Time | Water Level | Time | Water Level |
|------|-------------|------|-------------|------|-------------|
|      |             |      |             |      |             |

Date of test 15 Dec  
Bailer test 3.9 gal./min. with 0 ft. drawdown after 0.1 hrs.  
Artesian flow ..... g.p.m. Date .....  
Temperature of water 44.40°C Was a chemical analysis made? Yes ☒ No ☐

### (10) WELL LOG: Monitor Well

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

| MATERIAL                                                                       | FROM | TO  |
|--------------------------------------------------------------------------------|------|-----|
| ASPHALT                                                                        | 0"   | 3"  |
| SAND: green-gray, clean, slightly silty sand. This unit is saturated below 10" | 3"   | 14' |

|                                                                                                                            |     |     |
|----------------------------------------------------------------------------------------------------------------------------|-----|-----|
| SILT: Gray, sandy, clayey silt with woody fibers. Some organic-rich, gray to black horizons. This unit is generally moist. | 14' | 18' |
|----------------------------------------------------------------------------------------------------------------------------|-----|-----|

|                                                                   |     |       |
|-------------------------------------------------------------------|-----|-------|
| SAND: Green-gray, clean, somewhat silty sand. This unit is moist. | 18' | 24.5' |
|-------------------------------------------------------------------|-----|-------|

### AQUIFERS:

Saturated: 10' to 14'  
Moist: below 14'

Note: All units below asphalt are unconsolidated.

RECEIVED

DEPT. OF ECOLOGY  
NORTHWEST REGION

Work started 12-13 19 86 Completed 12-15 19 86

### WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Holt Drilling Co  
(Person, firm, or corporation) (Type or print)

Address Puyallup WA

[Signed] (Jack)  
(Well Driller)

License No. .... Date ..... 19 .....

File Original and First Copy with  
Department of Ecology

Second Copy—Owner's Copy

Third Copy—Driller's Copy

**WATER WELL REPORT**

STATE OF WASHINGTON

Water Right Permit No. \_\_\_\_\_

Start Card No. 076135

(1) OWNER: Name SCOTT'S GENERAL CONST Address 70405 SE 344th AUBURN(2) LOCATION OF WELL: County KING NW & SW & Sec 17 T. 24 N. R. 4 E. W. 4(2a) STREET ADDRESS OF WELL (or nearest address) 4501 6th AVE S SEATTLE WA(3) PROPOSED USE: ☐ Domestic ☐ Industrial ☐ Municipal ☐  
☐ Irrigation ☐ Test Well ☐ Other ☐  
☒ DeWater(4) TYPE OF WORK: Owner's number of well (if more than one) 2Abandoned ☐ New well ☒ Method: Dug ☐ Bored ☒  
Deepened ☐ Cable ☐ Driven ☐  
Reconditioned ☐ Rotary ☐ Jetted ☐(5) DIMENSIONS: Diameter of well 36 inches.  
Drilled 30 feet. Depth of completed well 30 ft.

## (6) CONSTRUCTION DETAILS:

Casing installed: 12 Diam. from 6 ft. to 10 ft.  
Welded ☐ Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Liner installed ☐ Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Threaded ☐ Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.Perforations: Yes ☐ No ☐

Type of perforator used \_\_\_\_\_

SIZE of perforations \_\_\_\_\_ in. by \_\_\_\_\_ in.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.Screens: Yes ☒ No ☐Manufacturer's Name WESTERN WELLSCREENType PVC

Model No. \_\_\_\_\_

Diam. 12" Slot size 0.5" from 10 ft. to 30 ft.

Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Gravel packed: Yes ☒ No ☐ Size of gravel "4X8" PEAGravel placed from 30 ft. to 3 ft.Surface seal: Yes ☒ No ☐ To what depth? 3 ft.Material used in seal ENVIROPLUG #8Did any strata contain unusable water? Yes ☐ No ☐

Type of water? \_\_\_\_\_ Depth of strata \_\_\_\_\_

Method of sealing strata off \_\_\_\_\_

(7) PUMP: Manufacturer's Name PRASSER/ENBO  
Type: SUBMERSIBLE DEWATERING H.P. 5(8) WATER LEVELS: Land-surface elevation above mean sea level \_\_\_\_\_ ft.  
Static level 8 ft. below top of well Date SEPT 9, 91

Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

Artesian water is controlled by \_\_\_\_\_ (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? Yes ☐ No ☒ If yes, by whom? \_\_\_\_\_Yield: 350 gal./min. with 20 ft. drawdown after 1 hrs." 350 " 27 " 48 "

" " " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time Water Level Time Water Level Time Water Level

Date of test \_\_\_\_\_

Galler test \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.

Artesian \_\_\_\_\_ gal./min. with stem set at \_\_\_\_\_ ft. for \_\_\_\_\_ hrs.

Artesian flow \_\_\_\_\_ g.p.m. Date \_\_\_\_\_

Temperature of water \_\_\_\_\_ Was a chemical analysis made? Yes ☐ No ☐

## (10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTION

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information.

| MATERIAL                                                | FROM | TO |
|---------------------------------------------------------|------|----|
| BROWN SANDY FILL WITH LARGE CHUNKS OF CONCRETE & GRAVEL | 0    | 6  |

|                                         |   |    |
|-----------------------------------------|---|----|
| GRAY BLACK SAND, SILTY SAND FINE TO MED | 6 | 30 |
|-----------------------------------------|---|----|

RECEIVED  
SEP 16 1991  
DEPT. OF ECOLOGY

Work started SEPT 6, 19. Completed SEPT 6, 1991

## WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME ANDERSON DEWATERING  
(PERSON, FIRM, OR CORPORATION) (TYPE OR PRINT)Address PO BOX 3093 FEDERAL WAY(Signed) William Anderson License No. 1522  
(WELL DRILLER)Contractor's Registration No. ANDERD\*110PP Date SEPT 10, 1991

(USE ADDITIONAL SHEETS IF NECESSARY)

File Original and First Copy with  
Department of Ecology  
Second Copy — Owner  
Third Copy — Driller's Copy

**ENTERED****WATER WELL REPORT**

STATE OF WASHINGTON

Water Right Permit No.

Start Card No.

21168

UNIQUE WELL I.D. #

(1) OWNER: Name UNKNOWN

Address

24-4E-18M(2) LOCATION OF WELL: County KINGNW 1/4 SW 1/4 Sec 18 T. 24 N. R. 4 E W.M.(2a) STREET ADDRESS OF WELL (or nearest address) 4500 W. MARGINAL WAY SW

(3) PROPOSED USE: ☐ Domestic ☐ Industrial ☐ Municipal ☐  
☐ Irrigation ☐ Test Well ☐ Other ☐  
☒ DeWater

(4) TYPE OF WORK: Owner's number of well (if more than one) 1-2

Abandoned ☐ New well ☒ Method: Dug ☐ Bored ☐  
 Deepened ☐ Cable ☐ Driven ☐  
 Reconditioned ☐ Rotary ☒ Jetted ☐

(5) DIMENSIONS: Diameter of well 10" inches.  
 Drilled 30 feet. Depth of completed well 30 ft.

## (6) CONSTRUCTION DETAILS:

Casing installed: 10" Diam. from 0 ft. to 30 ft.  
 Welded ☐ Diam. from     ft. to     ft.  
 Liner installed ☐ Diam. from     ft. to     ft.  
 Threaded ☐

Perforations: Yes ☒ No ☐Type of perforator used MACHINERSIZE of perforations .030 in. by 2 in..030 perforations from 10" ft. to 30 ft.perforations from     ft. to     ft.perforations from     ft. to     ft.Screens: Yes ☐ No ☐Manufacturer's Name    Type     Model No.    Diam.     Slot size     from     ft. to     ft.Diam.     Slot size     from     ft. to     ft.Gravel packed: Yes ☒ No ☐ Size of gravel 3/8"Gravel placed from 30 ft. to 0 ft.Surface seal: Yes ☒ No ☐ To what depth? 5 ft.Material used in seal NATIVE CLAYDid any strata contain unusable water? Yes ☐ No ☒Type of water?     Depth of strata    Method of sealing strata off    

(7) PUMP: Manufacturer's Name      
 Type:     H.P.    

(8) WATER LEVELS: Land-surface elevation above mean sea level     ft.Static level 4' ft. below top of well Date 10-24-96Artesian pressure     lbs. per square inch Date    Artesian water is controlled by     (Cap. valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? Yes ☐ No ☒ If yes, by whom?    Yield:     gal./min. with     ft. drawdown after     hrs.

" " " "

" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time Water Level Time Water Level Time Water Level

Time Water Level Time Water Level Time Water Level

Time Water Level Time Water Level Time Water Level

Date of test    Ballor test     gal./min. with     ft. drawdown after     hrs.Airtest     gal./min. with stem set at     ft. for     hrs.Artesian flow     g.p.m. Date    Temperature of water     Was a chemical analysis made? Yes ☐ No ☐

## (10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTION

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information.

| MATERIAL      | FROM | TO |
|---------------|------|----|
| PIT RUN       | 0    | 4  |
| SAND & GRAVEL | 4    | 8  |
| CLAY          | 8    | 11 |
| BLACK SAND    | 11   | 30 |

WELLS ARE  
INSIDE EXCAVATION

RECEIVED

NOV 12 1996

DEPARTMENT OF ECOLOGY  
SHORELANDS AND  
WATER RESOURCES PROGRAM

Work Started 10-24-96 19. Completed 10-24-96 19

## WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME SLEAD'S CONSTRUCTION INC.

(PERSON, FIRM OR CORPORATION) (TYPE OR PRINT)

Address 2703 96TH ST NW TAC, WA(Signed) [Signature] License No. 1761Contractor's Registration No. SLEADCB25KO Date 10/30 19 96

(USE ADDITIONAL SHEETS IF NECESSARY)

Ecology is an Equal Opportunity and Affirmative Action employer. For special accommodation needs, contact the Water Resources Program at (206) 407-6600. The TDD number is (206) 407-6008.