



11000 N. MoPac Expressway, Suite 500  
Austin, Texas 78759  
Phone: (512) 451-6334  
Fax: (512) 459-1459

SWRB  
Pierce

Date Printed and Mailed: 10/20/2023

RECEIVED  
Date

OCT 31 2023

Washington State Department of Ecology  
Toxics Cleanup Program

UNDERGROUND STORAGE TANK SECTION  
WASHINGTON DEPT. OF ECOLOGY  
P.O. BOX 47655  
OLYMPIA, WA 98504

Test Date: 10/19/2023  
Order Number: 2362766

Dear Regulator,

Enclosed are the results of recent testing performed at the following facility:

7-Eleven 38699  
2631 S 38th St  
Tacoma, WA 98409

Testing performed:  
IMPACT VALVE  
LEAK DETECTOR  
MONITOR CERTIFICATION  
OVERFILL OPERABILITY  
SPILL BUCKET TEST

Sincerely,

A handwritten signature in cursive script that reads 'Dawn Kohlmeier'.

Dawn Kohlmeier  
Manager, Field Reporting



DEPARTMENT OF  
**ECOLOGY**  
State of Washington

# LEAK TESTING CHECKLIST FOR UNDERGROUND STORAGE TANKS (USTs)

RECEIVED  
Date

UST ID #: A5871

OCT 31 2023

County: PIERCE

This checklist certifies testing activities conducted in accordance with Washington State Department of Ecology  
Chapter 173-360A WAC. Read instructions on pages 4-7.


<input type="checkbox"/> <b>PASS</b> – All Section VI services performed have passing results. <input checked="" type="checkbox"/> <b>FAIL</b> – One or more components tested in Section VI require repair and re-testing.		<b>DATE TESTS CONDUCTED:</b> 10/19/2023	
<b>I. UST FACILITY</b>		<b>II. CERTIFIED SERVICE PROVIDER</b>	
Facility Compliance Tag #: A _____		Service Provider Name: David Chambers	
UST ID #: A5871		Company Name: TANKNOLOGY, INC.	
Site Name: 7-Eleven 38699		Address: 11000 N. MOPAC EXPRESSWAY #500	
Site Address: 2631 S 38th St		City: AUSTIN	State: TX Zip: 78759
City: Tacoma		Phone: (800)800-4688 Email: info@tanknology.com	
County: PIERCE		ICC Certification Type: ICC UST Tank Tightness Testing	
Site Phone: 253-310-5783		ICC Cert. #: 10225709	Exp. Date: 08/15/2024
<b>III. UST OWNER/OPERATOR</b>			
Name: Marc Westfall Phone: 214-415-0146 Email: marc.westfall@7-11.com			
<b>IV. UST SYSTEM INFORMATION</b>			
<b>Observations on test day.</b>			
1. Tank ID #, as registered with Ecology or identified on ATG	T1 RUL	T2 PUL	T3 DSL
2. Tank Status. OP (Operational); TC (Temporary Closure)	OP	OP	OP
3. Product stored, including % of alternative fuels	REG-87	PREM-92	DSL-40
4. Tank or compartment capacity (gallons)	19930	8039	11897
5. Product pumping/flow method. Note as: P (Pressurized); NS (Non-safe Suction); SS (Safe Suction); Si (Siphon); GR (Gravity Fed)	P	P	P
Abbreviations for lines 5 and 6 below: Steel (ST); Fiberglass (FRP); Clad Steel (CLAD); Flexible (FLEX); Double Wall (DW); Single Wall (SW); Not Visible (NV)			
6. Tank material and construction observed	FRP DW	FRP DW	FRP DW
7. Pipe material and construction observed	FLEX DW	FLEX DW	FLEX DW
<b>V. REASON FOR SERVICES PERFORMED</b> (Check all that apply)			
<input checked="" type="checkbox"/> Annual testing <input checked="" type="checkbox"/> 3-year testing	<input type="checkbox"/> Test after install/repair <input type="checkbox"/> Return UST system to operation	<input type="checkbox"/> Other (explain):	

VI. SERVICES PERFORMED				
Required: Include verification for each test performed.				
		# PASS	# FAIL	# REPAIRED & PASSING
SERVICES:		DESCRIPTIONS REQUIRED: (SEE INSTRUCTIONS P. 4-7)		
<b>ALLD Test (attach data)</b> Test method used: LDT-5000 Test method cert. exp. date:		3	—	—
<b>Line Tightness Test (attach data)</b> Test method used: TLD-1 Test method cert. exp. date: 09/07/2026		—	—	—
<b>Electronic Monitoring System Tests</b> Controller manufacturer/model: Veeder-Root TLS-350R Controller cert. exp. date: 08/2024		1	—	—
Monitor/controller Probe Sump Sensor Functionality Tank Annular Sensor Functionality		3 12 1	— — 1	— — —
<b>Overfill Equipment Test</b> <input checked="" type="checkbox"/> Auto shutoff <input type="checkbox"/> Ball float valve <input type="checkbox"/> Overfill alarm		3	—	—
<b>Fill/Spill Bucket Test (attach data)</b>		3	—	—
<b>Tank-Top or Transition Sump Test (attach data)</b>		—	—	—
<b>UDC Sump Test (attach data)</b>		—	—	—
<b>Tank Tightness Test (attach data)</b> 3 <sup>rd</sup> -party certified test: Test method used: VacuTest Test method cert. exp. date:		—	—	—
<b>Other</b>		—	—	—
<b>3x Vaporless LD-2000 MLLD's passed 3 gph leak testing.</b>  <b>NOT SCHEDULED FOR TESTING.</b>  <b>3X Probe's 90-110 (mag) passed.</b> <b>3x Electronic double wall spill bucket sensors- OPW single float-passed.</b> <b>3x STP sump sensors- 208's- passed.</b> <b>6x UDC sensors- 208's passed.</b> <b>1x regular annular sensor- 409 passed.</b> <b>1x T2 and T3 Combo annular sensor- not tested due to cover lid bolts rounded off and cant get access to sensor for testing.</b>  <b>3x OPW 71SO-410C flapper drop tubes passed Overfill survey and meet 95% or better requirements.</b>  <b>3x double wall spill buckets passed testing. method used RP-1200, Vacuum on interstice, 30inh20 for 1 mins.</b>  <b>NOT SCHEDULED FOR TESTING.</b>  <b>NOT SCHEDULED FOR TESTING.</b>  <b>NOT SCHEDULED FOR TESTING.</b>  <b>NA</b>				

VII. EXPLANATIONS/PROBLEMS ENCOUNTERED:	
Provide additional test information. Explain irregularities. Describe problems encountered and how addressed.	

# VIII. UST SITE AND SYSTEM DIAGRAM

Diagram required. Include North arrow.



PERSONS SUBMITTING FALSE INFORMATION ARE SUBJECT TO FORMAL ENFORCEMENT AND/OR PENALTIES UNDER CHAPTER 173-360A WAC.

## IX. FINAL CHECK

Mark the following:

1. All checked services tested per recommended practices, code and/or manufacturer's requirements, and in accordance with state regulations.
2. Owner/operator provided with copy of the checklist and testing results.
3. Any faulty equipment or necessary repairs explained to owner/operator or site contact.

YES NO N/A

<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

## X. REQUIRED SIGNATURES

10/19/2023

Date

Signature of Certified Service Provider

David Chambers

Print or Type Name

10/19/2023

Date

Signature of Tank Owner or Authorized Representative

Jerry Belloli

Print or Type Name




**LDT 5000 Field Test Apparatus**  
Line Leak Detector Test

Page 1 of 1

Work Order: 2362766 Date: 10/19/2023  
Site Name / ID: 7-Eleven 38699 / 38699  
Address: 2631 S 38th St  
City: Tacoma State: WA Zip: 98409

Tank ID	T1: Regular	T2: Premium	T3: Diesel			
Product	REGULAR	PUL	Diesel			
Product Line	1	1	1			
Tested From	3	3	3			
Existing/New	Existing	Existing	Existing			
Mechanical/Electronic	Mechanical	Mechanical	Mechanical			
Manufacturer/Model	Vaporless LD-2000	Vaporless LD-2000	Vaporless LD-2000			
Serial No.	20081155	20081153	20081154			
Pump Operating Pressure (psi)	27.00	25.00	32.00			
Calibrated Leak (ml/min)	189.0	189.0	189.0			
Calibrated Leak (gph)	3.00	3.00	3.00			
Holding PSI *N/A for Electronic LD's	27.00	25.00	30.00			
Resiliency (ml) *N/A for Electronic LD's	150.00	160.00	100.00			
Metering PSI *N/A for Electronic LD's	20	20	21			
Opening Time (sec) *N/A for Electronic LD's	9	6	4			
Test Results	Pass	Pass	Pass			

Technician Comments:

Technician Name: David Chambers Certification #: 135637  
Technician Signature:  Expire Date: 9/7/2026



## Impact Valve Inspection

### Impact Valve Operational Inspection

Work Order: 2362766  
Site Name/ID: 7-Eleven 38699  
Address: 2631 S 38th St  
City: Tacoma

Date: 10/19/2023

State: WA

Zip: 98409

How Inspected:

Line Test ☐

NFPA 30A ☐

PEI RP1200 ☒

Other ☐

Dispenser Number	Grade	Secure Mount?	Valve Lock?	Pass/ Fail	Comments
1/2	87	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/> Not Tested	
1/2	92	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/> Not Tested	
3/4	40	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/> Not Tested	
3/4	87	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/> Not Tested	
3/4	92	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/> Not Tested	
5/6	87	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/> Not Tested	
5/6	92	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/> Not Tested	
7/8	87	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/> Not Tested	
7/8	92	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/> Not Tested	
9/10	87	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/> Not Tested	
9/10	92	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/> Not Tested	
11/12	40	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/> Not Tested	
11/12	87	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/> Not Tested	
11/12	92	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/> Not Tested	

Technician Comments:

Technician Name:

David Chambers

Signature:

# MONITORING SYSTEM CERTIFICATION

This form is used to document testing and servicing of tank and piping leak monitoring equipment. If required by applicable law, a copy of the completed form must be provided by the Testing Contractor or owner to the governing UST agency as required by regulation.

## A. General Information

Facility Name: 7-Eleven 38699 Bldg. No.: \_\_\_\_\_  
 Site Address: 2631 S 38th St City: Tacoma State: WA Zip: 98409  
 Facility Contact Person: \_\_\_\_\_ Contact Phone No.: 253-310-5783  
 Make/Model of Monitoring System: Veeder Root TLS-350R Date of Testing/Servicing: 10/19/2023


## B. Inventory of Equipment Tested/Certified

Check the appropriate boxes to indicate specific equipment inspected/serviced:

<b>Tank ID: T1: Regular - REGULAR</b> <input checked="" type="checkbox"/> In-Tank Gauging Probe. Model: <u>846390-110</u> <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>794390-409</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>794380-208</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: <u>Vaporless LD-2000</u> <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input checked="" type="checkbox"/> Tank Overfill / High-Level Sensor. Model: <u>OPW -flapper</u> <input checked="" type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).	<b>Tank ID: T2: Premium - PUL</b> <input checked="" type="checkbox"/> In-Tank Gauging Probe. Model: <u>846390-110</u> <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>Shared W/T3</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>794380-208</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: <u>Vaporless LD-2000</u> <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input checked="" type="checkbox"/> Tank Overfill / High-Level Sensor. Model: <u>OPW -flapper</u> <input checked="" type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).
<b>Tank ID: T3: Diesel - Diesel</b> <input checked="" type="checkbox"/> In-Tank Gauging Probe. Model: <u>846390-110</u> <input checked="" type="checkbox"/> Annular Space or Vault Sensor. Model: <u>Not Tested.</u> <input checked="" type="checkbox"/> Piping Sump / Trench Sensor(s). Model: <u>794380-208</u> <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input checked="" type="checkbox"/> Mechanical Line Leak Detector. Model: <u>Vaporless LD-2000</u> <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input checked="" type="checkbox"/> Tank Overfill / High-Level Sensor. Model: <u>OPW -flapper</u> <input checked="" type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).	<b>Tank ID:</b> <input type="checkbox"/> In-Tank Gauging Probe. Model: _____ <input type="checkbox"/> Annular Space or Vault Sensor. Model: _____ <input type="checkbox"/> Piping Sump / Trench Sensor(s). Model: _____ <input type="checkbox"/> Fill Sump Sensor(s). Model: _____ <input type="checkbox"/> Mechanical Line Leak Detector. Model: _____ <input type="checkbox"/> Electronic Line Leak Detector. Model: _____ <input type="checkbox"/> Tank Overfill / High-Level Sensor. Model: _____ <input type="checkbox"/> Other (specify equipment type and model in Section E on Page 2).
<b>Dispenser ID: 1/2</b> <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>794380-208</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).	<b>Dispenser ID: 7/8</b> <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>794380-208</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).
<b>Dispenser ID: 3/4</b> <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>794380-208</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).	<b>Dispenser ID: 9/10</b> <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>794380-208</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).
<b>Dispenser ID: 5/6</b> <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>794380-208</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).	<b>Dispenser ID: 11/12</b> <input checked="" type="checkbox"/> Dispenser Containment Sensor(s). Model: <u>794380-208</u> <input checked="" type="checkbox"/> Shear Valve(s). <input type="checkbox"/> Dispenser Containment Float(s) and Chain(s).

\*If the facility contains more tanks or dispensers, copy this form. Include information for every tank and dispenser at the facility.

**C. Certification - I certify that the equipment identified in this document was inspected/serviced in accordance with the manufacturers' guidelines. Attached to this Certification is a Plot Plan showing the layout of monitoring equipment. For any equipment capable of generating such reports, I have also attached a copy of the report; (check all that apply):** ☐ System set-up ☒ Alarm history report

Technician Name (print): David Chambers Signature:   
 Certification No.: C23292 License. No.: \_\_\_\_\_  
 Testing Company Name: Tanknology Phone No.: (800) 800-4633  
 Testing Company Address: 11000 N. MoPac Expressway Suite 500 Date of Testing/Servicing: 10/19/2023

**D. Results of Testing/Servicing**

Software Version Installed: 335.00

Complete the following checklist:

<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No* <input type="checkbox"/> N/A	Is the <b>visual</b> alarm on the console operational?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No* <input type="checkbox"/> N/A	Is the <b>audible</b> alarm on the console operational?
<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	Is the external <b>visual</b> overfill alarm (light unit) present?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	Is the external <b>visual</b> overfill alarm operating properly?
<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	Is the external <b>audible</b> overfill alarm present?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	Is the external <b>audible</b> overfill alarm operating properly?
%	<input checked="" type="checkbox"/> N/A	At what percent of tank(s) capacity is the external alarm programmed to trigger? <i>If different % between tanks, clarify in section E.</i>
<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No* <input type="checkbox"/> N/A	Were all sensors visually inspected, functionally tested, and confirmed operational?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No* <input type="checkbox"/> N/A	Were all sensors installed at lowest point of secondary containment and positioned so that other equipment will not interfere with their proper operation?
<input type="checkbox"/> Yes	<input type="checkbox"/> No* <input checked="" type="checkbox"/> N/A	For pressurized piping systems, does the turbine automatically shut down if the piping secondary containment monitoring system detects a leak, fails to operate, or is electrically disconnected? If yes: which sensors initiate positive shut-down? <i>(Check all that apply)</i> <input type="checkbox"/> Sump/Trench Sensors; <input type="checkbox"/> Dispenser Containment Sensors. Did you confirm positive shut-down due to leaks <u>and</u> sensor failure/disconnection? <input type="checkbox"/> Yes; <input type="checkbox"/> No
<input type="checkbox"/> Yes*	<input checked="" type="checkbox"/> No	Was any monitoring equipment replaced? If yes, identify specific sensors, probes, or other equipment replaced and list the manufacturer name and model for all replacement parts in Section E, below.
<input type="checkbox"/> Yes*	<input checked="" type="checkbox"/> No	Was liquid found inside any secondary containment systems designed as dry systems? <i>(Check all that apply)</i> <input type="checkbox"/> Product; <input type="checkbox"/> Water. If yes, describe causes in Section E, below.
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Was monitoring system set-up reviewed to ensure proper settings? Attach set up reports, if applicable
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Is all monitoring equipment operational per manufacturer's specifications?

\* In Section E below, describe how and when these deficiencies were or will be corrected.

**E. Comments:**

Backup Battery reading, if applicable (Required for VR TLS 300/350): Backup Battery Reading @ \*3.68. Vdc.

- Were all sensors visually inspected, functionally tested, and confirmed operational? NO, Tank 2 & Tank 3 Combo Annular sensor not tested due to cover lid bolt rounded off and can't get cover off to access sensor.

- Other (specify equipment type and model in Section E on Page 2). ALL Tanks have electronic sensors inside double wall spill buckets and monitored by Veeder-Root. make of sensors are OPW single float. passed testing.



#### **F. In-Tank Gauging / SIR Equipment:**

☐ Check this box if tank gauging is used only for inventory control.

☐ Check this box if no tank gauging or SIR equipment is installed.

This section must be completed if in-tank gauging equipment is used to perform leak detection monitoring.

**Complete the following checklist:**

<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all tank gauging probes visually inspected for damage and residue buildup?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Was accuracy of system product level readings tested?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Was accuracy of system water level readings tested?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all probes reinstalled properly?
<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	Were all items on the equipment manufacturer's maintenance checklist completed?

\* In the Section G, below, describe how and when these deficiencies were or will be corrected.

**G. Comments:**

--


DID OVERALL MONITOR SYSTEM TESTING PASS (Check One)? YES ☐ NO ☐  
INCONCLUSIVE ☒

Customer Name: 7-Eleven 38699 Location #: 38699 City: Tacoma State: WA Zip: 98409

### SPILL/OVERFILL CONTAINMENT BOXES

Facility is Not Equipped With Fill Riser Containment Sumps <input checked="" type="checkbox"/>			Test Date: 10/19/2023
Fill Riser Containment Sumps are Present, but were Not Tested <input type="checkbox"/>			
	Spill Box # Tank T1: RUL REGULAR - Fill 1 - Direct	Spill Box # Tank T2: PUL PUL - Fill 1 - Direct	Spill Box # Tank T3: DSL Diesel - Fill 1 - Direct
Double Wall:	Y	Y	Y
Bucket Diameter (in inches):	16.00	16.00	16.00
Bucket Depth (in inches):	12.50	12.25	12.00
Test Method Developed By:	Industry Standard-PEI RP 1200	Industry Standard-PEI RP 1200	Industry Standard-PEI RP 1200
Test Method Used By:	Vacuum on interstice	Vacuum on interstice	Vacuum on interstice
Test Equipment Used:	VACUUM TEST	VACUUM TEST	VACUUM TEST
Equipment Resolution:	0.1 gph	0.1 gph	0.1 gph
Wait time between applying pressure/vacuum/water and starting test	1 min	1 min	1 min
Test Start Time:	09:31:00	08:47:00	08:44:00
Initial Reading ( $R_I$ ):	30.00 in. H2O	30.00 in. H2O	30.00 in. H2O
Test End Time:	09:32:00	08:48:00	08:45:00
Final Reading ( $R_F$ ):	30.00 in. H2O	30.00 in. H2O	30.00 in. H2O
Test Duration:	1 min	1 min	1 min
Change in Reading ( $R_F - R_I$ ):	0.00 in. H2O	0.00 in. H2O	0.00 in. H2O
Pass/Fail Threshold or Criteria:	+/- -4.00	+/- -4.00	+/- -4.00
<b>Test Result:</b>	<b>Pass</b>	<b>Pass</b>	<b>Pass</b>

**Comments** — (include information on repairs made prior to testing, and recommended follow-up for failed tests)

Technician Name:	<u>David Chambers</u>	Test Date:	<u>10/19/2023</u>
Technician Signature:		Certification #:	<u>135640</u>

## Appendix B

### 7150 Overfill Valve In Tank Shut off Level Worksheet

**Important:** This is meant to be supplemental worksheet and not a substitute to following the installation manual instructions. All length measurements are in inches. Please contact the Authority Having Jurisdiction (AHJ) and review local, state, and national codes to determine the regulatory requirements governing shut-off capacity in your region, as well as take into account other considerations such as extreme tank tilt.

Tank ID: T1: Regular(REGULAR)

Take the following measurements with the valve installed in the tank:

Distance from the 7150 inlet tube flange to the cast lug in the 7150 body (see figures), upper tube length.

Note: the Upper Tube Length must be at least 16" to include the protective bend in the tube.

(D) = 64.25

Distance from the 7150 inlet tube flange to the top and bottom of lower tube, valve length.

(W) = 163.125

(U) = 160.375

Distance from the 7150 inlet tube flange to the bottom of the tank. Note: If a tank bottom protector is present it may be necessary to add this thickness to dimension (OPW 6111 & 61TP models add 0.6")

(B) = 165.50

From the tank calibration chart provided by tank manufacturer find the dipstick number (Y) which corresponds to the 100% volume.

(Y) = 119.375

#### 1. To determine shut-off percentage:

Subtract upper tube length (D) from distance to tank bottom (B)


(X) = (B) - (D) - 2" = 99.25

Using the tank calibration chart provided by the tank manufacturer determine the tank capacity at the calculated (X) dimension and the 100% volume (Y) tank capacity.

(X) tank capacity in gallons = 17780

(Y) tank capacity in gallons = 19930

50% = (X) capacity / (Y) capacity x 100 = 89.21



Note: The overfill valve must be installed per AHJ requirements and all applicable local, state, and national codes. If the overfill valve is set above the allowable shut-off percentage the overfill valve must be removed and replaced. For reference 40 CFR part 280 Subpart B Section 280.20 overfill valves should be set to a maximum of 95%.

## Appendix B

### 7150 Overfill Valve In Tank Shut off Level Worksheet

**Important:** This is meant to be supplemental worksheet and not a substitute to following the installation manual instructions. All length measurements are in inches. Please contact the Authority Having Jurisdiction (AHJ) and review local, state, and national codes to determine the regulatory requirements governing shut-off capacity in your region, as well as take into account other considerations such as extreme tank tilt.

Tank ID: T2: Premium(PUL)

Take the following measurements with the valve installed in the tank:

Distance from the 7150 inlet tube flange to the cast lug in the 7150 body (see figures), upper tube length.

Note: the Upper Tube Length must be at least 16" to include the protective bend in the tube.

(D) = 65.875

Distance from the 7150 inlet tube flange to the top and bottom of lower tube, valve length.

(W) = 165.125

(U) = 162.50

Distance from the 7150 inlet tube flange to the bottom of the tank. Note: If a tank bottom protector is present it may be necessary to add this thickness to dimension (OPW 6111 & 61TP models add 0.6")

(B) = 168.25

From the tank calibration chart provided by tank manufacturer find the dipstick number (Y) which corresponds to the 100% volume.

(Y) = 119.375

#### 1. To determine shut-off percentage:

Subtract upper tube length (D) from distance to tank bottom (B)


(X) = (B) - (D) - 2" = 100.375

Using the tank calibration chart provided by the tank manufacturer determine the tank capacity at the calculated (X) dimension and the 100% volume (Y) tank capacity.

(X) tank capacity in gallons = 7216

(Y) tank capacity in gallons = 8039

SO% = (X) capacity / (Y) capacity x 100 = 89.76



**Note:** The overfill valve must be installed per AHJ requirements and all applicable local, state, and national codes. If the overfill valve is set above the allowable shut-off percentage the overfill valve must be removed and replaced. For reference 40 CFR part 280 Subpart B Section 280.20 overfill valves should be set to a maximum of 95%.

## Appendix B

### 7150 Overfill Valve In Tank Shut off Level Worksheet

**Important:** This is meant to be supplemental worksheet and not a substitute to following the installation manual instructions. All length measurements are in inches. Please contact the Authority Having Jurisdiction (AHJ) and review local, state, and national codes to determine the regulatory requirements governing shut-off capacity in your region, as well as take into account other considerations such as extreme tank tilt.

Tank ID: T3: Diesel(Diesel)

Take the following measurements with the valve installed in the tank:

Distance from the 7150 inlet tube flange to the cast lug in the 7150 body (see figures), upper tube length.  
**Note:** the Upper Tube Length must be at least 16" to include the protective bend in the tube.

(D) = 70.25

Distance from the 7150 inlet tube flange to the top and bottom of lower tube, valve length.

(W) = \_\_\_\_\_

(U) = \_\_\_\_\_

Distance from the 7150 inlet tube flange to the bottom of the tank. **Note:** If a tank bottom protector is present it may be necessary to add this thickness to dimension (OPW 6111 & 61TP models add 0.6")

(B) = 172.25

From the tank calibration chart provided by tank manufacturer find the dipstick number (Y) which corresponds to the 100% volume.

(Y) = 119.375

#### 1. To determine shut-off percentage:

Subtract upper tube length (D) from distance to tank bottom (B)


(X) = (B) - (D) - 2" = 100.00

Using the tank calibration chart provided by the tank manufacturer determine the tank capacity at the calculated (X) dimension and the 100% volume (Y) tank capacity.

(X) tank capacity in gallons = 10710

(Y) tank capacity in gallons = 11897

SO% = (X) capacity / (Y) capacity x 100 = 90.02



**Note:** The overfill valve must be installed per AHJ requirements and all applicable local, state, and national codes. If the overfill valve is set above the allowable shut-off percentage the overfill valve must be removed and replaced. For reference 40 CFR part 280 Subpart B Section 280.20 overfill valves should be set to a maximum of 95%.

Tank ID: T1: Regular(REGULAR)

**2. To determine lower tube distance from tank bottom to bottom of cut:**

Subtract valve length (W) from distance to tank bottom (B)

$$(V) = (B) - (W) = 2.375$$

**Note:** Lower tube clearance must meet tank manufacturer requirements and all AHJ, local, state, and national codes. Typical clearance is about 4". If lower tube clearance is not met valve must be removed and adjusted to meet these requirements.

**3. To determine lower tube distance from tank bottom to top of cut:**


Subtract valve length (U) from distance to tank bottom (B)

$$(T) = (B) - (U) = 5.125$$

**Note:** Lower tube distance from tank bottom to top of cut must meet all AHJ, local, state, and national codes. For reference per 40 CFR 63 subpart CCCCCC / NESHAP the lower tube can be no more than 6" from the bottom of the tank. If lower tube distance is not met valve must be removed and adjusted to meet these requirements.

**4. To determine float alignment:**

Looking into upper tube (see figure) the float should be aligned along the length of the tank. If float is not aligned properly adjustments need to be made.



*View into drop tube from above*

**2. To determine lower tube distance from tank bottom to bottom of cut:**

Subtract valve length (W) from distance to tank bottom (B)

$$(V) = (B) - (W) = 3.125$$

**Note:** Lower tube clearance must meet tank manufacturer requirements and all AHJ, local, state, and national codes. Typical clearance is about 4". If lower tube clearance is not met valve must be removed and adjusted to meet these requirements.

**3. To determine lower tube distance from tank bottom to top of cut:**


Subtract valve length (U) from distance to tank bottom (B)

$$(T) = (B) - (U) = 5.75$$

**Note:** Lower tube distance from tank bottom to top of cut must meet all AHJ, local, state, and national codes. For reference per 40 CFR 63 subpart CCCCCC / NESHAP the lower tube can be no more than 6" from the bottom of the tank. If lower tube distance is not met valve must be removed and adjusted to meet these requirements.

**4. To determine float alignment:**

Looking into upper tube (see figure) the float should be aligned along the length of the tank. If float is not aligned properly adjustments need to be made.



**View into drop tube from above**



# Site Diagram

(This site diagram is for reference only and is not drawn to scale)

Work Order:

2362766

Site ID / Name:

38699 / 7-Eleven 38699

Address:


2631 S 38th St

City:

Tacoma

State: WA

Zip: 98409





203096 7-11 38699  
2631 S 38TH ST  
TACOMA WA 98409  
U11268752605001

OCT 19, 2023 8:20 AM

SYSTEM STATUS REPORT

ALL FUNCTIONS NORMAL

INVENTORY REPORT

T 1:RUL  
VOLUME = 12158 GALS  
ULLAGE = 7772 GALS  
90% ULLAGE = 5779 GALS  
TC VOLUME = 12128 GALS  
HEIGHT = 69.78 INCHES  
WATER VOL = 0 GALS  
WATER = 0.00 INCHES  
TEMP = 63.6 DEG F

T 2:PUL  
VOLUME = 2309 GALS  
ULLAGE = 5730 GALS  
90% ULLAGE = 4926 GALS  
TC VOLUME = 2302 GALS  
HEIGHT = 39.11 INCHES  
WATER VOL = 0 GALS  
WATER = 0.00 INCHES  
TEMP = 64.2 DEG F

T 3:DSL  
VOLUME = 3176 GALS  
ULLAGE = 8721 GALS  
90% ULLAGE = 7531 GALS  
TC VOLUME = 3168 GALS  
HEIGHT = 37.64 INCHES  
WATER VOL = 0 GALS  
WATER = 0.00 INCHES  
TEMP = 65.4 DEG F

\*\*\*\*\* END \*\*\*\*\*

203096 7-11 38699  
2631 S 38TH ST  
TACOMA WA 98409  
U11268752605001

OCT 19, 2023 8:21 AM

LIQUID STATUS

OCT 19, 2023 8:21 AM

L 1:DISP 1-2  
SENSOR NORMAL

L 2:DISP 3-4  
SENSOR NORMAL

L 3:DISP 5-6  
SENSOR NORMAL

L 4:DISP 7-8  
SENSOR NORMAL

L 5:DISP 9-10  
SENSOR NORMAL

L 6:DISP 11-12  
SENSOR NORMAL

L 7:RUL STP SUMP  
SENSOR NORMAL

L 8:PUL STP SUMP  
SENSOR NORMAL

L 9:DSL STP SUMP  
SENSOR NORMAL

L10:RUL ANNULAR  
SENSOR NORMAL

L11:DSL-PUL ANNULAR  
SENSOR NORMAL

L12:DSL FILL  
SENSOR NORMAL

L13:PUL FILL  
SENSOR NORMAL

L14:RUL FILL  
SENSOR NORMAL

\*\*\*\*\* END \*\*\*\*\*

203096 7-11 38699  
2631 S 38TH ST  
TACOMA WA 98409  
U11268752605001

OCT 19, 2023 1:08 PM

SYSTEM STATUS REPORT

ALL FUNCTIONS NORMAL

INVENTORY REPORT

T 1:RUL  
VOLUME = 12154 GALS  
ULLAGE = 7776 GALS  
90% ULLAGE = 5783 GALS  
TC VOLUME = 12122 GALS  
HEIGHT = 69.76 INCHES  
WATER VOL = 0 GALS  
WATER = 0.00 INCHES  
TEMP = 63.7 DEG F

T 2:PUL  
VOLUME = 2255 GALS  
ULLAGE = 5784 GALS  
90% ULLAGE = 4980 GALS  
TC VOLUME = 2249 GALS  
HEIGHT = 38.44 INCHES  
WATER VOL = 0 GALS  
WATER = 0.00 INCHES  
TEMP = 63.8 DEG F

T 3:DSL  
VOLUME = 3176 GALS  
ULLAGE = 8721 GALS  
90% ULLAGE = 7531 GALS  
TC VOLUME = 3167 GALS  
HEIGHT = 37.64 INCHES  
WATER VOL = 0 GALS  
WATER = 0.00 INCHES  
TEMP = 65.4 DEG F

\*\*\*\*\* END \*\*\*\*\*

SOFTWARE REVISION LEVEL  
VERSION 335.00  
SOFTWARE# 346335-100-A  
CREATED - 16.08.27.10.22

S-MODULE# 330160-100-a  
SYSTEM FEATURES:  
PERIODIC IN-TANK TESTS  
ANNUAL IN-TANK TESTS  
BIR

203096 7-11 38699  
2631 S 38TH ST  
TACOMA WA 98409  
U11268752605001

OCT 19, 2023 1:08 PM

LIQUID STATUS

OCT 19, 2023 1:08 PM

L 1:DISP 1-2  
SENSOR NORMAL

L 2:DISP 3-4  
SENSOR NORMAL

L 3:DISP 5-6  
SENSOR NORMAL

L 4:DISP 7-8  
SENSOR NORMAL

L 5:DISP 9-10  
SENSOR NORMAL

L 6:DISP 11-12  
SENSOR NORMAL

L 7:RUL STP SUMP  
SENSOR NORMAL

L 8:PUL STP SUMP  
SENSOR NORMAL

L 9:DSL STP SUMP  
SENSOR NORMAL

L10:RUL ANNULAR  
SENSOR NORMAL

L11:DSL-PUL ANNULAR  
SENSOR NORMAL

L12:DSL FILL  
SENSOR NORMAL

L13:PUL FILL  
SENSOR NORMAL

L14:RUL FILL  
SENSOR NORMAL

## IN-TANK SETUP

T 1:RUL  
 PRODUCT CODE : 1  
 THERMAL COEFF : .000690  
 TANK DIAMETER : 119.38  
 TANK PROFILE : 4 PTS  
 FULL VOL : 19930  
 89.5 INCH VOL : 16112  
 59.7 INCH VOL : 10003  
 29.8 INCH VOL : 3866  
 METER DATA : YES  
 END FACTOR: HEMISPHER  
 CAL UPDATE: NEVER

FLOAT SIZE: 4.0 IN.  
 WATER MINIMUM : 0.000

WATER WARNING : 0.8  
 HIGH WATER LIMIT: 1.0  
 WATER ALARM FILTER: LOW

MAX OR LABEL  
 VOLUME : 19930

HIGH PRODUCT  
 % MAX : 95.0  
 (GALLONS) : 18934

OVERFILL LIMIT  
 % MAX : 90.0  
 (GALLONS) : 17937

DELIVERY LIMIT  
 % MAX : 15.0  
 (GALLONS) : 2990

LOW PRODUCT  
 VOLUME : 801

LEAK ALARM LIMIT: 15  
 SUDDEN LOSS LIMIT: 99  
 TANK TILT : 0.00  
 PROBE OFFSET : 0.00

SIPHON MANIFOLDED TANKS  
 T#: NONE  
 LINE MANIFOLDED TANKS  
 T#: NONE

LEAK MIN PERIODIC: 25%  
 : 4982

LEAK MIN ANNUAL : 50%  
 : 9965

PERIODIC TEST TYPE  
 STANDARD

ANNUAL TEST FAIL  
 ALARM DISABLED

PERIODIC TEST FAIL  
 ALARM DISABLED

GROSS TEST FAIL  
 ALARM DISABLED

ANN TEST AVERAGING: OFF  
 PER TEST AVERAGING: OFF

TANK TEST NOTIFY: OFF

TNK TST SIPHON BREAK:OFF

DELIVERY DELAY : 5 MIN  
 PUMP THRESHOLD : 10.00%

T 2:PUL  
 PRODUCT CODE : 3  
 THERMAL COEFF : .000690  
 TANK DIAMETER : 119.38  
 TANK PROFILE : 4 PTS  
 FULL VOL : 8039  
 89.5 INCH VOL : 7096  
 59.7 INCH VOL : 4035  
 29.8 INCH VOL : 1590  
 METER DATA : YES  
 END FACTOR: HEMISPHER  
 CAL UPDATE: NEVER

FLOAT SIZE: 4.0 IN.  
 WATER MINIMUM : 0.000

WATER WARNING : 0.8  
 HIGH WATER LIMIT: 1.0  
 WATER ALARM FILTER: LOW

MAX OR LABEL  
 VOLUME : 8039

HIGH PRODUCT  
 % MAX : 95.0  
 (GALLONS) : 7637

OVERFILL LIMIT  
 % MAX : 90.0  
 (GALLONS) : 7235

DELIVERY LIMIT  
 % MAX : 15.0  
 (GALLONS) : 1206

LOW PRODUCT  
 VOLUME : 339

LEAK ALARM LIMIT: 15  
 SUDDEN LOSS LIMIT: 99  
 TANK TILT : 0.00  
 PROBE OFFSET : 0.00

SIPHON MANIFOLDED TANKS  
 T#: NONE  
 LINE MANIFOLDED TANKS  
 T#: NONE

LEAK MIN PERIODIC: 25%  
 : 2009

LEAK MIN ANNUAL : 50%  
 : 4019

PERIODIC TEST TYPE  
 STANDARD

ANNUAL TEST FAIL  
 ALARM DISABLED

PERIODIC TEST FAIL  
 ALARM DISABLED

GROSS TEST FAIL  
 ALARM DISABLED

ANN TEST AVERAGING: OFF  
 PER TEST AVERAGING: OFF

TANK TEST NOTIFY: OFF

TNK TST SIPHON BREAK:OFF

DELIVERY DELAY : 5 MIN  
 PUMP THRESHOLD : 10.00%

T 3:DSL  
 PRODUCT CODE : 4  
 THERMAL COEFF : .000450  
 TANK DIAMETER : 119.38  
 TANK PROFILE : 4 PTS  
 FULL VOL : 11897  
 89.5 INCH VOL : 9648  
 59.7 INCH VOL : 5971  
 29.8 INCH VOL : 2280  
 METER DATA : YES  
 END FACTOR: HEMISPHER  
 CAL UPDATE: NEVER

FLOAT SIZE: 4.0 IN.  
 WATER MINIMUM : 0.000

WATER WARNING : 0.8  
 HIGH WATER LIMIT: 1.0  
 WATER ALARM FILTER: LOW

MAX OR LABEL  
 VOLUME : 11897

HIGH PRODUCT  
 % MAX : 95.0  
 (GALLONS) : 11302

OVERFILL LIMIT  
 % MAX : 90.0  
 (GALLONS) : 10707

DELIVERY LIMIT  
 % MAX : 15.0  
 (GALLONS) : 1785

LOW PRODUCT  
 VOLUME : 462

LEAK ALARM LIMIT: 15  
 SUDDEN LOSS LIMIT: 99  
 TANK TILT : 0.00  
 PROBE OFFSET : 0.00

SIPHON MANIFOLDED TANKS  
 T#: NONE  
 LINE MANIFOLDED TANKS  
 T#: NONE

LEAK MIN PERIODIC: 25%  
 : 2974

LEAK MIN ANNUAL : 50%  
 : 5948

PERIODIC TEST TYPE  
 STANDARD

ANNUAL TEST FAIL  
 ALARM DISABLED

PERIODIC TEST FAIL  
 ALARM DISABLED

GROSS TEST FAIL  
 ALARM DISABLED

ANN TEST AVERAGING: OFF  
 PER TEST AVERAGING: OFF

TANK TEST NOTIFY: OFF

TNK TST SIPHON BREAK:OFF

DELIVERY DELAY : 5 MIN  
 PUMP THRESHOLD : 10.00%

# ALARM HISTORY REPORT

---- IN-TANK ALARM ----

T 1:RUL

SETUP DATA WARNING  
NOV 12. 2020 1:37 PM

HIGH WATER ALARM  
OCT 19. 2023 9:46 AM  
NOV 2. 2022 4:47 AM  
NOV 10. 2021 1:22 PM

OVERFILL ALARM  
OCT 19. 2023 9:47 AM  
NOV 2. 2022 5:10 AM  
NOV 10. 2021 1:24 PM

LOW PRODUCT ALARM  
OCT 19. 2023 9:43 AM  
NOV 2. 2022 4:43 AM  
NOV 30. 2020 10:18 AM

HIGH PRODUCT ALARM  
OCT 19. 2023 9:50 AM  
NOV 2. 2022 5:10 AM  
NOV 10. 2021 1:33 PM

INVALID FUEL LEVEL  
OCT 19. 2023 9:43 AM  
  
PROBE OUT  
NOV 17. 2020 10:40 AM  
NOV 12. 2020 10:33 AM

HIGH WATER WARNING  
OCT 19. 2023 9:46 AM  
NOV 2. 2022 4:47 AM  
NOV 10. 2021 1:22 PM

DELIVERY NEEDED  
OCT 19. 2023 9:43 AM  
JUN 9. 2023 4:10 AM  
NOV 2. 2022 4:43 AM

MAX PRODUCT ALARM  
NOV 10. 2021 1:33 PM  
NOV 30. 2020 11:46 AM

LOW TEMP WARNING  
OCT 19. 2023 9:52 AM  
NOV 2. 2022 5:13 AM  
NOV 10. 2021 1:46 PM

# ALARM HISTORY REPORT

---- IN-TANK ALARM ----

T 2:PUL

SETUP DATA WARNING  
NOV 12. 2020 1:37 PM

HIGH WATER ALARM  
OCT 19. 2023 8:43 AM  
NOV 2. 2022 4:55 AM  
NOV 10. 2021 1:24 PM

OVERFILL ALARM  
OCT 19. 2023 8:46 AM  
NOV 2. 2022 5:08 AM  
JAN 12. 2022 4:41 AM

LOW PRODUCT ALARM  
OCT 19. 2023 9:00 AM  
OCT 19. 2023 8:40 AM  
NOV 2. 2022 4:50 AM

HIGH PRODUCT ALARM  
OCT 19. 2023 8:46 AM  
NOV 2. 2022 5:08 AM  
NOV 10. 2021 1:25 PM

INVALID FUEL LEVEL  
OCT 19. 2023 8:41 AM  
  
PROBE OUT  
NOV 17. 2020 10:30 AM  
NOV 12. 2020 10:33 AM

HIGH WATER WARNING  
OCT 19. 2023 8:43 AM  
NOV 2. 2022 4:53 AM  
NOV 10. 2021 1:24 PM

DELIVERY NEEDED  
OCT 19. 2023 9:00 AM  
OCT 19. 2023 8:39 AM  
OCT 9. 2023 4:06 PM

MAX PRODUCT ALARM  
OCT 19. 2023 8:50 AM  
NOV 2. 2022 5:10 AM  
NOV 10. 2021 1:33 PM

LOW TEMP WARNING  
NOV 10. 2021 1:44 PM  
NOV 30. 2020 2:09 PM

# ALARM HISTORY REPORT

---- IN-TANK ALARM ----

T 3:DSL

SETUP DATA WARNING  
NOV 12. 2020 1:37 PM

HIGH WATER ALARM  
OCT 19. 2023 8:42 AM  
NOV 2. 2022 4:56 AM  
NOV 10. 2021 1:27 PM

OVERFILL ALARM  
OCT 19. 2023 8:46 AM  
NOV 2. 2022 5:10 AM  
NOV 10. 2021 1:26 PM

LOW PRODUCT ALARM  
OCT 19. 2023 8:39 AM  
NOV 2. 2022 4:52 AM  
NOV 30. 2020 10:14 AM

HIGH PRODUCT ALARM  
OCT 19. 2023 8:46 AM  
NOV 2. 2022 5:10 AM  
NOV 10. 2021 1:33 PM

INVALID FUEL LEVEL  
NOV 2. 2022 4:52 AM  
NOV 30. 2020 10:14 AM  
NOV 12. 2020 1:35 PM

PROBE OUT  
NOV 17. 2020 9:50 AM  
NOV 12. 2020 10:33 AM

HIGH WATER WARNING  
OCT 19. 2023 8:42 AM  
NOV 2. 2022 4:56 AM  
JAN 12. 2022 5:10 AM

DELIVERY NEEDED  
OCT 19. 2023 8:38 AM  
OCT 6. 2023 2:37 PM  
SEP 30. 2023 1:43 AM

MAX PRODUCT ALARM  
NOV 10. 2021 1:33 PM  
NOV 30. 2020 11:47 AM

LOW TEMP WARNING  
OCT 19. 2023 8:56 AM  
NOV 2. 2022 5:20 AM

# ALARM HISTORY REPORT

---- SENSOR ALARM ----

L13:PUL FILL

OTHER SENSORS

FUEL ALARM  
OCT 19. 2023 8:55 AM

FUEL ALARM  
NOV 2. 2022 5:13 AM

FUEL ALARM  
NOV 10. 2021 12:47 PM

\* \* \* \* \* END \* \* \* \* \*

# ALARM HISTORY REPORT

---- SENSOR ALARM ----

L14:RUL FILL

OTHER SENSORS

FUEL ALARM  
OCT 19. 2023 9:34 AM

FUEL ALARM  
NOV 2. 2022 5:07 AM

FUEL ALARM  
NOV 10. 2021 12:46 PM

## ALARM HISTORY REPORT

----- SENSOR ALARM -----  
L 1:DISP 1-2  
DISPENSER PAN  
FUEL ALARM  
OCT 19, 2023 9:50 AM

FUEL ALARM  
NOV 2, 2022 5:01 AM

FUEL ALARM  
NOV 10, 2021 12:24 PM

\*\*\*\*\* END \*\*\*\*\*

## ALARM HISTORY REPORT

----- SENSOR ALARM -----  
L 4:DISP 7-8  
DISPENSER PAN  
FUEL ALARM  
OCT 19, 2023 9:49 AM

FUEL ALARM  
NOV 2, 2022 4:59 AM

FUEL ALARM  
NOV 10, 2021 12:26 PM

\*\*\*\*\* END \*\*\*\*\*

## ALARM HISTORY REPORT

----- SENSOR ALARM -----  
L 7:PUL STP SUMP  
STP SUMP  
FUEL ALARM  
OCT 19, 2023 9:42 AM

FUEL ALARM  
NOV 2, 2022 4:42 AM

FUEL ALARM  
NOV 10, 2021 12:29 PM

\*\*\*\*\* END \*\*\*\*\*

## ALARM HISTORY REPORT

----- SENSOR ALARM -----  
L10:PUL ANNULAR  
ANNULAR SPACE  
FUEL ALARM  
OCT 19, 2023 9:58 AM

FUEL ALARM  
NOV 2, 2022 7:34 AM

FUEL ALARM  
NOV 10, 2021 12:59 PM

\*\*\*\*\* END \*\*\*\*\*

## ALARM HISTORY REPORT

----- SENSOR ALARM -----  
L 3:DISP 3-4  
DISPENSER PAN  
FUEL ALARM  
OCT 19, 2023 9:49 AM

FUEL ALARM  
NOV 2, 2022 5:01 AM

FUEL ALARM  
NOV 10, 2021 12:25 PM

\*\*\*\*\* END \*\*\*\*\*

## ALARM HISTORY REPORT

----- SENSOR ALARM -----  
L 5:DISP 9-10  
DISPENSER PAN  
FUEL ALARM  
OCT 19, 2023 9:57 AM

FUEL ALARM  
NOV 2, 2022 4:58 AM

FUEL ALARM  
NOV 10, 2021 12:26 PM

\*\*\*\*\* END \*\*\*\*\*

## ALARM HISTORY REPORT

----- SENSOR ALARM -----  
L 8:PUL STP SUMP  
STP SUMP  
FUEL ALARM  
OCT 19, 2023 8:39 AM

FUEL ALARM  
NOV 2, 2022 4:49 AM

FUEL ALARM  
NOV 10, 2021 12:29 PM

\*\*\*\*\* END \*\*\*\*\*

## ALARM HISTORY REPORT

----- SENSOR ALARM -----  
L11:DSL-PUL ANNULAR  
ANNULAR SPACE  
FUEL ALARM  
NOV 2, 2022 6:53 AM

FUEL ALARM  
NOV 10, 2021 12:55 PM

FUEL ALARM  
NOV 30, 2020 1:27 PM

\*\*\*\*\* END \*\*\*\*\*

## ALARM HISTORY REPORT

----- SENSOR ALARM -----  
L 3:DISP 5-6  
DISPENSER PAN  
FUEL ALARM  
OCT 19, 2023 9:48 AM

FUEL ALARM  
NOV 2, 2022 5:00 AM

FUEL ALARM  
NOV 10, 2021 12:25 PM

## ALARM HISTORY REPORT

----- SENSOR ALARM -----  
L 6:DISP 11-12  
DISPENSER PAN  
FUEL ALARM  
OCT 19, 2023 9:47 AM

FUEL ALARM  
NOV 2, 2022 4:59 AM

FUEL ALARM  
NOV 2, 2022 1:26 PM

## ALARM HISTORY REPORT

----- SENSOR ALARM -----  
L 9:DSL STP SUMP  
STP SUMP  
FUEL ALARM  
OCT 19, 2023 8:08 AM

FUEL ALARM  
NOV 2, 2022 4:51 AM

FUEL ALARM  
NOV 10, 2021 12:30 PM

## ALARM HISTORY REPORT

----- SENSOR ALARM -----  
L12:DSL FILL  
OTHER SENSORS  
FUEL ALARM  
OCT 19, 2023 8:54 AM

FUEL ALARM  
NOV 2, 2022 5:17 AM

FUEL ALARM  
NOV 10, 2021 12:48 PM