

GALVANIC CATHODIC PROTECTION EVALUATION CHECKLIST FOR UNDERGROUND STORAGE TANKS

This checklist certifies that cathodic protection testing activities were performed and conducted in accordance with Chapter 173-360A WAC. Instructions are found on the back page.

I. UST FACILITY			II. CERTIFIED CATHODIC PROTECTION TESTER		
Facility Compliance Tag #: A0005			Service Provider Name: MARCUS ROUNDS		
UST ID #: 3997			Company Name: MTM SERVICES LLC		
Site Name: FOODMART #0605			Address: PO BOX 576		
Site Address: 108 HWY 603			City: TWISP	State: WA	Zip: 98856
City: CHEHALIS			Phone: 509-560-0421	Email: MARCUS.ROUNDS94@GMAIL.COM	
County: LEWIS			Certification Type: STI		
Phone: 253-255-0487			Certification Number: CP- 16624	Exp. Date: 06-25	
III. RESULTS OF EVALUATION (which include results of both continuity and system surveys)					
<input checked="" type="checkbox"/> PASS The criteria used to evaluate whether cathodic protection is adequate were in accordance with a code of practice developed by a nationally recognized association (e.g. NACE), as required by the Washington State Underground Storage Tank Regulations.					
<input type="checkbox"/> FAIL					
Date CP Evaluation Performed: 9/18/2024					
IV. CRITERIA APPLICABLE TO EVALUATION					
<input checked="" type="checkbox"/> PASS – continuity data is passing and no action is needed <input type="checkbox"/> FAIL – continuity data is failing and the system requires a repair or retrofit					
Neg. 850 mV ON	<input checked="" type="checkbox"/> PASS <input type="checkbox"/> FAIL			3	A negative (cathodic) potential of at least -850 mV with the cathodic protection applied. This potential is with respect to a saturated copper-copper sulfate reference electrode containing electrolyte.
Neg. 850 mV Instant Off	<input type="checkbox"/> PASS <input type="checkbox"/> FAIL				A negative polarized potential of at least 850 mV relative to a saturated copper-copper sulfate reference electrode (Instant Off Potential).
100 mV Polarization	<input type="checkbox"/> PASS <input type="checkbox"/> FAIL				A minimum of 100 mV of cathodic polarization between the structure surface and a stable reference electrode contacting the electrolyte.
V. ACTION REQUIRED AS A RESULT OF THIS EVALUATION (check one box and explain further in comment box below)					
<input checked="" type="checkbox"/> NONE		The cathodic protection system is adequately providing protection. No further action is necessary at this time. System must be tested in three years unless more immediate attention is required.			
<input type="checkbox"/> RETEST		The cathodic protection system may not be adequately protecting steel from corroding. Retesting is necessary.			
<input type="checkbox"/> RETROFIT/REPAIR		The cathodic protection system is not adequately providing protection. Retrofitting or repairing is necessary.			
<input type="checkbox"/> RETEST AFTER RETROFIT/REPAIR		The cathodic protection system has been retrofitted or repaired and tested at time of the retrofit/repair. Testing is required again within one to six months after the retrofit or repair.			
Comments (include type of testing gear used, steel components tested, etc.: FLUKE 110 MULTIMETER, MCMILLER RE-5 REFERENCE CELL, COPPER ROD, WIRE SPOOL)					

1. If no submersible turbine pump (STP) is present, these steel flex connectors (SFC) are on the tank end of piping.
2. If no dispenser is installed, these SFCs are on the non-tank end of piping.


VI. CONTINUITY SURVEY

Structure "A"	Structure "B"	Point "A" to Point "B" or Fixed Cell Location >30'	Structure "A" Fixed Voltage >30'	Structure "B" Fixed Voltage >30'	Point-to-Point or Fixed Voltage Difference	P A S S	F A I L	Method and Standards Used (e.g. RP-0285, R051)
FLEX 680	FILL	30' SOUTH	-1228 MV	-528 MV	700 MV	<input checked="" type="checkbox"/>	<input type="checkbox"/>	R051
FLEX 182	FILL	"	-1349 MV	-474 MV	875 MV	<input checked="" type="checkbox"/>	<input type="checkbox"/>	"
FLEX 181	FILL	"	-1466 MV	-472 MV	-994 MV	<input checked="" type="checkbox"/>	<input type="checkbox"/>	"
						<input type="checkbox"/>	<input type="checkbox"/>	
						<input type="checkbox"/>	<input type="checkbox"/>	
						<input type="checkbox"/>	<input type="checkbox"/>	
						<input type="checkbox"/>	<input type="checkbox"/>	
						<input type="checkbox"/>	<input type="checkbox"/>	
						<input type="checkbox"/>	<input type="checkbox"/>	
						<input type="checkbox"/>	<input type="checkbox"/>	
						<input type="checkbox"/>	<input type="checkbox"/>	
						<input type="checkbox"/>	<input type="checkbox"/>	
						<input type="checkbox"/>	<input type="checkbox"/>	
						<input type="checkbox"/>	<input type="checkbox"/>	
						<input type="checkbox"/>	<input type="checkbox"/>	
						<input type="checkbox"/>	<input type="checkbox"/>	

VII. SYSTEM SURVEY

Structure	Contact Point	Half Cell Location	Local Voltage "ON"	Local Voltage "Instant Off"	Remote Voltage "ON" >30'	Local Voltage (Depolarized)	P A S S	F A I L	Method and Standard Used
FLEX 680	LINE	STP	-1092 MV		-1228 MV		<input checked="" type="checkbox"/>	<input type="checkbox"/>	-850 ON
FLEX 182	"	"	-1146 MV		-1349 MV		<input checked="" type="checkbox"/>	<input type="checkbox"/>	"
FLEX 181	"	"	-1253 MV		-1466 MV		<input checked="" type="checkbox"/>	<input type="checkbox"/>	"
							<input type="checkbox"/>	<input type="checkbox"/>	
							<input type="checkbox"/>	<input type="checkbox"/>	
							<input type="checkbox"/>	<input type="checkbox"/>	
							<input type="checkbox"/>	<input type="checkbox"/>	
							<input type="checkbox"/>	<input type="checkbox"/>	
							<input type="checkbox"/>	<input type="checkbox"/>	
							<input type="checkbox"/>	<input type="checkbox"/>	
							<input type="checkbox"/>	<input type="checkbox"/>	
							<input type="checkbox"/>	<input type="checkbox"/>	
							<input type="checkbox"/>	<input type="checkbox"/>	
							<input type="checkbox"/>	<input type="checkbox"/>	
							<input type="checkbox"/>	<input type="checkbox"/>	
							<input type="checkbox"/>	<input type="checkbox"/>	
							<input type="checkbox"/>	<input type="checkbox"/>	

Diagram the site layout, including tanks, piping, and process buildings, equipment, etc., and any other notable structures or physical features. Indicate north with arrow. On the map labels include the full name and designations of any units, structures, etc., as they appear on the ground or as they are known to you. Do not use abbreviations.



IX. RETROFIT OR REPAIR DESIGN (if applicable)

All retrofitting or repairs to CP systems shall be designed by a Corrosion Expert. I certify that I am a Corrosion Expert qualified to engage in the practice of corrosion control on buried or submerged metal piping systems and metal tanks. I have attached copies of the retrofit/repair design and of the Underground Storage Tank Retrofit and Repair Checklist.

Corrosion Expert's Name:

Company's Name:

Nationally Recognized Association:


Certification Number:

Corrosion Expert's Signature:

Date:

X. REQUIRED SIGNATURES

The certified supervisor certifies the criteria used to evaluate whether cathodic protection is adequate were in accordance with a code of practice developed by a nationally recognized association (e.g. NACE), as required by the Washington State Underground Storage Tank Regulations.

9-18-2024		Marcus Rowles
Date	Signature of Certified Supervisor	Print or Type Name
9-18-2024	AMAN	AMAN
Date	Signature of Tank Owner or Authorized Representative	Print or Type Name