

Department of Ecology - Northwest Regional Office
 Underground Storage Tank Notice of Confirmed Release

Incident #: 4579 Date Ecology Notified: 7-9-93 Received by: UST-HR
 UST #: 101923 Incident Reported by: WT Services Phone: (206) 365-4872
 ERTS #: _____

Site

Owner

Name: Highline Water District ^{Shop yard}
 Address: 1986.3 28th Ave. S
 City: Seattle
 Zip + 4: 98198
 County: King
 Phone: _____
 Contact: _____

Name: Highline Water District
 Address: P.O. Box 3867
 City: Kent, WA 98032
 Zip + 4: 98032
 County: King
 Phone: (206) 824-0375
 Contact: _____

Consultant/Other Contacts

Contact Name	Affiliation	Phone	Ext.
<u>Daniel A. Wright</u>	<u>Consultant</u>	<u>365-4872</u>	_____
_____	_____	_____	_____
_____	_____	_____	_____

Affected Media

☒ Soil ☐ GW ☐ DW ☐ SW ☐ Sed.

Free Product?

☐ Yes ☒ No ☐ Excavation? ☐ GW?

Tank Information

Tank ID	Substance	Status	Status Date	Tank ID	Substance	Status	Status Date
1.	<u>500 gal Diesel</u>	<u>Removed</u>		6.			
2.	<u>3000 gal Gasoline</u>	<u>Removed</u>		7.			
3.				8.			
4.				9.			
5.				10.			

Cleanup Status: ☐ Assessing ☐ In Progress ☐ Monitoring ☒ Conducted ☐ Unknown

Comments (include remediation methods, PCS status, and if this is a "limited" cleanup):

Gasoline contamination in stockpiled excavated soil - no contamination below tank. No tank leakage observed by consultant. No diesel contamination based on lab results. 53 tons of soil disposed from site. gasoline - 160 mg/kg. Consultant believes site cleanup up completed.