

#8
30 day
Notice

CORVAIR FORGE
NOTICE OF PERMANENT CLOSURE OF UNDERGROUND STORAGE TANK(S)

NWRO

Site Owner/Operator: TOM STRICKLAND
Site Address: 9255 16th AVE. S.W. / CAMBRIDGE ST S.W.
Telephone: (206) 358-3416 SEATTLE

Site Notification Number (If known; this is assigned by Ecology): _____
Tank has been registered with Ecology (☐); tank was not registered (☐).

Local closure permit (if any) obtained from: SEATTLE FIRE DEPT.
(Always contact local authorities regarding permit requirements.)

Tank closure performed by:
Company/Individual: JOE HALL CONST INC
Telephone: (206) 922-6815 Date of Tank Closure: MARCH 1990
Method of Closure: (☒) Removal (☐) In-Place Closure
If closed in place, type of fill material used: _____

If removed, how will the tank(s) be disposed of? (☒) Scrap (☐) Landfill
(☐) Other method (please specify): _____
Disposal Location: GENERAL METALS / FINE SAND & GRAVEL

Tank ID Number	Tank(s) Closed		Last Material Stored
	Age	Size	
_____	<u>32 yrs</u>	<u>4,000</u>	<u>GAS</u>
_____	<u>32</u>	<u>1500</u>	<u>GAS</u>
_____	<u>32</u>	<u>1500</u>	<u>GAS</u>
_____	<u>27</u>	<u>200</u>	<u>WASTE OIL</u>
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

Will the tanks be replaced by new underground tanks? (☐) Yes (☒) No
(NOTE: If YES, you need to submit a notification form for the new tanks.)

Was a site assessment completed? (☒) Yes (☐) No If so, was contamination found? (☒) Yes (☐) No

(NOTE: The appropriate regional office of the Washington Department of Ecology should be contacted for assistance if contamination is found (see attached map). Records of the site closure must also be maintained at the site and must be available upon an inspector's request for at least three years after closure.)

Inspecting Agency: SEATTLE FIRE DEPT Inspector Name: PAMALA
(NOTE: This is generally the local fire department or agency enforcing the Uniform Fire Code; in some cases (usually involving contamination) it may be Ecology. In some instances there may be no inspecting agency.)

Signature: Ron Shrank Date: 2-7-90
Title: Job Foreman

Please return the completed form to:

Storage Tank Unit
Department of Ecology
M/S PV-11
Olympia, WA 98504-8711

DEPARTMENT OF ECOLOGY
UNDERGROUND STORAGE TANKS
RECEIVED

FEB 20 1990

DEPT. OF ECOLOGY-NWRO
ENVIRONMENTAL FORM

UNDERGROUND STORAGE TANK

NOTICE OF RELEASE

Complaint recieved by _____ Date 2-15-90
Reporter name _____
address _____
phone no. _____

Site name CORVAIR FORGE site ph. no. 762-6677
site address 16th SW + CAMBRIDGE (OFF OF DELBRIEGE)
site city SEATTLE county KING zip 98147
9255 16th SW OLD REPAIR FACILITY
Site owner _____
owner's address _____
city _____ zip _____

Consultant name JOE HALL
company HALL CONSTRUCTION ph.no. 784-8489
Other party TOM STRICKLAND ph.no. (821-0460)?
SPECTRA LABS
Description of Incident

Material: gasoline _____ diesel _____ waste oil _____ heat fuel _____
other material (describe) _____
No. of tanks _____ tank removal date _____
Status of clean-up _____
Comments _____

BTS { TANKS REMOVED
SAMPLES TPH 975 ppm
SOIL STOCKPILED IN BACK

Date inspected _____ Investigator _____
Referred to _____



2-15-90

LUST CLEANUP REPORT REVIEW	
LUST # <u>2628</u>	UST # <u>200907</u> Site Name <u>LORVAIR FORGE</u>
Change in Status of Release & Date (Awaiting Cleanup) (Cleanup Started) (Monitoring) (Reported Cleaned Up) (No Further Action) (<u>Unknown</u>) Date <u>NC</u> <u>7/13/00</u>	
Cause of Release (Overfill) (Piping Failure) (Spill)(Tank Failure) (Unknown) Remediation Technologies Used	
Report Title _____	Report Date _____
Report Type (Interim) (Monitoring) (Final) (Site Characterization) (Unknown)	
Date Received _____	Contractor _____
Comments <u>Rv 2000. NO UST FILE. INSUFFICIENT</u> <u>INFORMATION TO CHANGE STATUS. NO SA REPORTS;</u> <u>NO CLEANUP REPORTS. TPH-G / TPH-D, TPAG @</u> <u>975 WOULD NOT PASS METHOD B.</u>	
Fund Source (LUST Trust Fund) (PLIA) (Responsible Party) (State Fund)	
VCP/IRAP Status (Requested) (Not Requested) (Complete)	Reviewed by <u>John Bail</u> Date <u>7/13/00</u>

Nov. 4, 1999 (GG)

PC'S PROBABLY REMOVED FROM EXCAVATION.
NO RECORD TO JUSTIFY. (JB)

NO TANK DETAIL -
NO CLEANUP REPORTS -