



WA Leak Testing Checklist

FOR Underground Storage Tanks

UST ID #: 4852

County : Spokane

This checklist certifies testing activities were conducted in accordance with Chapter 173-360 WAC. Instructions are found on pages 4 and 5.

DATE TEST CONDUCTED: 05/30/2019

I. UST FACILITY		II. CERTIFIED SERVICE PROVIDER		
Facility Compliance Tag #:A3274		Service Provider Name: Neil Rosenkranz		
UST ID #: 4852		Company Name: Northwest Tank & Environmental Services, Inc.		
Site Name: The Gas Company		Address: 17407 59th Ave SE		
Site Address: 2706 E 29th Ave		City: Snohomish	State: WA	Zipcode: 98296
City: Spokane		Phone: (800) 742-9620	Email: info@nwtank.com	
Site Phone: 509-534-4828		ICC Certification Type: Tightness Testing ICBO- U3		
		ICC Cert. #: 8588-U3 Exp. Date: 10/12/2020		
III. UST OWNER/OPERATOR				
Name: The Gas Company		Phone: 509-534-4828	Email:	
Mailing Address: 2706 E 29th Ave		City: Spokane	State: WA	Zipcode: 99223-4808
IV. UST SYSTEM INFORMATION based on observations, not Ecology database				
-- use bolded acronyms, where applicable --				
	Tank ID:	Tank ID:	Tank ID:	Tank ID:
1. Tank ID # (tank name registered with Ecology)	1	2	3	
2. Date installed (if known)	7/14/1987	7/14/1987	7/14/1987	
3. Tank capacity (gallons)	10000	6000	6000	
4. Tank material (select NV if not <u>visually</u> verified): Steel (ST); Steel Clad w/ Corrosion Resist (CLAD); Fiberglass Reinforced Plastic (FRP); ST Ip3 ; Not Visible (NV)	STI-P3	STI-P3	STI-P3	
5. Tank construction (select NV if not <u>visually</u> verified): Single Wall (SW); Double Wall (DW); Compartment (COMP); Not Visible (NV)	DW	DW	DW	
6. Piping material (select NV if not <u>visually</u> verified): Steel (ST); Fiberglass reinforced Plastic (FRP); Flexible Plastic (FLEX); Not Visible (NV); Other(specify)	FLX	FLX	FLX	
7. Piping construction (select NV if not visually verified): Single Wall (SW); Double Wall (DW); Not Visible (NV)	DW	DW	DW	
8. Pumping system: Pressurized (PR); Safe Suction (SS); Non-Safe Suction (NSS); Siphon (S)	Pressure	Pressure	Pressure	

ECY 070-69 (Rev. Jan. 2016)



V. SERVICES PERFORMED (CHECK ALL THAT APPLY)						
Supporting test data and/or documentation must be attached or this checklist is considered incomplete.						
	PASS	FAIL	# tested	Describe: dispenser # used for testing lines and ALLD and other information required to duplicate test results.		
Lines	<input checked="" type="checkbox"/> ALLD Test	<input checked="" type="checkbox"/>	<input type="checkbox"/>	3	Leak detectors tested from dispenser 3/4	
	Method Used: <u>LDT 890</u> Mfr. Cert. exp. date: <u>03-13-2019</u>					
	Manufacturer and model numbers must be provided for each ALLD on the supporting documentation.					
Lines	<input checked="" type="checkbox"/> Line Tightness Test	<input checked="" type="checkbox"/>	<input type="checkbox"/>	3	Lines tested from dispenser 3/4	
	Method Used: <u>Acurite</u> Mfr. Cert. exp. date: <u>09-20-2020</u>					
	<input type="checkbox"/> Line Interstitial (or Sump Sensor) Test	<input type="checkbox"/>	<input type="checkbox"/>	—		
Tanks	<input type="checkbox"/> Tank Tightness Test (i.e. 3rd-party certified test up to overfill prevention level)	<input type="checkbox"/>	<input type="checkbox"/>	—		
	Method Used: _____ Mfr. Cert. exp. date: _____					
	<input type="checkbox"/> Tank Interstitial (or Tank Sensor) Test	<input type="checkbox"/>	<input type="checkbox"/>	—		
UST Equipment	<input type="checkbox"/> Monitor Equipment Check	<input type="checkbox"/>	<input type="checkbox"/>	—		
	<input type="checkbox"/> Overfill Equipment Check (check all that apply)	<input type="checkbox"/> Auto shutoff device	<input type="checkbox"/>	<input type="checkbox"/>	—	
		<input type="checkbox"/> Ball float valve	<input type="checkbox"/>	<input type="checkbox"/>	—	
		<input type="checkbox"/> Overfill Alarm	<input type="checkbox"/>	<input type="checkbox"/>	—	
	<input type="checkbox"/> Spill Bucket Test	<input type="checkbox"/>	<input type="checkbox"/>	—		
	<input type="checkbox"/> Tank Sump Test	<input type="checkbox"/>	<input type="checkbox"/>	—		
<input type="checkbox"/> Other (describe briefly)	<input type="checkbox"/>	<input type="checkbox"/>	—			
VI. COMMENTS <i>include descriptions to problems encountered and how they were addressed.</i>						
<p>Leak Detector: Comments - Leak detectors tested from dispenser 3/4. All leak detectors found 3 GPH leak at 10 psi. Leak detector testing passed.</p> <p>Line Test: Comments - Line tightness testing performed from dispenser 3/4. Lines tested at or above 1.5 times operating pressure. Line tightness testing passed.</p> <p>Tank Monitor: --Tank_monitors-- #1: All manual stick readings were within 1" of ATG readings.</p> <p>All liquid sensors were functionally tested and operate as required.</p> <p>Overfill and high product limits were set incorrectly in tank monitor. All limits were adjusted and reflect required percentages.</p>						

VII. CHECKLIST			
The following items shall be initialed by the Certified Service Provider.	YES	NO	N/A
1. Have all checked items been tested per recommended practices, code and/or manufacturer's requirements and in accordance with federal and/or state regulations?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2. Has the owner/operator been provided with written documentation of the testing results?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3. Has the owner/operator been made aware of any faulty equipment or necessary repairs?*	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Date work was completed:	05/30/2019		

ECY 070-69 (Rev. jan 2016)

VIII.SITE DIAGRAM -- include description and/or locations of equipment tested --	
<div> <div> <div> <div>1/2</div> <div>3/4</div> </div> <div> <div>5/6</div> <div>7/8</div> </div> </div> <div> <div> <div>STP</div> <div>Fill</div> <div>Vap</div> <div>ATG</div> <div>2" Riser</div> </div> <div> <div>STP</div> <div>Fill</div> <div>Vap</div> <div>ATG</div> <div>2" Riser</div> </div> <div> <div>STP</div> <div>Fill</div> <div>Vap</div> <div>ATG</div> <div>2" Riser</div> </div> </div> <div> <div>Vent's</div> <div> <div>TLS 300</div> </div> </div> <div> <div> <div>↗</div> <div>N</div> </div> <div> <div>DWF Lines</div> <div>DW STI-P3 Tank's</div> </div> </div> </div>	
<p>PERSONS SUBMITTING FALSE INFORMATION ARE SUBJECT TO FORMAL ENFORCEMENT AND/OR PENALTIES UNDER CHAPTER 173-360 WAC. .</p>	

IX. REQUIRED SIGNATURES

05/30/2019		Neil Rosenkranz - Tech
Date	Signature of Certified Service Provider	Print or Type Name
05/30/2019		Denny - Manager
Date	Signature of Tank Owner or Authorized Representative	Print or Type Name

ECY 070-69 (Rev. Jan. 2016)

Automatic Line Leak Detector Test Results

Company Name: The Gas Company
Site Name: The Gas Company
Address: 2706 E 29th Ave Spokane, WA 99223-4808
UST Site ID: 4852
Test Date/Time: 05/30/2019 06:58:25 am

Job ID Number: 84135
Technician Name: Neil Rosenkranz
License Number: 8588-U3
Expiration Date: 10/12/2020

Product: Regular Tank ID: 1 LD Type: Mechanical	Make: VMI Model: LD2000 Serial#: 15041218	Operating Pressure: 29 Holding Pressure: 28 Bleedback (ml): 150	Result: Pass
Additional Data For Mechanical Leak Detectors Only Metering Pressure: 17 Step Through Time: 3			
Product: Premium Tank ID: 2 LD Type: Mechanical	Make: VMI Model: LD2000 Serial#: 73743	Operating Pressure: 27 Holding Pressure: 26 Bleedback (ml): 150	Result: Pass
Additional Data For Mechanical Leak Detectors Only Metering Pressure: 18 Step Through Time: 2			
Product: Diesel Tank ID: 3 LD Type: Mechanical	Make: VMI Model: LD2000 Serial#: 30991	Operating Pressure: 29 Holding Pressure: 29 Bleedback (ml): 200	Result: Pass
Additional Data For Mechanical Leak Detectors Only Metering Pressure: 12 Step Through Time: 3			

Leak detector testing conducted in accordance with the procedures and limitations of the LDT 890 leak detector tester. A leak is simulated at the highest point in the line using the LDT 890 calibrated to 3 gph at a metering pressure of 10 psi. The owner or operator of the UST system is required to ensure any failed leak detector is replaced before placing the line back in service.

The results of any sampling, testing, or monitoring shall be maintained for at least five years, or for another reasonable period of time determined by the department or delegated agency, except that the results of tank tightness testing conducted in accordance with CFR 40 Part 280.44 shall be retained until the next test is conducted.

Comments: Leak detectors tested from dispenser 3/4. All leak detectors found 3 GPH leak at 10 psi. Leak detector testing passed.

Technician Name: Neil Rosenkranz
Signature:



Date: 05/30/2019

Line Tightness Test Results

Company Name: The Gas Company
 Site Name: The Gas Company
 Address: 2706 E 29th Ave Spokane, WA 99223-4808
 UST Site ID: 4852
 Test Date: 05/30/2019

Job ID Number: 84135
 Technician Name: Neil Rosenkranz
 License Number: 8588-U3
 Expiration Date: 10/12/2020

Line Tightness Test Data

Product:	Regular	Tank ID:	1	Start Time:	07:40
Approx Length:	100	STP MFG:	Red Jacket 3/4 HP	End Time:	08:15
Size:	1.5	Operating Pressure:	29	Total Test Time:	35mins
Line Material:	FLX	Test Pressure:	50	Final Leak Rate:	.00000
Wall Type:	DW	Isolation Dispenser:	Solenoid	Impact Valves Operational:	Yes
Boot Back:	Yes	Isolation Pump:	Ball Valve	Check Valve Location:	N/A
Line Type:	Pressure	Initial Cylinder Level:	0.025	Result:	Pass
		Final Cylinder Level:	0.025		

Product:	Premium	Tank ID:	2	Start Time:	07:40
Approx Length:	100	STP MFG:	Red Jacket 3/4 HP	End Time:	08:15
Size:	1.5	Operating Pressure:	27	Total Test Time:	35mins
Line Material:	FLX	Test Pressure:	50	Final Leak Rate:	.00000
Wall Type:	DW	Isolation Dispenser:	Solenoid	Impact Valves Operational:	Yes
Boot Back:	Yes	Isolation Pump:	Ball Valve	Check Valve Location:	N/A
Line Type:	Pressure	Initial Cylinder Level:	0.025	Result:	Pass
		Final Cylinder Level:	0.025		

Product:	Diesel	Tank ID:	3	Start Time:	07:40
Approx Length:	100	STP MFG:	Red Jacket 3/4 HP	End Time:	08:15
Size:	1.5	Operating Pressure:	29	Total Test Time:	35mins
Line Material:	FLX	Test Pressure:	50	Final Leak Rate:	.00000
Wall Type:	DW	Isolation Dispenser:	Solenoid	Impact Valves Operational:	Yes
Boot Back:	Yes	Isolation Pump:	Ball Valve	Check Valve Location:	N/A
Line Type:	Pressure	Initial Cylinder Level:	0.025	Result:	Pass
		Final Cylinder Level:	0.025		


Line tightness testing conducted in accordance with the procedures and limitations of the Acurite pipeline tester. A consistent leak rate of .01 gph or higher at 150% of normal operating pressure is considered a failure. The owner or operator of the UST system is required to report all failures to the appropriate agency within 24 hours.

The results of any sampling, testing, or monitoring shall be maintained for at least five years, or for another reasonable period of time determined by the department or delegated agency, except that the results of tank tightness testing conducted in accordance with CFR 40 Part 280.44 shall be retained until the next test is conducted.

Comments: Line tightness testing performed from dispenser 3/4. Lines tested at or above 1.5 times operating pressure. Line tightness testing passed.

Technician Name: Neil Rosenkranz

Signature:



Date: 05/30/2019

Monitoring System Certification

This form must be used to document testing and servicing of monitoring equipment. A separate certification or report must be prepared for each monitoring system control panel by the technician who performs the work. A copy of this form must be provided to the tank system owner/operator. The owner/operator must submit a copy of this form to the local agency regulating UST systems within 30 days of test date.

A. General Information

Facility Contact Person: Greg Svoboda
Make / Model Monitoring System: V-RTLS 300

Company Name: The Gas Company
Site Address: 2706 E 29th Ave
UST Site ID: 4852
Date Of Testing: 05/30/2019
Site Name: The Gas Company
City, State, ZIP: Spokane, WA 99223-4808
Facility Phone Number: 509-534-4828
Serial #: 71145578705001

B. Inventory of Equipment Tested/Certified

Tank #: 1 Regular		Tank #: 2 Premium	
In-Tank Gauging Probe	Mag 1 Probe	In-Tank Gauging Probe	Mag 1 Probe
Annular Space or Vault Sensor:	VR-409 (10 diam)	Annular Space or Vault Sensor:	VR-409 (10 diam)
Piping Sump / Trench Sensor:	VR-208	Piping Sump / Trench Sensor:	VR-208
Fill Sump Sensor:	N/A	Fill Sump Sensor:	N/A
Mechanical Line Leak Detector:	LD2000	Mechanical Line Leak Detector:	LD2000
Electronic Line Leak Detector:	N/A	Electronic Line Leak Detector:	N/A
Tank Overfill / High Level Sensor:	Emco BF	Tank Overfill / High Level Sensor:	Emco BF
Other:		Other:	
Tank #: 3 Diesel			
In-Tank Gauging Probe	Mag 1 Probe		
Annular Space or Vault Sensor:	VR-409 (10 diam)		
Piping Sump / Trench Sensor:	VR-208		
Fill Sump Sensor:	N/A		
Mechanical Line Leak Detector:	LD2000		
Electronic Line Leak Detector:	N/A		
Tank Overfill / High Level Sensor:	Emco BF		
Other:			

Dispenser ID:	1/2	Dispenser ID:	3/4
Dispenser Containment Sensors Model:	N/A	Dispenser Containment Sensors Model:	N/A
Shear Valves: Yes	Floats & Chains: No	Shear Valves: Yes	Floats & Chains: No
Dispenser ID:	5/6	Dispenser ID:	7/8
Dispenser Containment Sensors Model:	N/A	Dispenser Containment Sensors Model:	N/A
Shear Valves: Yes	Floats & Chains: No	Shear Valves: Yes	Floats & Chains: No

C. Certification

I certify that the equipment identified in this document was inspected/serviced in accordance with the manufacturers' guidelines. Attached to this certification is information (e.g. manufacturers' checklists) necessary to verify that this information is correct and a Plot Plan showing the layout of monitoring equipment. For any equipment capable of generating such reports, I have also attached a copy of the report (check all that apply):

Technician Name: Neil Rosenkranz

Certification Number:

Expiration Date:

Signature:



Testing Company Name: Northwest Tank & Environmental Services, Inc.

Address: 17407 59th Ave SE Snohomish, WA 98296

Date of Testing: 05/30/2019

D. Results of Testing/Service

Yes	Is the audible alarm operational?
Yes	Is the visual alarm operational?
Yes	Were all sensors visually inspected, functionally tested, and confirmed operational?
N/A	If alarms are relayed to a remote monitoring station, is all communications equipment operational?
No	For pressurized piping systems, does the turbine automatically shut down if the piping secondary containment monitoring system detects a leak, fails to operate, or is electrically disconnected?
N/A	If yes: which sensors initiate positive shut-down?
N/A	Did you confirm positive shut-down due to leaks and sensor failure/disconnection?
N/A	For tank systems that utilize the monitoring system as the primary tank overfill warning device (i.e. no mechanical overfill prevention valve is installed), is the overfill warning alarm visible and audible at the tank fill point(s) and operating properly?
N/A	If so, at what percent of tank capacity does the alarm trigger?
No	Was any monitoring equipment replaced? If yes, identify specific sensors, probes or other equipment replaced and list the manufacturer name and model for all replacement parts in Section E below.
No	Was liquid found in any secondary containment systems designed as dry systems?
N/A	If yes, what type of liquid?
Yes	Was monitoring system set-up reviewed to ensure proper settings? Attach setup reports, if applicable.
Yes	Is all monitoring equipment operational per manufacturers specifications?

In section E. below, describe how and when these deficiencies were or will be corrected.

E. Comments

All manual stick readings were within 1" of ATG readings. All liquid sensors were functionally tested and operate as required. Overfill and high product limits were set incorrectly in tank monitor. All limits were adjusted and reflect required percentages.

State Tank ID	Product	Manual Stick Readings(inches)	Gauge Readings(inches)	Difference
1	Regular	55.5	54.56	.94
2	Premium	36.75	35.75	1.00
3	Diesel	20.5	20.03	.47

F. In-Tank Gauging / SIR Equipment

This section must be completed if in-tank gauging equipment is used to perform leak detection monitoring.

No	Has all input wiring been inspected for proper entry and termination, including testing for ground faults?
No	Were all tank gauging probes visually inspected for damage and residue buildup?
Yes	Was accuracy of system product level readings tested?
Yes	Was accuracy of system water level readings tested?
N/A	Were all probes reinstalled properly?
No	Were all items on the equipment manufacturer's maintenance checklist completed?

G. Line Leak Detectors (LLD):

Yes	For equipment startup or annual equipment certification, was leak simulated to verify LLD performance?
3 GPH	Leak Rate
Yes	Were all LLDs confirmed operational and accurate within regulatory requirements?
Yes	Was the testing apparatus properly calibrated?
Yes	For mechanical LLDs, does the LLD restrict product flow if it detects a leak?
N/A	For electronic LLDs, does the turbine automatically shut off if the LLD detects a leak?
N/A	For electronic LLDs, does the turbine automatically shut off if any portion of the monitoring system is disabled or disconnected?
N/A	For electronic LLDs, does the turbine automatically shut off if any portion of the monitoring system malfunctions or fails a test?
N/A	For electronic LLDs, have all accessible wiring connections been visually inspected?
Yes	Were all items on the equipment manufacturer's maintenance checklist completed?