

## Underground Storage Tank System Summary

UST ID: 5250

**Site Name:** 7-ELEVEN #42090

[Glossary](#)

<b>UST ID:</b> 5250	<b>Facility/Site ID:</b> 75488972	<b>Latitude:</b> 47.32192	<b>Active Tag(s):</b> A0748
<b>Address:</b> 31204 PACIFIC HWY S		<b>Longitude:</b> -122.31311	<b>Responsible Unit:</b> Northwest
FEDERAL WAY, WA 98003		<b>County:</b> King	

### Tank Summary

Tank Name	Tank Status	Tank Install Date
7	Operational	7/1/1994
8	Operational	7/1/1994
6	Operational	7/1/1994
2	Removed	1/10/1984
3	Removed	1/1/1984
5	Removed	1/1/1984
1	Removed	1/1/1984
4	Removed	12/31/1964

<b>Tank Name:</b> 7		<b>Tank Status:</b> Operational	
<b>Tank Installation:</b> 7/1/1994	<b>Tank Upgrade:</b> 2/6/1998	<b>Business License Endorsement Expiration:</b> 11/30/2024	
<b>Tank Status Date:</b> 8/6/1996	<b>Piping Installation:</b> 2/6/1998	<b>Tank Permanently Closed Date:</b>	
Tank Information		Piping Information	
<b>Material:</b>	Fiberglass Reinforced Plastic	<b>Material:</b>	Fiberglass
<b>Construction:</b>	Double Wall Tank	<b>Construction:</b>	Double Wall Pipe
<b>Corrosion Protection:</b>	Corrosion Resistant	<b>Corrosion Protection:</b>	Corrosion Resistant
<b>Manifolded Tank:</b>		<b>SFC* at Tank:</b>	Single Wall Sump
<b>Release Detection:</b>	Interstitial Monitoring	<b>SFC* at Dispenser/Pump:</b>	Single Wall Sump
<b>Tank Manufacturer:</b>		<b>Primary Release Detection:</b>	Automatic Line Leak Detector (ALLD)
<b>Spill Prevention:</b>	Single Wall Spill Bucket	<b>Secondary Release Detection:</b>	Annual Line Tightness Test (LTT)
<b>Overfill Prevention:</b>	Automatic Shutoff (fill pipe)	<b>Pumping System:</b>	Pressurized System
<b>Actual Capacity:</b>	15,000 Gallons	<b>Piping Manufacturer:</b>	
<b>Capacity Range:</b>	10,000 to 19,999 Gallons	*SFC = Steel Flex Connector	
Compartment	Substance Stored	Substance Used	Capacity
1	Unleaded Gasoline	Motor Fuel for Vehicles	15,000 Gallons

## Underground Storage Tank System Summary

UST ID: 5250

<b>Tank Name:</b> 8		<b>Tank Status:</b> Operational	
<b>Tank Installation:</b> 7/1/1994	<b>Tank Upgrade:</b> 2/6/1998	<b>Business License Endorsement Expiration:</b> 11/30/2024	
<b>Tank Status Date:</b> 8/6/1996	<b>Piping Installation:</b> 2/6/1998	<b>Tank Permanently Closed Date:</b>	
Tank Information		Piping Information	
<b>Material:</b> Fiberglass Reinforced Plastic	<b>Material:</b> Fiberglass		
<b>Construction:</b> Double Wall Tank	<b>Construction:</b> Double Wall Pipe		
<b>Corrosion Protection:</b> Corrosion Resistant	<b>Corrosion Protection:</b> Corrosion Resistant		
<b>Manifolded Tank:</b>	<b>SFC* at Tank:</b> Single Wall Sump		
<b>Release Detection:</b> Interstitial Monitoring	<b>SFC* at Dispenser/Pump:</b> Single Wall Sump		
<b>Tank Manufacturer:</b>	<b>Primary Release Detection:</b> Automatic Line Leak Detector (ALLD)		
<b>Spill Prevention:</b> Single Wall Spill Bucket	<b>Secondary Release Detection:</b> Annual Line Tightness Test (LTT)		
<b>Overfill Prevention:</b> Automatic Shutoff (fill pipe)	<b>Pumping System:</b> Pressurized System		
<b>Actual Capacity:</b> 15,000 Gallons	<b>Piping Manufacturer:</b>		
<b>Capacity Range:</b> 10,000 to 19,999 Gallons	*SFC = Steel Flex Connector		
Compartment	Substance Stored	Substance Used	Capacity
1	Unleaded Gasoline	Motor Fuel for Vehicles	15,000 Gallons

<b>Tank Name:</b> 6		<b>Tank Status:</b> Operational	
<b>Tank Installation:</b> 7/1/1994	<b>Tank Upgrade:</b> 2/6/1998	<b>Business License Endorsement Expiration:</b> 11/30/2024	
<b>Tank Status Date:</b> 8/6/1996	<b>Piping Installation:</b> 2/6/1998	<b>Tank Permanently Closed Date:</b>	
Tank Information		Piping Information	
<b>Material:</b> Fiberglass Reinforced Plastic	<b>Material:</b> Fiberglass		
<b>Construction:</b> Double Wall Tank	<b>Construction:</b> Double Wall Pipe		
<b>Corrosion Protection:</b> Corrosion Resistant	<b>Corrosion Protection:</b> Corrosion Resistant		
<b>Manifolded Tank:</b>	<b>SFC* at Tank:</b> Single Wall Sump		
<b>Release Detection:</b> Interstitial Monitoring	<b>SFC* at Dispenser/Pump:</b> Single Wall Sump		
<b>Tank Manufacturer:</b>	<b>Primary Release Detection:</b> Automatic Line Leak Detector (ALLD)		
<b>Spill Prevention:</b> Single Wall Spill Bucket	<b>Secondary Release Detection:</b> Annual Line Tightness Test (LTT)		
<b>Overfill Prevention:</b> Automatic Shutoff (fill pipe)	<b>Pumping System:</b> Pressurized System		
<b>Actual Capacity:</b> 15,000 Gallons	<b>Piping Manufacturer:</b>		
<b>Capacity Range:</b> 10,000 to 19,999 Gallons	*SFC = Steel Flex Connector		
Compartment	Substance Stored	Substance Used	Capacity
1	Unleaded Gasoline	Motor Fuel for Vehicles	15,000 Gallons

## Underground Storage Tank System Summary

UST ID: 5250

<b>Tank Name:</b> 2		<b>Tank Status:</b> Removed	
<b>Tank Installation:</b> 1/10/1984	<b>Tank Upgrade:</b>	<b>Business License Endorsement Expiration:</b> 7/1/1994	
<b>Tank Status Date:</b> 8/6/1996	<b>Piping Installation:</b>	<b>Tank Permanently Closed Date:</b>	
Tank Information		Piping Information	
<b>Material:</b> Fiberglass Reinforced Plastic		<b>Material:</b> Fiberglass	
<b>Construction:</b> Single Wall Tank		<b>Construction:</b> Single Wall Pipe	
<b>Corrosion Protection:</b> Corrosion Resistant		<b>Corrosion Protection:</b> Corrosion Resistant	
<b>Manifolded Tank:</b>		<b>SFC* at Tank:</b>	
<b>Release Detection:</b>		<b>SFC* at Dispenser/Pump:</b>	
<b>Tank Manufacturer:</b>		<b>Primary Release Detection:</b>	
<b>Spill Prevention:</b> Single Wall Spill Bucket		<b>Secondary Release Detection:</b>	
<b>Overfill Prevention:</b> Ball Float Valve (vent line)		<b>Pumping System:</b> Pressurized System	
<b>Actual Capacity:</b> 10,000 Gallons		<b>Piping Manufacturer:</b>	
<b>Capacity Range:</b> 10,000 to 19,999 Gallons		*SFC = Steel Flex Connector	
Compartment	Substance Stored	Substance Used	Capacity
1	Unleaded Gasoline	Motor Fuel for Vehicles	10,000 Gallons

<b>Tank Name:</b> 3		<b>Tank Status:</b> Removed	
<b>Tank Installation:</b> 1/1/1984	<b>Tank Upgrade:</b>	<b>Business License Endorsement Expiration:</b> 7/1/1994	
<b>Tank Status Date:</b> 8/6/1996	<b>Piping Installation:</b>	<b>Tank Permanently Closed Date:</b>	
Tank Information		Piping Information	
<b>Material:</b> Fiberglass Reinforced Plastic		<b>Material:</b> Fiberglass	
<b>Construction:</b> Single Wall Tank		<b>Construction:</b> Single Wall Pipe	
<b>Corrosion Protection:</b> Corrosion Resistant		<b>Corrosion Protection:</b> Corrosion Resistant	
<b>Manifolded Tank:</b>		<b>SFC* at Tank:</b>	
<b>Release Detection:</b>		<b>SFC* at Dispenser/Pump:</b>	
<b>Tank Manufacturer:</b>		<b>Primary Release Detection:</b>	
<b>Spill Prevention:</b> Single Wall Spill Bucket		<b>Secondary Release Detection:</b>	
<b>Overfill Prevention:</b> Ball Float Valve (vent line)		<b>Pumping System:</b> Pressurized System	
<b>Actual Capacity:</b> 10,000 Gallons		<b>Piping Manufacturer:</b>	
<b>Capacity Range:</b> 10,000 to 19,999 Gallons		*SFC = Steel Flex Connector	
Compartment	Substance Stored	Substance Used	Capacity
1	Unleaded Gasoline	Motor Fuel for Vehicles	10,000 Gallons

## Underground Storage Tank System Summary

UST ID: 5250

<b>Tank Name:</b> 5		<b>Tank Status:</b> Removed	
<b>Tank Installation:</b> 1/1/1984	<b>Tank Upgrade:</b>	<b>Business License Endorsement Expiration:</b> 7/1/1994	
<b>Tank Status Date:</b> 8/6/1996	<b>Piping Installation:</b>	<b>Tank Permanently Closed Date:</b>	
Tank Information		Piping Information	
<b>Material:</b> Fiberglass Reinforced Plastic		<b>Material:</b> Fiberglass	
<b>Construction:</b> Single Wall Tank		<b>Construction:</b> Single Wall Pipe	
<b>Corrosion Protection:</b> Corrosion Resistant		<b>Corrosion Protection:</b>	
<b>Manifolded Tank:</b>		<b>SFC* at Tank:</b>	
<b>Release Detection:</b>		<b>SFC* at Dispenser/Pump:</b>	
<b>Tank Manufacturer:</b>		<b>Primary Release Detection:</b> Automatic Line Leak Detector (ALLD)	
<b>Spill Prevention:</b> 25 Gallons or less		<b>Secondary Release Detection:</b>	
<b>Overfill Prevention:</b> 25 Gallons or less		<b>Pumping System:</b> Product Removed by Reclaimer	
<b>Actual Capacity:</b>		<b>Piping Manufacturer:</b>	
<b>Capacity Range:</b> 111 TO 1,100 Gallons		*SFC = Steel Flex Connector	
Compartment	Substance Stored	Substance Used	Capacity
1	Used Oil/Waste Oil		

<b>Tank Name:</b> 1		<b>Tank Status:</b> Removed	
<b>Tank Installation:</b> 1/1/1984	<b>Tank Upgrade:</b>	<b>Business License Endorsement Expiration:</b> 7/1/1994	
<b>Tank Status Date:</b> 8/6/1996	<b>Piping Installation:</b>	<b>Tank Permanently Closed Date:</b>	
Tank Information		Piping Information	
<b>Material:</b> Fiberglass Reinforced Plastic		<b>Material:</b> Fiberglass	
<b>Construction:</b> Single Wall Tank		<b>Construction:</b> Single Wall Pipe	
<b>Corrosion Protection:</b> Corrosion Resistant		<b>Corrosion Protection:</b> Corrosion Resistant	
<b>Manifolded Tank:</b>		<b>SFC* at Tank:</b>	
<b>Release Detection:</b>		<b>SFC* at Dispenser/Pump:</b>	
<b>Tank Manufacturer:</b>		<b>Primary Release Detection:</b>	
<b>Spill Prevention:</b> Single Wall Spill Bucket		<b>Secondary Release Detection:</b>	
<b>Overfill Prevention:</b> Ball Float Valve (vent line)		<b>Pumping System:</b> Pressurized System	
<b>Actual Capacity:</b> 10,000 Gallons		<b>Piping Manufacturer:</b>	
<b>Capacity Range:</b> 10,000 to 19,999 Gallons		*SFC = Steel Flex Connector	
Compartment	Substance Stored	Substance Used	Capacity
1	Leaded Gasoline	Motor Fuel for Vehicles	10,000 Gallons

## Underground Storage Tank System Summary

UST ID: 5250

<b>Tank Name:</b> 4		<b>Tank Status:</b> Removed	
<b>Tank Installation:</b> 12/31/1964	<b>Tank Upgrade:</b>	<b>Business License Endorsement Expiration:</b>	
<b>Tank Status Date:</b> 8/6/1996	<b>Piping Installation:</b>	<b>Tank Permanently Closed Date:</b>	
<b>Tank Information</b>		<b>Piping Information</b>	
<b>Material:</b> Fiberglass Reinforced Plastic	<b>Material:</b> Fiberglass		
<b>Construction:</b> Single Wall Tank	<b>Construction:</b>		
<b>Corrosion Protection:</b>	<b>Corrosion Protection:</b>		
<b>Manifolded Tank:</b>	<b>SFC* at Tank:</b>		
<b>Release Detection:</b>	<b>SFC* at Dispenser/Pump:</b>		
<b>Tank Manufacturer:</b>	<b>Primary Release Detection:</b>		
<b>Spill Prevention:</b>	<b>Secondary Release Detection:</b>		
<b>Overfill Prevention:</b>	<b>Pumping System:</b>		
<b>Actual Capacity:</b>	<b>Piping Manufacturer:</b>		
<b>Capacity Range:</b> 111 TO 1,100 Gallons	<b>*SFC = Steel Flex Connector</b>		
<b>Compartment</b>	<b>Substance Stored</b>	<b>Substance Used</b>	<b>Capacity</b>
1	Diesel		