

## Underground Storage Tank System Summary

UST ID: 8801

**Site Name:** 7-ELEVEN #38699

[Glossary](#)

<b>UST ID:</b> 8801	<b>Facility/Site ID:</b> 22318281	<b>Latitude:</b> 47.22292	<b>Active Tag(s):</b> A5871
<b>Address:</b> 2631 S 38TH ST		<b>Longitude:</b> -122.47328	<b>Responsible Unit:</b> Southwest
TACOMA, WA 98409		<b>County:</b> Pierce	

### Tank Summary

Tank Name	Tank Status	Tank Install Date
1 RUL	Operational	9/24/2020
2A PUL/2B DIESEL	Operational	9/24/2020
UNLEAD 3	Removed	7/1/1989
UNLEAD 2	Removed	7/1/1989
REGULAR 1	Removed	7/1/1989
SUPER 4	Removed	7/1/1989
1	Removed	12/31/1964
3	Removed	12/31/1964
2	Removed	12/31/1964
4	Removed	12/31/1964

**Tank Name:** 1 RUL

**Tank Status:** Operational

**Tank Installation:** 9/24/2020    **Tank Upgrade:**    **Business License Endorsement Expiration:** 11/30/2025

**Tank Status Date:** 11/13/2020    **Piping Installation:** 10/20/2020    **Tank Permanently Closed Date:**

Tank Information		Piping Information	
<b>Material:</b>	Fiberglass Reinforced Plastic	<b>Material:</b>	Flexible Piping
<b>Construction:</b>	Double Wall Tank	<b>Construction:</b>	Double Wall Pipe
<b>Corrosion Protection:</b>	Sacrificial Anode and Interior Lining	<b>Corrosion Protection:</b>	Corrosion Resistant
<b>Manifolded Tank:</b>	Non-Manifolded Tank	<b>SFC* at Tank:</b>	Single Wall Sump
<b>Release Detection:</b>	Interstitial Monitoring	<b>SFC* at Dispenser/Pump:</b>	Single Wall Sump
<b>Tank Manufacturer:</b>		<b>Primary Release Detection:</b>	Interstitial Monitoring (or Sump Sensor)
<b>Spill Prevention:</b>	Double Wall Dry Spill Bucket	<b>Secondary Release Detection:</b>	Automatic Line Leak Detector (ALLD)
<b>Overfill Prevention:</b>	Automatic Shutoff (fill pipe)	<b>Pumping System:</b>	Pressurized System
<b>Actual Capacity:</b>	20,000 Gallons	<b>Piping Manufacturer:</b>	
<b>Capacity Range:</b>	20,000 to 29,999 Gallons	*SFC = Steel Flex Connector	
<b>Compartment</b>	<b>Substance Stored</b>	<b>Substance Used</b>	<b>Capacity</b>
1	Unleaded Gasoline	Motor Fuel for Vehicles	20,000 Gallons

## Underground Storage Tank System Summary

UST ID: 8801

<b>Tank Name:</b>	2A PUL/2B DIESEL		<b>Tank Status:</b>	Operational
<b>Tank Installation:</b>	9/24/2020	<b>Tank Upgrade:</b>	<b>Business License Endorsement Expiration:</b>	11/30/2025
<b>Tank Status Date:</b>	11/23/2020	<b>Piping Installation:</b>	10/20/2020	
<b>Tank Information</b>			<b>Piping Information</b>	
<b>Material:</b>	Fiberglass Reinforced Plastic		<b>Material:</b>	Fiberglass
<b>Construction:</b>	Double Wall Tank		<b>Construction:</b>	Double Wall Pipe
<b>Corrosion Protection:</b>	Impressed Current		<b>Corrosion Protection:</b>	Corrosion Resistant
<b>Manifolded Tank:</b>	Non-Manifolded Tank		<b>SFC* at Tank:</b>	Single Wall Sump
<b>Release Detection:</b>	Interstitial Monitoring		<b>SFC* at Dispenser/Pump:</b>	Single Wall Sump
<b>Tank Manufacturer:</b>			<b>Primary Release Detection:</b>	Interstitial Monitoring (or Sump Sensor)
<b>Spill Prevention:</b>	Double Wall Dry Spill Bucket		<b>Secondary Release Detection:</b>	Automatic Line Leak Detector (ALLD)
<b>Overfill Prevention:</b>	Automatic Shutoff (fill pipe)		<b>Pumping System:</b>	Pressurized System
<b>Actual Capacity:</b>	20,000 Gallons		<b>Piping Manufacturer:</b>	
<b>Capacity Range:</b>	20,000 to 29,999 Gallons		*SFC = Steel Flex Connector	
<b>Compartment</b>	<b>Substance Stored</b>	<b>Substance Used</b>	<b>Capacity</b>	
1	Unleaded Gasoline	Motor Fuel for Vehicles	8,000 Gallons	
2	Diesel	Motor Fuel for Vehicles	12,000 Gallons	

<b>Tank Name:</b>	UNLEAD 3		<b>Tank Status:</b>	Removed
<b>Tank Installation:</b>	7/1/1989	<b>Tank Upgrade:</b>	3/2/1998	<b>Business License Endorsement Expiration:</b> 7/31/2019
<b>Tank Status Date:</b>	3/25/2019	<b>Piping Installation:</b>		
<b>Tank Information</b>			<b>Piping Information</b>	
<b>Material:</b>	Fiberglass Reinforced Plastic		<b>Material:</b>	Fiberglass
<b>Construction:</b>	Double Wall Tank		<b>Construction:</b>	Double Wall Pipe
<b>Corrosion Protection:</b>	Corrosion Resistant		<b>Corrosion Protection:</b>	Corrosion Resistant
<b>Manifolded Tank:</b>	Auxiliary		<b>SFC* at Tank:</b>	Single Wall Sump
<b>Release Detection:</b>	Interstitial Monitoring		<b>SFC* at Dispenser/Pump:</b>	Single Wall Sump
<b>Tank Manufacturer:</b>			<b>Primary Release Detection:</b>	Interstitial Monitoring (or Sump Sensor)
<b>Spill Prevention:</b>	Single Wall Spill Bucket		<b>Secondary Release Detection:</b>	
<b>Overfill Prevention:</b>	Automatic Shutoff (fill pipe)		<b>Pumping System:</b>	Siphon
<b>Actual Capacity:</b>	10,000 Gallons		<b>Piping Manufacturer:</b>	
<b>Capacity Range:</b>	10,000 to 19,999 Gallons		*SFC = Steel Flex Connector	
<b>Compartment</b>	<b>Substance Stored</b>	<b>Substance Used</b>	<b>Capacity</b>	
1	Unleaded Gasoline	Motor Fuel for Vehicles	10,000 Gallons	

## Underground Storage Tank System Summary

UST ID: 8801

<b>Tank Name:</b>	UNLEAD 2		<b>Tank Status:</b>	Removed
<b>Tank Installation:</b>	7/1/1989	<b>Tank Upgrade:</b>	3/2/1998	<b>Business License Endorsement Expiration:</b> 7/31/2019
<b>Tank Status Date:</b>	3/25/2019	<b>Piping Installation:</b>	<b>Tank Permanently Closed Date:</b>	
<b>Tank Information</b>			<b>Piping Information</b>	
<b>Material:</b>	Fiberglass Reinforced Plastic		<b>Material:</b>	Fiberglass
<b>Construction:</b>	Double Wall Tank		<b>Construction:</b>	Double Wall Pipe
<b>Corrosion Protection:</b>	Corrosion Resistant		<b>Corrosion Protection:</b>	Corrosion Resistant
<b>Manifolded Tank:</b>			<b>SFC* at Tank:</b>	Single Wall Sump
<b>Release Detection:</b>	Interstitial Monitoring		<b>SFC* at Dispenser/Pump:</b>	Single Wall Sump
<b>Tank Manufacturer:</b>			<b>Primary Release Detection:</b>	Automatic Line Leak Detector (ALLD)
<b>Spill Prevention:</b>	Single Wall Spill Bucket		<b>Secondary Release Detection:</b>	Interstitial Monitoring (or Sump Sensor)
<b>Overfill Prevention:</b>	Automatic Shutoff (fill pipe)		<b>Pumping System:</b>	Pressurized System
<b>Actual Capacity:</b>	10,000 Gallons		<b>Piping Manufacturer:</b>	
<b>Capacity Range:</b>	10,000 to 19,999 Gallons		*SFC = Steel Flex Connector	
<b>Compartment</b>	<b>Substance Stored</b>	<b>Substance Used</b>	<b>Capacity</b>	
1	Unleaded Gasoline	Motor Fuel for Vehicles	10,000 Gallons	

<b>Tank Name:</b>	REGULAR 1		<b>Tank Status:</b>	Removed
<b>Tank Installation:</b>	7/1/1989	<b>Tank Upgrade:</b>	3/2/1998	<b>Business License Endorsement Expiration:</b> 7/31/2019
<b>Tank Status Date:</b>	3/25/2019	<b>Piping Installation:</b>	<b>Tank Permanently Closed Date:</b>	
<b>Tank Information</b>			<b>Piping Information</b>	
<b>Material:</b>	Fiberglass Reinforced Plastic		<b>Material:</b>	Fiberglass
<b>Construction:</b>	Double Wall Tank		<b>Construction:</b>	Double Wall Pipe
<b>Corrosion Protection:</b>	Corrosion Resistant		<b>Corrosion Protection:</b>	Corrosion Resistant
<b>Manifolded Tank:</b>			<b>SFC* at Tank:</b>	Single Wall Sump
<b>Release Detection:</b>	Interstitial Monitoring		<b>SFC* at Dispenser/Pump:</b>	Single Wall Sump
<b>Tank Manufacturer:</b>			<b>Primary Release Detection:</b>	Automatic Line Leak Detector (ALLD)
<b>Spill Prevention:</b>	Single Wall Spill Bucket		<b>Secondary Release Detection:</b>	Interstitial Monitoring (or Sump Sensor)
<b>Overfill Prevention:</b>	Automatic Shutoff (fill pipe)		<b>Pumping System:</b>	Pressurized System
<b>Actual Capacity:</b>	10,000 Gallons		<b>Piping Manufacturer:</b>	
<b>Capacity Range:</b>	10,000 to 19,999 Gallons		*SFC = Steel Flex Connector	
<b>Compartment</b>	<b>Substance Stored</b>	<b>Substance Used</b>	<b>Capacity</b>	
1	Unleaded Gasoline	Motor Fuel for Vehicles	10,000 Gallons	

## Underground Storage Tank System Summary

UST ID: 8801

<b>Tank Name:</b> SUPER 4		<b>Tank Status:</b> Removed	
<b>Tank Installation:</b> 7/1/1989	<b>Tank Upgrade:</b> 3/2/1998	<b>Business License Endorsement Expiration:</b> 7/31/2019	
<b>Tank Status Date:</b> 3/25/2019	<b>Piping Installation:</b>	<b>Tank Permanently Closed Date:</b>	
Tank Information		Piping Information	
<b>Material:</b> Fiberglass Reinforced Plastic	<b>Material:</b> Fiberglass		
<b>Construction:</b> Double Wall Tank	<b>Construction:</b> Double Wall Pipe		
<b>Corrosion Protection:</b> Corrosion Resistant	<b>Corrosion Protection:</b> Corrosion Resistant		
<b>Manifolded Tank:</b>	<b>SFC* at Tank:</b> Single Wall Sump		
<b>Release Detection:</b> Interstitial Monitoring	<b>SFC* at Dispenser/Pump:</b> Single Wall Sump		
<b>Tank Manufacturer:</b>	<b>Primary Release Detection:</b> Automatic Line Leak Detector (ALLD)		
<b>Spill Prevention:</b> Single Wall Spill Bucket	<b>Secondary Release Detection:</b> Interstitial Monitoring (or Sump Sensor)		
<b>Overfill Prevention:</b> Automatic Shutoff (fill pipe)	<b>Pumping System:</b> Pressurized System		
<b>Actual Capacity:</b> 10,000 Gallons	<b>Piping Manufacturer:</b>		
<b>Capacity Range:</b> 10,000 to 19,999 Gallons	*SFC = Steel Flex Connector		
Compartment	Substance Stored	Substance Used	Capacity
1	Unleaded Gasoline	Motor Fuel for Vehicles	10,000 Gallons

<b>Tank Name:</b> 1		<b>Tank Status:</b> Removed	
<b>Tank Installation:</b> 12/31/1964	<b>Tank Upgrade:</b>	<b>Business License Endorsement Expiration:</b>	
<b>Tank Status Date:</b> 8/6/1996	<b>Piping Installation:</b>	<b>Tank Permanently Closed Date:</b>	
Tank Information		Piping Information	
<b>Material:</b> Steel	<b>Material:</b>		
<b>Construction:</b>	<b>Construction:</b>		
<b>Corrosion Protection:</b>	<b>Corrosion Protection:</b>		
<b>Manifolded Tank:</b>	<b>SFC* at Tank:</b>		
<b>Release Detection:</b>	<b>SFC* at Dispenser/Pump:</b>		
<b>Tank Manufacturer:</b>	<b>Primary Release Detection:</b>		
<b>Spill Prevention:</b>	<b>Secondary Release Detection:</b>		
<b>Overfill Prevention:</b>	<b>Pumping System:</b>		
<b>Actual Capacity:</b>	<b>Piping Manufacturer:</b>		
<b>Capacity Range:</b>	*SFC = Steel Flex Connector		
Compartment	Substance Stored	Substance Used	Capacity
1	Leaded Gasoline		

## Underground Storage Tank System Summary

UST ID: 8801

<b>Tank Name:</b> 3		<b>Tank Status:</b> Removed	
<b>Tank Installation:</b> 12/31/1964	<b>Tank Upgrade:</b>	<b>Business License Endorsement Expiration:</b>	
<b>Tank Status Date:</b> 8/6/1996	<b>Piping Installation:</b>	<b>Tank Permanently Closed Date:</b>	
Tank Information		Piping Information	
<b>Material:</b> Steel	<b>Material:</b>		
<b>Construction:</b>	<b>Construction:</b>		
<b>Corrosion Protection:</b>	<b>Corrosion Protection:</b>		
<b>Manifolded Tank:</b>	<b>SFC* at Tank:</b>		
<b>Release Detection:</b>	<b>SFC* at Dispenser/Pump:</b>		
<b>Tank Manufacturer:</b>	<b>Primary Release Detection:</b>		
<b>Spill Prevention:</b>	<b>Secondary Release Detection:</b>		
<b>Overfill Prevention:</b>	<b>Pumping System:</b>		
<b>Actual Capacity:</b>	<b>Piping Manufacturer:</b>		
<b>Capacity Range:</b>	*SFC = Steel Flex Connector		
<b>Compartment</b>	<b>Substance Stored</b>	<b>Substance Used</b>	<b>Capacity</b>
1	Unleaded Gasoline		

<b>Tank Name:</b> 2		<b>Tank Status:</b> Removed	
<b>Tank Installation:</b> 12/31/1964	<b>Tank Upgrade:</b>	<b>Business License Endorsement Expiration:</b>	
<b>Tank Status Date:</b> 8/6/1996	<b>Piping Installation:</b>	<b>Tank Permanently Closed Date:</b>	
Tank Information		Piping Information	
<b>Material:</b> Steel	<b>Material:</b>		
<b>Construction:</b>	<b>Construction:</b>		
<b>Corrosion Protection:</b>	<b>Corrosion Protection:</b>		
<b>Manifolded Tank:</b>	<b>SFC* at Tank:</b>		
<b>Release Detection:</b>	<b>SFC* at Dispenser/Pump:</b>		
<b>Tank Manufacturer:</b>	<b>Primary Release Detection:</b>		
<b>Spill Prevention:</b>	<b>Secondary Release Detection:</b>		
<b>Overfill Prevention:</b>	<b>Pumping System:</b>		
<b>Actual Capacity:</b>	<b>Piping Manufacturer:</b>		
<b>Capacity Range:</b>	*SFC = Steel Flex Connector		
<b>Compartment</b>	<b>Substance Stored</b>	<b>Substance Used</b>	<b>Capacity</b>
1	Unleaded Gasoline		

## Underground Storage Tank System Summary

UST ID: 8801

<b>Tank Name:</b> 4		<b>Tank Status:</b> Removed	
<b>Tank Installation:</b> 12/31/1964		<b>Tank Upgrade:</b>	
<b>Tank Status Date:</b> 8/6/1996		<b>Business License Endorsement Expiration:</b>	
<b>Piping Installation:</b>		<b>Tank Permanently Closed Date:</b>	
<b>Tank Information</b>		<b>Piping Information</b>	
<b>Material:</b> Steel		<b>Material:</b>	
<b>Construction:</b>		<b>Construction:</b>	
<b>Corrosion Protection:</b>		<b>Corrosion Protection:</b>	
<b>Manifolded Tank:</b>		<b>SFC* at Tank:</b>	
<b>Release Detection:</b>		<b>SFC* at Dispenser/Pump:</b>	
<b>Tank Manufacturer:</b>		<b>Primary Release Detection:</b>	
<b>Spill Prevention:</b>		<b>Secondary Release Detection:</b>	
<b>Overfill Prevention:</b>		<b>Pumping System:</b>	
<b>Actual Capacity:</b>		<b>Piping Manufacturer:</b>	
<b>Capacity Range:</b>		*SFC = Steel Flex Connector	
<b>Compartment</b>	<b>Substance Stored</b>	<b>Substance Used</b>	<b>Capacity</b>
1			