

**Addendum to the Permit for
State Waste Discharge Permit No. ST0501319
*Terramar Brewery***

Modification Effective Date: November 2, 2021

1. General Information

Facility: Terramar Brewery
5712 Gilkey Street
Edison, WA 98232

This is an addendum to the permit and fact sheet for the State Waste Discharge Permit No. ST0501319, issued on December 2, 2019. The following change is made to revise the permit limit for flow.

2. Modification to the Permit

The current permit limits for flow are an average monthly volume of 467 gallons per day (gpd) and a maximum daily volume of 1,325 gpd. These values were miss-transcribed from information in the fact sheet.

This modification is to correct this technical mistake and change the flow limits to an average monthly volume of 1,325 gpd and a daily maximum volume of 1,421 gpd.

3. Justification

The current permit limits for flow were miss-transcribed during the permit development process. A narrative description in Section II Background Information in the fact sheet to the permit outlined a projected wastewater flow of 467 gpd in year one and increasing to an average of 1,325 gpd by year five.

The correct permit limits are an average monthly of 1,325 gpd and a daily maximum volume of 1,421 gpd. The average monthly flow limit is based on the projected average wastewater flow at build-out (year 5). The maximum daily flow is based on the design criteria of the spray fields.

4. Public Process

The proposed change in this modification is a minor modification. The permit changes do not involve changes in characteristics of discharge beyond those previously authorized that would require a public notice (WAC 173-216-090). Therefore, the permit changes are not required to be published for a 30-day public comment period.

The primary author of this permit and fact sheet is Chris Martin, LHG.

Appendix A --Your Right to Appeal

You have a right to appeal this permit to the Pollution Control Hearing Board (PCHB) within 30 days of the date of receipt of the final permit. The appeal process is governed by chapter 43.21B RCW and chapter 371-08 WAC. "Date of receipt" is defined in RCW 43.21B.001(2).

To appeal you must do the following within 30 days of the date of receipt of this permit:

- File your appeal and a copy of this permit with the PCHB (see addresses below). Filing means actual receipt by the PCHB during regular business hours.
- Serve a copy of your appeal and this permit on Ecology in paper form - by mail or in person. (See addresses below.) E-mail is not accepted.

You must also comply with other applicable requirements in chapter 43.21B RCW and chapter 371-08 WAC.

ADDRESS AND LOCATION INFORMATION

Street Addresses	Mailing Addresses
Department of Ecology Attn: Appeals Processing Desk 300 Desmond Drive SE Lacey, WA 98503	Department of Ecology Attn: Appeals Processing Desk PO Box 47608 Olympia, WA 98504-7608
Pollution Control Hearings Board 1111 Israel RD SW STE 301 Tumwater, WA 98501	Pollution Control Hearings Board PO Box 40903 Olympia, WA 98504-0903