



Issue Date: November 9, 2021
Effective Date: January 1, 2022
Expiration Date: December 31, 2026

STATE WASTE DISCHARGE PERMIT NUMBER ST 6049

State of Washington
DEPARTMENT OF ECOLOGY
Southwest Regional Office
PO Box 47775
Olympia, Washington 98504-7775

In compliance with the provisions of the
State of Washington Water Pollution Control Law
Chapter 90.48 Revised Code of Washington, as amended,

Rainbow Valley Landfill, Inc.
114 Airport Road
Raymond, WA 98577

is authorized to discharge wastewater in accordance with the special and general conditions which follow.

Facility Location: Hwy 105 (5 miles west of Raymond) Raymond, WA 98577 Industry Type: Solid Waste Landfill POTW Receiving Discharge: Willapa Regional Wastewater Treatment Plant	SIC Code: 4953 Refuse Systems NAICS Code: 562212 Solid Waste Landfill Categorical Industry
---	--



Andrew Kolosseus
Southwest Region Section Manager
Southwest Regional Office
Washington State Department of Ecology

TABLE OF CONTENTS

SUMMARY OF PERMIT REPORT SUBMITTALS.....4

SPECIAL CONDITIONS.....5

S1. DISCHARGE LIMITS..... 5

S2. MONITORING REQUIREMENTS..... 5

 A. Monitoring Requirements 5

 B. Sampling and Analytical Procedures..... 7

 C. Flow Measurement and Continuous Monitoring Devices 7

 D. Laboratory Accreditation 7

S3. REPORTING AND RECORDING REQUIREMENTS..... 8

 A. Discharge Monitoring Reports..... 8

 B. Permit Submittals and Schedules 9

 C. Records Retention 10

 D. Recording of Results 10

 E. Additional Monitoring by the Permittee 10

 F. Reporting Permit Violations..... 10

 G. Other Reporting 12

 H. Maintaining a Copy of this Permit 13

 I. Dangerous Waste Discharge Notification 13

 J. Spill Notification..... 13

 K. Changes in Contract..... 13

S4. OPERATION AND MAINTENANCE 13

 A. Operations and Maintenance (O&M) Manual..... 14

 B. Bypass Procedures 14

S5. PROHIBITED DISCHARGES 17

 A. General Prohibitions 17

 B. Specific Prohibitions..... 17

 C. Prohibited Unless Approved 17

S6. DILUTION PROHIBITED..... 18

S7. SOLID WASTE DISPOSAL..... 18

 A. Solid Waste Handling 18

 B. Leachate..... 18

S8. APPLICATION FOR PERMIT RENEWAL OR MODIFICATION FOR FACILITY CHANGES 18

GENERAL CONDITIONS.....19

G1. SIGNATORY REQUIREMENTS 19

G2. RIGHT OF ENTRY 19

G3. PERMIT ACTIONS..... 20

G4. REPORTING A CAUSE FOR MODIFICATION 20

G5. PLAN REVIEW REQUIRED 20

G6. COMPLIANCE WITH OTHER LAWS AND STATUTES..... 20

G7.	TRANSFER OF THIS PERMIT.....	20
G8.	REDUCED PRODUCTION FOR COMPLIANCE	21
G9.	REMOVED SUBSTANCES.....	21
G10.	PAYMENT OF FEES	21
G11.	PENALTIES FOR VIOLATING PERMIT CONDITIONS.....	21
G12.	DUTY TO PROVIDE INFORMATION.....	21
G13.	DUTY TO COMPLY	21
APPENDIX A.....		23
List of Pollutants with Analytical Methods, Detection Limits and Quantitation Levels		23
	Table 1: Conventional Pollutants	24
	Table 2: Nonconventional Pollutants.....	24
Priority Pollutants		27
	Table 3: Metals, Cyanide & Total Phenols	27
	Table 4: Acid Compounds	29
	Table 5: Volatile Compounds.....	29
	Table 6: Base/Neutral Compounds (Compounds in Bold are Ecology PBTS).....	31
	Table 7: Dioxin	34
	Table 8: Pesticides/PCBS.....	34
Analytical Methods		37

SUMMARY OF PERMIT REPORT SUBMITTALS

Refer to the Special and General Conditions of this permit for additional submittal requirements.

Permit Section	Submittal	Frequency	First Submittal Date
S3.A	Discharge Monitoring Report (DMR)	Quarterly	April 15, 2022
S3.A	DMR - Priority Pollutant Data - Single Sample Data	1/permit cycle	June 1, 2025
S3.F	Reporting Permit Violations	As necessary	
S4.A.	Operation and Maintenance Manual	1/permit cycle	April 1, 2022
S4.A.	O&M Manual Update or Review Confirmation Letter	Annually	January 1, 2023
S4.B	Reporting Bypasses	As necessary	
S8.	Application for Permit Renewal	1/permit cycle	June 1, 2025
G1.	Notice of Change in Authorization	As necessary	
G4.	Permit Application for Substantive Changes to the Discharge	As necessary	
G5.	Engineering Report for Construction or Modification Activities	As necessary	
G7.	Notice of Permit Transfer	As necessary	
G10.	Duty to Provide Information	As necessary	

SPECIAL CONDITIONS

S1. DISCHARGE LIMITS

All discharges and activities authorized by this permit must comply with the terms and conditions of this permit. The discharge of any of the following pollutants more frequently than, or at a concentration in excess of, that authorized by this permit violates the terms and conditions of this permit.

Beginning on the effective date, the Permittee is authorized to discharge wastewater to the Willapa Regional Wastewater Treatment Plant subject to the following limits:

Effluent Limits: 001		
Latitude: 46.71009 Longitude: -123.82508		
Parameter	Average Quarterly ^a	Maximum Daily ^b
Flow	40,000 GPD	50,000 GPD
Biochemical Oxygen Demand (BOD ₅)	n/a	300 mg/L
Temperature	n/a	150 °F
Oil and Grease	n/a	100 mg/L
Parameter	Minimum	Maximum
pH	5.5 Standard Units	8.5 Standard Units
^a	The average quarterly effluent limitation is defined as the highest allowable average of daily discharges over a quarter (January-March, April-June, July-September, and October-December), calculated as the sum of all daily discharges measured during a calendar quarter divided by the number of daily discharges measured during that quarter.	
^b	Maximum daily effluent limit means the highest allowable daily discharge. The daily discharge means the maximum discharge of a pollutant measured during a calendar day. For pollutants with limits expressed in units of mass, calculate the daily discharge as the total mass of the pollutant discharged over the day. For other units of measurement, the daily discharge is the average measurement of the pollutant over the day. This does not apply to pH.	

S2. MONITORING REQUIREMENTS

A. Monitoring Requirements

The Permittee must monitor in accordance with the following schedule and the requirements specified in Appendix A.

Parameter	Units	Sampling Frequency	Sample Type
(1) Final Wastewater Effluent			
Flow	GPD	Once per defined event ^a	Measured per Truck Load
BOD ₅	mg/L	Quarterly ^b	Grab ^c
Total Suspended Solids (TSS)	mg/L	Quarterly ^b	Grab ^c
pH ^d	Standard Units	Quarterly ^b	Grab ^c
Oil and Grease	mg/L	Quarterly ^b	Grab ^c
Temperature	°F	Quarterly ^b	Grab ^c
Ammonia	mg/L	Quarterly ^b	Grab ^c
Parameter	Units	Sampling Frequency	Sample Type
(2) Permit Renewal Application Requirements – Final Wastewater Effluent			
Priority Pollutants (PP) – Total Metals	µg/L; ng/L for Mercury	1 per permit cycle ^e	Grab ^c
PP – Volatile Organic Compounds	µg/L	1 per permit cycle ^e	Grab ^c
PP – Acid-extractable Compounds	µg/L	1 per permit cycle ^e	Grab ^c
PP – Base-neutral Compounds	µg/L	1 per permit cycle ^e	Grab ^c
PP - Dioxin	pg/L	1 per permit cycle ^e	Grab ^c
PP – Pesticides/PCBs	µg/L	1 per permit cycle ^e	Grab ^c
^a	Once per defined event means the total flow value must be reported for each truck load of leachate leaving the facility		
^b	Quarterly sampling periods are January through March, April through June, July through September, and October through December. The Permittee must report the quarterly DMRs by the 15 th of January, April, July, and October, beginning April 15, 2022 .		
^c	Grab means an individual sample collected over a 15-minute, or less, period.		
^d	The Permittee must report the instantaneous maximum and minimum pH monthly. Do not average pH values.		
^e	The priority pollutant scans must be submitted with the application for permit renewal which is due 18 months before the permit expiration date.		

B. Sampling and Analytical Procedures

Samples and measurements taken to meet the requirements of this permit must represent the volume and nature of the monitored parameters, including representative sampling of any unusual discharge or discharge condition, including bypasses, upsets, and maintenance-related conditions affecting effluent quality.

Sampling and analytical methods used to meet the water and wastewater monitoring requirements specified in this permit must conform to the latest revision of the following rules and documents unless otherwise specified in this permit or approved in writing by the Department of Ecology (Ecology).

- Guidelines Establishing Test Procedures for the Analysis of Pollutants contained in 40 Code of Federal Regulations (CFR) Part 136
- Standard Methods for the Examination of Water and Wastewater (APHA)

C. Flow Measurement and Continuous Monitoring Devices

The Permittee must:

1. Select and use appropriate flow measurement, field measurement, and continuous monitoring devices and methods consistent with accepted scientific practices.
2. Install, calibrate, and maintain these devices to ensure the accuracy of the measurements is consistent with the accepted industry standard, the manufacturer's recommendation, and approved Operation and Maintenance (O&M) Manual procedures for the device and the wastestream.
3. Calibrate continuous monitoring instruments weekly unless it can demonstrate a longer period is sufficient based on monitoring records. The Permittee:
 - a. May calibrate apparatus for continuous monitoring of Dissolved Oxygen by air calibration.
 - b. Must calibrate continuous pH measurement instruments using a grab sample analyzed in the lab with a pH meter calibrated with standard buffers and analyzed within 15 minutes of sampling.
 - c. Must calibrate continuous Chlorine measurement instruments using a grab sample analyzed in the laboratory within 15 minutes of sampling.
4. Maintain calibration records for at least three years.

D. Laboratory Accreditation

The Permittee must ensure that all monitoring data required by Ecology for permit specified parameters is prepared by a laboratory registered or accredited under the

provisions of chapter 173-50 Washington Administrative Code (WAC), 'Accreditation of Environmental Laboratories'. Flow, temperature, settleable solids, conductivity, pH, and internal process control parameters are exempt from this requirement.

S3. REPORTING AND RECORDING REQUIREMENTS

The Permittee must monitor and report in accordance with the following conditions. Falsification of information submitted to Ecology is a violation of the terms and conditions of this permit.

A. Discharge Monitoring Reports

The first monitoring period begins on the effective date of the permit (unless otherwise specified).

The Permittee must:

1. Summarize, report, and submit monitoring data obtained during each monitoring period on the electronic Discharge Monitoring Report (DMR) form provided by Ecology within the Water Quality Permitting Portal. Include data for each of the parameters tabulated in Special Condition S2 and as required by the form. Report a value for each day sampling occurred (unless specifically exempted in the permit) and for the summary values (when applicable) included on the electronic form.

To find out more information and to sign up for the [Water Quality Permitting Portal](https://ecology.wa.gov/Regulations-Permits/Guidance-technical-assistance/Water-quality-permits-guidance/WQWebPortal-guidance) go to <https://ecology.wa.gov/Regulations-Permits/Guidance-technical-assistance/Water-quality-permits-guidance/WQWebPortal-guidance>.

2. Enter the "No Discharge" reporting code for an entire DMR, for a specific monitoring point, or for a specific parameter as appropriate, if the Permittee did not discharge wastewater or a specific pollutant during a given monitoring period.
3. Report single analytical values below detection as "less than the Detection Level (DL)" by entering < followed by the numeric value of the detection level (e.g. < 2.0) on the DMR. If the method used did not meet the minimum DL and Quantitation Level (QL) identified in the permit, report the actual QL and DL in the comments or in the location provided.
4. Report the test method used for analysis in the comments if the laboratory used an alternative method not specified in the permit and as allowed in Appendix A.
5. Calculate average values and calculated total values (unless otherwise specified in the permit) using:
 - a. The reported numeric value for all parameters measured between the agency-required detection value and the agency-required quantitation value.

- b. One-half the detection value (for values reported below detection) if the lab detected the parameter in another sample from the same monitoring point for the reporting period.
 - c. Zero (for values reported below detection) if the lab did not detect the parameter in another sample for the reporting period.
6. Report single-sample grouped parameters (for example: priority pollutants, PAHs, pulp and paper chlorophenolics, TTOs) on the WQWebDMR form and include: sample date, concentration detected, DL (as necessary), and laboratory QL (as necessary).

The Permittee must also submit an electronic copy of the laboratory report as an attachment using WQWebDMR. The contract laboratory reports must also include information on the chain of custody, QA/QC results, and documentation of accreditation for the parameter.

7. Ensure that DMRs are electronically submitted no later than the dates specified below, unless otherwise specified in this permit.
8. Submit DMRs for parameters with the monitoring frequencies specified in Special Condition S2 (monthly, quarterly, annual, etc.) at the reporting schedule identified below. The Permittee must:
- a. Submit **quarterly DMRs**, unless otherwise specified in the permit, by the 15th day of the month following the monitoring period. Quarterly sampling periods are January through March, April through June, July through September, and October through December.
 - b. Submit permit renewal application monitoring data in WQWebDMR as required in Special Condition S2 by **June 1, 2025**.

B. Permit Submittals and Schedules

The Permittee must use the Water Quality Permitting Portal – Permit Submittals application (unless otherwise specified in the permit) to submit all other written permit-required reports by the date specified in the permit.

When another permit condition requires submittal of a paper (hard-copy) report, the Permittee must ensure that it is postmarked or received by Ecology no later than the dates specified by this permit. Send these paper reports to Ecology at:

Water Quality Permit Coordinator
Department of Ecology
Southwest Regional Office
PO Box 47775
Olympia, WA 98504-7775

C. **Records Retention**

The Permittee must retain records of all monitoring information for a minimum of three years. Such information must include all calibration and maintenance records and all original recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit. The Permittee must extend this period of retention during the course of any unresolved litigation regarding the discharge of pollutants by the Permittee or when requested by Ecology.

D. **Recording of Results**

For each measurement or sample taken, the Permittee must record the following information:

1. The date, exact place, method, and time of sampling or measurement;
2. The individual who performed the sampling or measurement;
3. The dates the analyses were performed;
4. The individual who performed the analyses;
5. The analytical techniques or methods used; and
6. The results of all analyses.

E. **Additional Monitoring by the Permittee**

If the Permittee monitors any pollutant more frequently than required by Special Condition S2 of this permit, then the Permittee must include the results of such monitoring in the calculation and reporting of the data submitted in the Permittee's DMR unless otherwise specified by Condition S2.

F. **Reporting Permit Violations**

The Permittee must take the following actions when it violates or is unable to comply with any permit condition:

1. Immediately take action to stop, contain, and cleanup unauthorized discharges or otherwise stop the noncompliance and correct the problem.
2. If applicable, immediately repeat sampling and analysis. Submit the results of any repeat sampling to Ecology within 30 days of sampling.

a. **Immediate Reporting**

The Permittee must report any noncompliance that may endanger health or the environment immediately to the Department of Ecology's Regional Office 24-hour number listed below:

Southwest Regional Office (360) 407-6300

b. **Twenty-Four-Hour Reporting**

The Permittee must report the following occurrences of noncompliance by telephone, to Ecology at the telephone numbers listed above, within 24 hours from the time the Permittee becomes aware of any of the following circumstances.

The Permittee must report:

- i. Any noncompliance that may endanger health or the environment, unless previously reported under immediate reporting requirements.
- ii. Any unanticipated bypass that causes an exceedance of an effluent limit in the permit (see Special Condition S4.B., "Bypass Procedures").
- iii. Any upset that causes an exceedance of an effluent limit in the permit. Upset means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limits because of factors beyond the reasonable control of the Permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.
- iv. Any violation of a maximum daily or instantaneous maximum discharge limit for any of the pollutants in Special Condition S1 of this permit.
- v. Any overflow prior to the treatment works, whether or not such overflow endangers health or the environment or exceeds any effluent limit in the permit. This requirement does not include industrial process wastewater overflows to impermeable surfaces which are collected and routed to the treatment works.

c. Report Within Five Days

The Permittee must also submit a written report within five days of the time that the Permittee becomes aware of any reportable event under subparts a or b, above.

The report must contain:

- i. A description of the noncompliance and its cause.
- ii. The period of noncompliance, including exact dates and times.
- iii. The estimated time the Permittee expects the noncompliance to continue if not yet corrected.
- iv. Steps taken or planned to reduce, eliminate, and prevent recurrence of the noncompliance.
- v. If the noncompliance involves an overflow prior to the treatment works, an estimate of the quantity (in gallons) of untreated overflow.

d. Waiver of Written Reports

Ecology may waive the written report required in subpart c, above, on a case-by-case basis upon request if the Permittee has submitted a timely oral report.

e. All Other Permit Violation Reporting

The Permittee must report all permit violations, which do not require immediate or within 24 hours reporting, when it submits monitoring reports for S3.A ("Reporting"). The reports must contain the information listed in subpart c, above. Compliance with these requirements does not relieve the Permittee from responsibility to maintain continuous compliance with the terms and conditions of this permit or the resulting liability for failure to comply.

G. Other Reporting

1. Spills of Oil or Hazardous Materials

The Permittee must report a spill of oil or hazardous materials in accordance with the requirements of Revised Code of Washington (RCW) 90.56.280 and chapter 173-303-145. You can obtain further instructions at the [Report a spill of oil or hazardous materials website](https://ecology.wa.gov/About-us/Get-involved/Report-an-environmental-issue/Report-a-spill) at <https://ecology.wa.gov/About-us/Get-involved/Report-an-environmental-issue/Report-a-spill>.

2. Failure to Submit Relevant or Correct Facts

Where the Permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application, or in any report to Ecology, it must submit such facts or information promptly.

H. Maintaining a Copy of this Permit

The Permittee must keep a copy of this permit at the facility and make it available upon request to Ecology inspectors.

I. Dangerous Waste Discharge Notification

The Permittee must notify the Publicly Owned Treatment Works (POTW) and Ecology in writing of any discharge into the POTW of a substance, which, if otherwise disposed of, would be a hazardous waste under 40 CFR 261. The Permittee must also notify the POTW and Ecology in writing of the intent to discharge into the POTW any substance designated as a dangerous waste in accordance with the provisions of WAC 173-303-070.

It must make this notification at least 90 days prior to the date that it proposes to initiate the discharge. The Permittee must not discharge this substance until authorized by Ecology and the POTW. It must also comply with the notification requirements of Special Condition S8 and General Condition G4.

J. Spill Notification

The Permittee must notify the POTW immediately (as soon as discovered) of all discharges that could cause problems to the POTW, such as process spills and unauthorized discharges (including slug discharges).

K. Changes in Contract

The Permittee must notify the Ecology immediately of any changes in the user agreement or contract with the POTW.

S4. OPERATION AND MAINTENANCE

The Permittee must, at all times, properly operate and maintain all facilities or systems of treatment and control (and related appurtenances) which are installed to achieve compliance with the terms and conditions of this permit. Proper operation and maintenance includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems, which are installed by a Permittee only when the operation is necessary to achieve compliance with the conditions of this permit.

A. Operations and Maintenance (O&M) Manual

1. O&M Manual Submittal and Requirements

The Permittee must:

- a. Prepare an O&M Manual that meets the requirements of WAC 173-240-150 and submit it to Ecology for approval by **April 1, 2022**.
- b. Review the O&M Manual at least **annually** and confirm this review by letter to Ecology by **January 1** of each year.
- c. Submit to Ecology for review and approval substantial changes or updates to the O&M Manual.
- d. Keep the approved O&M Manual at the permitted facility.
- e. Follow the instructions and procedures of this manual.

2. O&M Manual Components

In addition to the requirements of WAC 173-240-150, the O&M Manual must include:

- a. Emergency procedures for cleanup in event of wastewater system upset, spill, failure, or demand by the Publicly Owned Treatment Works (POTW) treating the discharge.
- b. Wastewater sampling protocols and procedures for compliance with the sampling and reporting requirements in the wastewater discharge permit.
- c. Minimum staffing adequate to operate and maintain the treatment processes and carry out compliance monitoring required by the permit.
- d. Procedures taken to prevent leachate from entering the waters of the state

B. Bypass Procedures

This permit prohibits a bypass, which is the intentional diversion of waste streams from any portion of a treatment facility. Ecology may take enforcement action against a Permittee for a bypass unless one of the following circumstances (1, 2, or 3) applies.

1. Bypass for essential maintenance without the potential to cause violation of permit limits or conditions.

This permit authorizes a bypass if it allows for essential maintenance and does not have the potential to cause violations of limits or other conditions of this

permit, or adversely impact public health as determined by Ecology prior to the bypass. The Permittee must submit prior notice, if possible, at least ten days before the date of the bypass.

2. Bypass is unavoidable, unanticipated, and results in noncompliance of this permit.

This permit authorizes such a bypass only if:

- a. Bypass is unavoidable to prevent loss of life, personal injury, or severe property damage. "Severe property damage" means substantial physical damage to property, damage to the treatment facilities which would cause them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass.
- b. No feasible alternatives to the bypass exist, such as:
- The use of auxiliary treatment facilities
 - Retention of untreated wastes
 - Stopping production
 - Maintenance during normal periods of equipment downtime, but not if the Permittee should have installed adequate backup equipment in the exercise of reasonable engineering judgment to prevent a bypass.
 - Transport of untreated wastes to another treatment facility.
- c. The Permittee has properly notified Ecology of the bypass as required in Special Condition S3.E of this permit.

3. If bypass is anticipated and has the potential to result in noncompliance of this permit.

- a. The Permittee must notify Ecology at least 30 days before the planned date of bypass.

The notice must contain:

- A description of the bypass and its cause;
- An analysis of all known alternatives which would eliminate, reduce, or mitigate the need for bypassing;
- A cost-effectiveness analysis of alternatives including comparative resource damage assessment;

- The minimum and maximum duration of bypass under each alternative;
 - A recommendation as to the preferred alternative for conducting the bypass;
 - The projected date of bypass initiation;
 - A statement of compliance with State Environmental Policy Act (SEPA);
 - A request for modification of Water Quality Standards as provided for in WAC 173-201A-410, if an exceedance of any Water Quality Standard is anticipated; and
 - Details of the steps taken or planned to reduce, eliminate, and prevent reoccurrence of the bypass.
- b. For probable construction bypasses, the Permittee must notify Ecology of the need to bypass as early in the planning process as possible. The Permittee must consider the analysis required above during the project planning and design process. The project-specific Engineering Report or Facilities Plan as well as the plans and specifications must include details of probable construction bypasses to the extent practical. In cases where the Permittee determines the probable need to bypass early, the Permittee must continue to analyze conditions up to and including the construction period in an effort to minimize or eliminate the bypass.
- c. Ecology will consider the following prior to issuing an administrative order for this type of bypass:
- If the bypass is necessary to perform construction or maintenance-related activities essential to meet the requirements of this permit.
 - If feasible alternatives to bypass exist, such as the use of auxiliary treatment facilities, retention of untreated wastes, stopping production, maintenance during normal periods of equipment down time, or transport of untreated wastes to another treatment facility.
 - If the Permittee planned and scheduled the bypass to minimize adverse effects on the public and the environment.

After consideration of the above and the adverse effects of the proposed bypass and any other relevant factors, Ecology will approve or deny the request. Ecology will give the public an opportunity to comment on bypass incidents of significant duration, to the extent feasible. Ecology will approve a request to bypass by issuing an administrative order under RCW 90.48.120.

S5. PROHIBITED DISCHARGES

The Permittee must comply with these General and Specific Prohibitions.

A. General Prohibitions

The Permittee must not introduce into the POTW pollutant(s), which cause Pass-Through or Interference.

B. Specific Prohibitions

In addition, the Permittee must not introduce the following into the POTW:

1. Pollutants which create a fire or explosion hazard in the POTW, including, but not limited to, waste streams with a closed cup flashpoint of less than 60 degrees C (140 degrees F) using the test methods specified in 40 CFR 261.21;
2. Solid or viscous pollutants in amounts, which will cause obstruction to the flow in the POTW resulting in interference;
3. Any pollutant [including oxygen-demanding pollutants (BOD₅, etc.)], released in a discharge at a flow rate and/or pollutant concentration that will cause interference with the POTW;
4. Heat in amounts which will inhibit biological activity in the POTW resulting in interference, but in no case heat in such quantities that the temperature at the POTW treatment plant exceeds 40 degrees C (104 degrees F) unless the approval authority, upon request of the POTW, approves alternative Temperature limits;
5. Petroleum oil, non-biodegradable cutting oil, or products of mineral oil origin in amounts that will cause interference or pass-through;
6. Pollutants which result in the presence of toxic gases, vapors, or fumes within the POTW in a quantity that may cause acute worker health and safety problems;
7. Any trucked or hauled pollutants, except at discharge points designated by the POTW; and
8. Pollutants that will cause corrosive structural damage to the POTW.

C. Prohibited Unless Approved

Any of the following discharges are prohibited unless approved by Ecology under extraordinary circumstances (such as a lack of direct discharge alternatives due to combined sewer service or a need to augment sewage flows due to septic conditions):

1. Noncontact cooling water in significant volumes
2. Stormwater and other direct inflow sources

3. Wastewaters significantly affecting system hydraulic loading, which do not require treatment or would not be afforded a significant degree of treatment by the system
4. The discharge of dangerous wastes as defined in Chapter 173-303 WAC (Unless specifically authorized in this permit)

S6. DILUTION PROHIBITED

The Permittee must not dilute the wastewater discharge with stormwater or increase the use of potable water, process water, noncontact cooling water, or, in any way, attempt to dilute an effluent as a partial or complete substitute for adequate treatment to achieve compliance with the limits contained in this permit.

S7. SOLID WASTE DISPOSAL

A. Solid Waste Handling

The Permittee must handle and dispose of all solid waste material in such a manner as to prevent its entry into state ground or surface water.

B. Leachate

The Permittee must not allow leachate from its solid waste material to enter state waters without providing all known, available, and reasonable methods of treatment, nor allow such leachate to cause violations of the State Surface Water Quality Standards, Chapter 173-201A WAC, or the State Ground Water Quality Standards, Chapter 173-200 WAC. The Permittee must apply for a permit or permit modification as may be required for such discharges to state ground or surface waters

S8. APPLICATION FOR PERMIT RENEWAL OR MODIFICATION FOR FACILITY CHANGES

The Permittee must submit an application for renewal of this permit by **June 1, 2025**.

The Permittee must also submit a new application or addendum at least 180 days prior to commencement of discharges, resulting from the activities listed below, which may result in permit violations. These activities include any facility expansions, production increases, or other planned changes, such as process modifications, in the permitted facility.

GENERAL CONDITIONS

G1. SIGNATORY REQUIREMENTS

All applications, reports, or information submitted to Ecology must be signed as follows:

- A. All permit applications must be signed by either a principal executive officer or ranking elected official.
- B. All reports required by this permit and other information requested by Ecology must be signed by a person described above or by a duly authorized representative of that person. A person is a duly authorized representative only if:
 - 1. The authorization is made in writing by the person described above and is submitted to Ecology at the time of authorization, and
 - 2. The authorization specifies either a named individual or any individual occupying a named position.
- C. Changes to authorization. If an authorization under paragraph G1.B. above is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization must be submitted to Ecology prior to or together with any reports, information, or applications to be signed by an authorized representative.
- D. Certification. Any person signing a document under this section must make the following certification:

"I certify under penalty of law, that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gathered and evaluated the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

G2. RIGHT OF ENTRY

Representatives of Ecology have the right to enter at all reasonable times in or upon any property, public or private, for the purpose of inspecting and investigating conditions relating to the pollution or the possible pollution of any waters of the state. Reasonable times include normal business hours; hours during which production, treatment, or discharge occurs; or times when Ecology suspects a violation requiring immediate inspection. Representatives of Ecology must be allowed to have access to, and copy at reasonable cost, any records required to be kept under terms and conditions of the permit; to inspect any monitoring equipment or method required in the permit; and to sample the discharge, waste treatment processes, or internal waste streams.

G3. PERMIT ACTIONS

This permit is subject to modification, suspension, or termination, in whole or in part by Ecology for any of the following causes:

- A. Violation of any permit term or condition;
- B. Obtaining a permit by misrepresentation or failure to disclose all relevant facts;
- C. A material change in quantity or type of waste disposal;
- D. A material change in the condition of the waters of the state; or
- E. Nonpayment of fees assessed pursuant to RCW 90.48.465.

Ecology may also modify this permit, including the schedule of compliance or other conditions, if it determines good and valid cause exists, including promulgation or revisions of regulations or new information.

G4. REPORTING A CAUSE FOR MODIFICATION

The Permittee must submit a new application, or a supplement to the previous application, along with required Engineering Plans and reports, whenever a new or increased discharge or change in the nature of the discharge is anticipated which is not specifically authorized by this permit. This application must be submitted at least 180 days prior to any proposed changes. Submission of this application does not relieve the Permittee of the duty to comply with the existing permit until it is modified or reissued.

G5. PLAN REVIEW REQUIRED

Prior to constructing or modifying any wastewater control facilities, an Engineering Report and detailed Plans and Specifications must be submitted to Ecology for approval in accordance with Chapter 173-240 WAC. Engineering Reports, Plans, and Specifications should be submitted at least 180 days prior to the planned start of construction. Facilities must be constructed and operated in accordance with the approved Plans.

G6. COMPLIANCE WITH OTHER LAWS AND STATUTES

Nothing in the permit excuses the Permittee from compliance with any applicable federal, state, or local statutes, ordinances, or regulations.

G7. TRANSFER OF THIS PERMIT

This permit is automatically transferred to a new owner or operator if:

- A. A written agreement between the old and new owner or operator containing a specific date for transfer of permit responsibility, coverage, and liability is submitted to Ecology;
- B. A copy of the permit is provided to the new owner; and

C. Ecology does not notify the Permittee of the need to modify the permit.

Unless this permit is automatically transferred according to Section A above, this permit may be transferred only if it is modified to identify the new Permittee and to incorporate such other requirements as determined necessary by Ecology.

G8. REDUCED PRODUCTION FOR COMPLIANCE

The Permittee must control production or discharge to the extent necessary to maintain compliance with the terms and conditions of this permit upon reduction of efficiency, loss, or failure of its treatment facility until the treatment capacity is restored or an alternative method of treatment is provided. This requirement applies in the situation where, among other things, the primary source of power for the treatment facility is reduced, lost, or fails.

G9. REMOVED SUBSTANCES

Collected screenings, grit, solids, sludges, filter backwash, or other pollutants removed in the course of treatment or control of wastewaters must not be resuspended or reintroduced to the effluent stream for discharge.

G10. PAYMENT OF FEES

The Permittee must submit payment of fees associated with this permit as assessed by Ecology. Ecology may revoke this permit if the permit fees established under Chapter 173-224 WAC are not paid.

G11. PENALTIES FOR VIOLATING PERMIT CONDITIONS

Any person who is found guilty of willfully violating the terms and conditions of this permit is guilty of a crime, and upon conviction thereof shall be punished by a fine of up to \$10,000 and costs of prosecution, or by imprisonment in the discretion of the court. Each day upon which a willful violation occurs is a separate and additional violation.

Any person who violates the terms and conditions of a waste discharge permit incurs, in addition to any other penalty as provided by law, a civil penalty in the amount of up to \$10,000 for every such violation. Each and every such violation is a separate and distinct offense, and in case of a continuing violation, every day's continuance is a separate and distinct violation.

G12. DUTY TO PROVIDE INFORMATION

The Permittee must submit to Ecology, within a reasonable time, all information which Ecology may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit or to determine compliance with this permit. The Permittee must also submit to Ecology upon request, copies of records required to be kept by this permit.

G13. DUTY TO COMPLY

The Permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of chapter 90.48 RCW and is grounds for enforcement action; for permit

termination, revocation and reissuance, or modification; or denial of a permit renewal application.

APPENDIX A

List of Pollutants with Analytical Methods, Detection Limits and Quantitation Levels

The Permittee must use the specified analytical methods, Detection Limits (DLs) and Quantitation Levels (QLs) in the following table for permit and application required monitoring unless:

- Another permit condition specifies other methods, detection levels, or quantitation levels.
- The method used produces measurable results in the sample and EPA has listed it as an EPA-approved method in 40 CFR Part 136. If the Permittee uses an alternative method, not specified in the permit and as allowed above, it must report the test method, DL, and QL on the discharge monitoring report or in the required report.

If the Permittee is unable to obtain the required DL and QL in its effluent due to matrix effects, the Permittee must submit a Matrix-Specific Detection Limit (MDL) and a QL to Ecology with appropriate laboratory documentation.

When the permit requires the Permittee to measure the base neutral compounds in the list of priority pollutants, it must measure all of the base neutral pollutants listed in the table below. The list includes EPA required base neutral priority pollutants and several additional polynuclear aromatic hydrocarbons (PAHs). The Water Quality Program added several PAHs to the list of base neutrals below from Ecology's Persistent Bioaccumulative Toxics (PBT) List. It only added those PBT parameters of interest to Appendix A that did not increase the overall cost of analysis unreasonably.

Ecology added this appendix to the permit in order to reduce the number of analytical "non-detects" in permit-required monitoring and to measure effluent concentrations near or below criteria values where possible at a reasonable cost.

The lists below include conventional pollutants (as defined in CWA section 502(6) and 40 CFR Part 122.), toxic or priority pollutants as defined in CWA section 307(a)(1) and listed in 40 CFR Part 122 Appendix D, 40 CFR Part 401.15 and 40 CFR Part 423 Appendix A), and nonconventionals. 40 CFR Part 122 Appendix D (Table V) also identifies toxic pollutants and hazardous substances which are required to be reported by dischargers if expected to be present. This permit appendix A list does not include those parameters.

Table 1: Conventional Pollutants

Pollutant	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL)¹ µg/L Unless specified	Quantitation Level (QL)² µg/L Unless specified
Biochemical Oxygen Demand		SM5210-B		2 mg/L
Biochemical Oxygen Demand, Soluble		SM5210-B ³		2 mg/L
Fecal Coliform		SM 9221E,9222	N/A	Specified in method sample aliquot dependent
Oil and Grease (HEM) (Hexane Extractable Material)		1664 A or B	1,400	5,000
pH		SM4500-H ⁺ B	N/A	N/A
Total Suspended Solids		SM2540-D		5 mg/L

Table 2: Nonconventional Pollutants

Pollutant	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL)¹ µg/L Unless specified	Quantitation Level (QL)² µg/L Unless specified
Alkalinity, Total		SM2320-B		5 mg/L as CaCO ₃
Aluminum, Total	7429-90-5	200.8	2.0	10
Ammonia, Total (as N)		SM4500-NH ₃ -B and C/D/E/G/H		20
Barium Total	7440-39-3	200.8	0.5	2.0

Pollutant	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL)¹ µg/L Unless specified	Quantitation Level (QL)² µg/L Unless specified
BTEX (benzene +toluene + ethylbenzene + m,o,p xylenes)		EPA SW 846 8021/8260	1	2
Boron, Total	7440-42-8	200.8	2.0	10.0
Chemical Oxygen Demand		SM5220-D		10 mg/L
Chloride		SM4500-Cl B/C/D/E and SM4110 B		Sample and limit dependent
Chlorine, Total Residual		SM4500 Cl G		50.0
Cobalt, Total	7440-48-4	200.8	0.05	0.25
Color		SM2120 B/C/E		10 color units
Dissolved oxygen		SM4500-OC/OG		0.2 mg/L
E.coli		SM 9221B, 9221F, 9223B	N/A	Specified in method - sample aliquot dependent
Enterococci		SM 9230B, 9230C, 9230D	N/A	Specified in method - sample aliquot dependent
Flow		Calibrated device		
Fluoride	16984-48-8	SM4500-F E	25	100
Hardness, Total		SM2340B		200 as CaCO ₃
Iron, Total	7439-89-6	200.7	12.5	50
Magnesium, Total	7439-95-4	200.7	10	50

Pollutant	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL)¹ µg/L Unless specified	Quantitation Level (QL)² µg/L Unless specified
Manganese, Total	7439-96-5	200.8	0.1	0.5
Molybdenum, Total	7439-98-7	200.8	0.1	0.5
Nitrate + Nitrite Nitrogen (as N)		SM4500-NO3- E/F/H		100
Nitrogen, Total Kjeldahl (as N)		SM4500-N _{org} B/C and SM4500NH ₃ -B/C/D/EF/G/H		300
NWTPH Dx ⁴		Ecology NWTPH Dx	250	250
NWTPH Gx ⁵		Ecology NWTPH Gx	250	250
Phosphorus, Total (as P)		SM 4500 PB followed by SM4500-PE/PF	3	10
Salinity		SM2520-B		3 practical salinity units or scale (PSU or PSS)
Settleable Solids		SM2540 -F		Sample and limit dependent
Soluble Reactive Phosphorus (as P)		SM4500-P E/F/G	3	10
Sulfate (as mg/L SO ₄)		SM4110-B		0.2 mg/L
Sulfide (as mg/L S)		SM4500-S ² F/D/E/G		0.2 mg/L
Sulfite (as mg/L SO ₃)		SM4500-SO3B		2 mg/L

Pollutant	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL) ¹ µg/L Unless specified	Quantitation Level (QL) ² µg/L Unless specified
Temperature (max. 7-day avg.)		Analog recorder or Use micro-recording devices known as thermistors		0.2° C
Tin, Total	7440-31-5	200.8	0.3	1.5
Titanium, Total	7440-32-6	200.8	0.5	2.5
Total Coliform		SM 9221B, 9222B, 9223B	N/A	Specified in method - sample aliquot dependent
Total Organic Carbon		SM5310-B/C/D		1 mg/L
Total dissolved solids		SM2540 C		20 mg/L

Priority Pollutants

Table 3: Metals, Cyanide & Total Phenols

Priority Pollutants	PP #	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL) ¹ µg/L Unless specified	Quantitation Level (QL) ² µg/L Unless specified
Antimony, Total	114	7440-36-0	200.8	0.3	1.0
Arsenic, Total	115	7440-38-2	200.8	0.1	0.5
Beryllium, Total	117	7440-41-7	200.8	0.1	0.5
Cadmium, Total	118	7440-43-9	200.8	0.05	0.25

Priority Pollutants	PP #	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL) ¹ µg/L Unless specified	Quantitation Level (QL) ² µg/L Unless specified
Chromium (hex) dissolved	119	18540-29-9	SM3500-Cr C	0.3	1.2
Chromium, Total	119	7440-47-3	200.8	0.2	1.0
Copper, Total	120	7440-50-8	200.8	0.4	2.0
Lead, Total	122	7439-92-1	200.8	0.1	0.5
Mercury, Total	123	7439-97-6	1631E	0.0002	0.0005
Nickel, Total	124	7440-02-0	200.8	0.1	0.5
Selenium, Total	125	7782-49-2	200.8	1.0	1.0
Silver, Total	126	7440-22-4	200.8	0.04	0.2
Thallium, Total	127	7440-28-0	200.8	0.09	0.36
Zinc, Total	128	7440-66-6	200.8	0.5	2.5
Cyanide, Total	121	57-12-5	335.4	5	10
Cyanide, Weak Acid Dissociable	121		SM4500-CN I	5	10
Cyanide, Free Amenable to Chlorination (Available Cyanide)	121		SM4500-CN G	5	10
Phenols, Total	65		EPA 420.1		50

Table 4: Acid Compounds

Priority Pollutants	PP #	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL) ¹ µg/L Unless specified	Quantitation Level (QL) ² µg/L Unless specified
2-Chlorophenol	24	95-57-8	625.1	3.3	9.9
2,4-Dichlorophenol	31	120-83-2	625.1	2.7	8.1
2,4-Dimethylphenol	34	105-67-9	625.1	2.7	8.1
4,6-dinitro-o-cresol (2-methyl-4,6,-dinitrophenol)	60	534-52-1	625.1/1625B	24	72
2,4 dinitrophenol	59	51-28-5	625.1	42	126
2-Nitrophenol	57	88-75-5	625.1	3.6	10.8
4-Nitrophenol	58	100-02-7	625.1	2.4	7.2
Parachlorometa cresol (4-chloro-3-methylphenol)	22	59-50-7	625.1	3.0	9.0
Pentachlorophenol	64	87-86-5	625.1	3.6	10.8
Phenol	65	108-95-2	625.1	1.5	4.5
2,4,6- Trichlorophenol	21	88-06-2	625.1	2.7	8.1

Table 5: Volatile Compounds

Priority Pollutants	PP #	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL) ¹ µg/L Unless specified	Quantitation Level (QL) ² µg/L Unless specified
Acrolein	2	107-02-8	624.1	5	10

Acrylonitrile	3	107-13-1	624.1	1.0	2.0
Benzene	4	71-43-2	624.1	4.4	13.2
Bromoform	47	75-25-2	624.1	4.7	14.1
Carbon tetrachloride	6	56-23-5	624.1/601 or SM6230B	2.8	8.4
Chlorobenzene	7	108-90-7	624.1	6.0	18.0
Chloroethane	16	75-00-3	624/601	1.0	2.0
2-Chloroethylvinyl Ether	19	110-75-8	624.1	1.0	2.0
Chloroform	23	67-66-3	624.1 or SM6210B	1.6	4.8
Dibromochloromethane (chlorodibromomethane)	51	124-48-1	624.1	3.1	9.3
1,2-Dichlorobenzene	25	95-50-1	624.1	1.9	7.6
1,3-Dichlorobenzene	26	541-73-1	624.1	1.9	7.6
1,4-Dichlorobenzene	27	106-46-7	624.1	4.4	17.6
Dichlorobromomethane	48	75-27-4	624.1	2.2	6.6
1,1-Dichloroethane	13	75-34-3	624.1	4.7	14.1
1,2-Dichloroethane	10	107-06-2	624.1	2.8	8.4
1,1-Dichloroethylene	29	75-35-4	624.1	2.8	8.4
1,2-Dichloropropane	32	78-87-5	624.1	6.0	18.0
1,3-dichloropropene (mixed isomers) (1,2-dichloropropylene) ⁶	33	542-75-6	624.1	5.0	15.0
Ethylbenzene	38	100-41-4	624.1	7.2	21.6

Methyl bromide (Bromomethane)	46	74-83-9	624/601	5.0	10.0
Methyl chloride (Chloromethane)	45	74-87-3	624.1	1.0	2.0
Methylene chloride	44	75-09-2	624.1	2.8	8.4
1,1,2,2-Tetrachloroethane	15	79-34-5	624.1	6.9	20.7
Tetrachloroethylene	85	127-18-4	624.1	4.1	12.3
Toluene	86	108-88-3	624.1	6.0	18.0
1,2-Trans-Dichloroethylene (Ethylene dichloride)	30	156-60-5	624.1	1.6	4.8
1,1,1-Trichloroethane	11	71-55-6	624.1	3.8	11.4
1,1,2-Trichloroethane	14	79-00-5	624.1	5.0	15.0
Trichloroethylene	87	79-01-6	624.1	1.9	5.7
Vinyl chloride	88	75-01-4	624/SM6200B	1.0	2.0

Table 6: Base/Neutral Compounds (Compounds in **Bold** are Ecology PBTS)

Priority Pollutants	PP #	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL)¹ µg/L Unless specified	Quantitation Level (QL)² µg/L Unless specified
Acenaphthene	1	83-32-9	625.1	1.9	5.7
Acenaphthylene	77	208-96-8	625.1	3.5	10.5
Anthracene	78	120-12-7	625.1	1.9	5.7
Benzidine	5	92-87-5	625.1	44	132

Benzyl butyl phthalate	67	85-68-7	625.1	2.5	7.5
Benzo(a)anthracene	72	56-55-3	625.1	7.8	23.4
Benzo(b)fluoranthene (3,4-benzofluoranthene) ⁷	74	205-99-2	610/625.1	4.8	14.4
Benzo(j)fluoranthene⁷		205-82-3	625	0.5	1.0
Benzo(k)fluoranthene (11,12-benzofluoranthene) ⁷	75	207-08-9	610/625.1	2.5	7.5
Benzo(r,s,t)pentaphene		189-55-9	625	1.3	5.0
Benzo(a)pyrene	73	50-32-8	610/625.1	2.5	7.5
Benzo(ghi)Perylene	79	191-24-2	610/625.1	4.1	12.3
Bis(2-chloroethoxy)methane	43	111-91-1	625.1	5.3	15.9
Bis(2-chloroethyl)ether	18	111-44-4	611/625.1	5.7	17.1
Bis(2-chloro-1-methylethyl)Ether (Bis(2-chloroisopropyl)ether) ¹⁰	42	108-60-1	625.1	5.7	17.1
Bis(2-ethylhexyl)phthalate	66	117-81-7	625.1	2.5	7.5
4-Bromophenyl phenyl ether	41	101-55-3	625.1	1.9	5.7
2-Chloronaphthalene	20	91-58-7	625.1	1.9	5.7
4-Chlorophenyl phenyl ether	40	7005-72-3	625.1	4.2	12.6
Chrysene	76	218-01-9	610/625.1	2.5	7.5
Dibenzo (a,h)acridine		226-36-8	610M/625M	2.5	10.0
Dibenzo (a,j)acridine		224-42-0	610M/625M	2.5	10.0

Dibenzo(a-h)anthracene (1,2,5,6-dibenzanthracene)	82	53-70-3	625.1	2.5	7.5
Dibenzo(a,e)pyrene		192-65-4	610M/625M	2.5	10.0
Dibenzo(a,h)pyrene		189-64-0	625M	2.5	10.0
3,3-Dichlorobenzidine	28	91-94-1	605/625.1	16.5	49.5
Diethyl phthalate	70	84-66-2	625.1	1.9	5.7
Dimethyl phthalate	71	131-11-3	625.1	1.6	4.8
Di-n-butyl phthalate	68	84-74-2	625.1	2.5	7.5
2,4-dinitrotoluene	35	121-14-2	609/625.1	5.7	17.1
2,6-dinitrotoluene	36	606-20-2	609/625.1	1.9	5.7
Di-n-octyl phthalate	69	117-84-0	625.1	2.5	7.5
1,2-Diphenylhydrazine (as Azobenzene)	37	122-66-7	1625B	5.0	20
Fluoranthene	39	206-44-0	625.1	2.2	6.6
Fluorene	80	86-73-7	625.1	1.9	5.7
Hexachlorobenzene	9	118-74-1	612/625.1	1.9	5.7
Hexachlorobutadiene	52	87-68-3	625.1	0.9	2.7
Hexachlorocyclopentadiene	53	77-47-4	1625B/625	2.0	4.0
Hexachloroethane	12	67-72-1	625.1	1.6	4.8
Indeno(1,2,3-cd)Pyrene	83	193-39-5	610/625.1	3.7	11.1
Isophorone	54	78-59-1	625.1	2.2	6.6

3-Methyl cholanthrene		56-49-5	625	2.0	8.0
Naphthalene	55	91-20-3	625.1	1.6	4.8
Nitrobenzene	56	98-95-3	625.1	1.9	5.7
N-Nitrosodimethylamine	61	62-75-9	607/625	2.0	4.0
N-Nitrosodi-n-propylamine	63	621-64-7	607/625	0.5	1.0
N-Nitrosodiphenylamine	62	86-30-6	625	1.0	2.0
Perylene		198-55-0	625	1.9	7.6
Phenanthrene	81	85-01-8	625.1	5.4	16.2
Pyrene	84	129-00-0	625.1	1.9	5.7
1,2,4-Trichlorobenzene	8	120-82-1	625.1	1.9	5.7

Table 7: Dioxin

Priority Pollutant	PP #	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL)¹ µg/L Unless specified	Quantitation Level (QL)² µg/L Unless specified
2,3,7,8-Tetra-Chlorodibenzo-P-Dioxin (2,3,7,8 TCDD)	129	1746-01-6	1613B	1.3 pg/L	5 pg/L

Table 8: Pesticides/PCBS

Priority Pollutants	PP #	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL)¹ µg/L Unless specified	Quantitation Level (QL)² µg/L Unless specified
Aldrin	89	309-00-2	608.3	4.0 ng/L	12 ng/L

Priority Pollutants	PP #	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL) ¹ µg/L Unless specified	Quantitation Level (QL) ² µg/L Unless specified
alpha-BHC	102	319-84-6	608.3	3.0 ng/L	9.0 ng/L
beta-BHC	103	319-85-7	608.3	6.0 ng/L	18 ng/L
gamma-BHC (Lindane)	104	58-89-9	608.3	4.0 ng/L	12 ng/L
delta-BHC	105	319-86-8	608.3	9.0 ng/L	27 ng/L
Chlordane ⁸	91	57-74-9	608.3	14 ng/L	42 ng/L
4,4'-DDT	92	50-29-3	608.3	12 ng/L	36 ng/L
4,4'-DDE	93	72-55-9	608.3	4.0 ng/L	12 ng/L
4,4' DDD	94	72-54-8	608.3	11ng/L	33 ng/L
Dieldrin	90	60-57-1	608.3	2.0 ng/L	6.0 ng/L
alpha-Endosulfan	95	959-98-8	608.3	14 ng/L	42 ng/L
beta-Endosulfan	96	33213-65-9	608.3	4.0 ng/L	12 ng/L
Endosulfan Sulfate	97	1031-07-8	608.3	66 ng/L	198 ng/L
Endrin	98	72-20-8	608.3	6.0 ng/L	18 ng/L
Endrin Aldehyde	99	7421-93-4	608.3	23 ng/L	70 ng/L
Heptachlor	100	76-44-8	608.3	3.0 ng/L	9.0 ng/L
Heptachlor Epoxide	101	1024-57-3	608.3	83 ng/L	249 ng/L
PCB-1242 ⁹	106	53469-21-9	608.3	0.065	0.195
PCB-1254	107	11097-69-1	608.3	0.065	0.195

Priority Pollutants	PP #	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL)¹ µg/L Unless specified	Quantitation Level (QL)² µg/L Unless specified
PCB-1221	108	11104-28-2	608.3	0.065	0.195
PCB-1232	109	11141-16-5	608.3	0.065	0.195
PCB-1248	110	12672-29-6	608.3	0.065	0.195
PCB-1260	111	11096-82-5	608.3	0.065	0.195
PCB-1016 ⁹	112	12674-11-2	608.3	0.065	0.195
Toxaphene	113	8001-35-2	608.3	240 ng/L	720 ng/L

ANALYTICAL METHODS

1. **Detection level (DL)** – or detection limit means the minimum concentration of an analyte (substance) that can be measured and reported with a 99 percent confidence that the analyte concentration is greater than zero as determined by the procedure given in 40 CFR part 136, Appendix B.
2. **Quantitation Level (QL)** – also known as Minimum Level of Quantitation (ML) – The lowest level at which the entire analytical system must give a recognizable signal and acceptable calibration point for the analyte. It is equivalent to the concentration of the lowest calibration standard, assuming that the lab has used all method-specified sample weights, volumes, and cleanup procedures. The QL is calculated by multiplying the MDL by 3.18 and rounding the result to the number nearest to $(1, 2, \text{ or } 5) \times 10^n$, where n is an integer. (64 FR 30417). **Also Given As:** The smallest detectable concentration of analyte greater than the Detection Limit (DL) where the accuracy (precision & bias) achieves the objectives of the intended purpose. (Report of the Federal Advisory Committee on Detection and Quantitation Approaches and Uses in Clean Water Act Programs Submitted to the US Environmental Protection Agency December 2007).
3. **Soluble Biochemical Oxygen Demand** – method note: First, filter the sample through a Millipore Nylon filter (or equivalent) - pore size of 0.45-0.50 um (prep all filters by filtering 250 ml of laboratory grade deionized water through the filter and discard). Then, analyze sample as per method 5210-B.
4. **Northwest Total Petroleum Hydrocarbons Diesel Extended Range OR NWTPH Dx** – [Analytical Methods for Petroleum Hydrocarbons](https://fortress.wa.gov/ecy/publications/documents/97602.pdf)
<https://fortress.wa.gov/ecy/publications/documents/97602.pdf>.
5. **Northwest Total Petroleum Hydrocarbons Gasoline Extended Range OR NWTPH Gx** – [Analytical Methods for Petroleum Hydrocarbons](https://fortress.wa.gov/ecy/publications/documents/97602.pdf)
<https://fortress.wa.gov/ecy/publications/documents/97602.pdf>.
6. **1, 3-dichloroproylene (mixed isomers)** – You may report this parameter as two separate parameters: cis-1, 3-dichloropropene (10061-01-5) and trans-1, 3-dichloropropene (10061-02-6).
7. **Total Benzofluoranthenes** – Because Benzo(b)fluoranthene, Benzo(j)fluoranthene and Benzo(k)fluoranthene co-elute you may report these three isomers as total benzofluoranthenes.
8. **Chlordane** – You may report alpha-chlordane (5103-71-9) and gamma-chlordane (5103-74-2) in place of chlordane (57-74-9). If you report alpha and gamma-chlordane, the DL/PQLs that apply are 14/42 ng/L.
9. **PCB 1016 & PCB 1242** – You may report these two PCB compounds as one parameter called PCB 1016/1242.
10. **Bis(2-Chloro-1-Methylethyl) Ether** – This compound was previously listed as Bis(2-Chloroisopropyl) Ether (39638-32-9).