



Water Quality Program

Permit Submittal Electronic Certification

Permittee: ECHO BAY MINERALS CO KEY PROJECT

Permit Number: WA0991005

Site Address: 363 FISH HATCHERY RD
REPUBLIC, WA 99166

Submittal Name: Reporting Permit Violations 5 Day Written Report

Version: 1

Due Date:

Comments: The average monthly limit for sulfate and TDS for February was exceeded. The system was still dealing with low temperatures, including below freezing. Water influent was very low the previous months, picking up in February. Attached analytical results show dates of sampling, and values. Values will also be reported in the DMR.

The finishing cell before discharge appeared to have ice built up as well. The finishing tank was stirred and broken up to improve surface contact and flow. Sampling will continue on schedule along with troubleshooting to improve treatment.

I certify under penalty of law, that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Kyle Hawkins

3/11/2024 11:38:30 AM

Signature

Date