



Water Quality Program

Permit Submittal Electronic Certification

Permittee: EDMONDS STP

Permit Number: WA0024058

Site Address: 200 2ND AVE S
EDMONDS, WA 98020-3578

Submittal Name: Toxicity Acute Testing

Version: 1

Due Date: 8/15/2024

Comments: There was no statistically significant difference between the control and the acute critical effluent concentration (ACEC) of 2.7% of the 24 hour composite final effluent sample collected on June 4, 2024.

I certify under penalty of law, that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Jeanne McKenzie

6/21/2024 1:09:51 PM

Signature

Date