



STATE OF WASHINGTON
DEPARTMENT OF ECOLOGY

15 W Yakima Ave, Ste 200 • Yakima, WA 98902-3452 • (509) 575-2490

April 17, 2014

Richard and Shontele Simonian
Santiago Communities, Inc.
326 West Katella Avenue, Suite 4K
Orange, CA 92867

RE: Groundwater Monitoring Frequency
Community Sewer and Water District, Permit No. ST-5529
Tracking No. 1401-3A

Dear Richard and Shontele Simonian:

Per your request, the Department of Ecology (Ecology) has received Community Sewer and Water District's (Permittee) request for a reduction of groundwater monitoring. Ecology APPROVES the groundwater sampling frequency for all five monitoring wells as described in Table 1 below.

Table 1. Revised Groundwater Monitoring Requirements

| Parameters | Sampling Frequency |
|---|--------------------|
| pH, s.u. | Quarterly* |
| Conductivity, $\mu\text{S}/\text{cm}$ | Quarterly |
| Temperature, $^{\circ}\text{C}$ | Quarterly |
| Static Water Level, ft (nearest 0.01 ft) | Quarterly |
| Ammonia-N, mg/L | Quarterly |
| Total Kjeldahl Nitrogen, mg/L | Quarterly |
| Nitrate-N, mg/L | Quarterly |
| Sodium, mg/L | Annually** |
| Calcium, mg/L | Annually |
| Chloride, mg/L | Annually |
| Sulfate, mg/L | Annually |
| Phosphate, mg/L | Annually |
| Ferrous Iron, mg/L | Annually |
| Fecal Coliform, # colonies/100 mL | Annually |
| *Quarterly monitoring due by April 15 th , July 15 th , October 15 th , and January 15 th every year. | |
| **Annual monitoring means 1 time during each calendar year in the month of June. Annual monitoring due by July 15 th every year. | |



Santiago Communities, Inc.
April 16, 2014
Page 2


The revised groundwater monitoring requirements in Table 1. are effective as of April 1, 2014 and shall be conducted until further notice from Ecology.

In addition, note that all other parameters, conditions, and requirements in permit ST-5529 remain unchanged until a new or modified permit can be issued.

Nothing in this approval shall be construed as satisfying other applicable federal, state or local statutes, ordinances or regulations.

Should you have any questions or need any additional information, please contact Ian Laseke, Facility Manager, at 509/457-7108.

Sincerely,

A handwritten signature in cursive script that reads "Charles McKinney".

Charles McKinney
Section Manager
Water Quality Program

cc: Christine Batayola, Harms Engineering, Inc.
Ian Laseke, Department of Ecology
Sanjay Barik, Department of Ecology