



STATE OF WASHINGTON  
DEPARTMENT OF ECOLOGY

PO Box 47600 • Olympia, WA 98504-7600 • 360-407-6000

711 for Washington Relay Service • Persons with a speech disability can call 877-833-6341

July 12, 2016

Mr. Duke Spencer  
Solvay Chemicals  
3500 Industrial Way  
Longview, Washington 98632

**Re: June 2016 Water Compliance Inspection Report – Unannounced Class I**

Dear Mr. Spencer:

I would like to thank Solvay Chemicals Longview for its assistance during the water compliance inspection without sampling on June 24, 2016.

Ecology noted no deficiencies during the inspection and no enforcement actions will be taken as a result. Ecology appreciates Solvay's commitment to the health of the community and environment. Please find enclosed a copy of the inspection report. If you have any questions regarding the results of the inspection, please contact me at (360) 407-7563 or [shingo.yamazaki@ecy.wa.gov](mailto:shingo.yamazaki@ecy.wa.gov).

Sincerely,

Shingo Yamazaki  
Industrial Section  
Waste 2 Resources Program

Enclosure





State of Washington Department of Ecology  
Industrial Section  
Water Compliance Inspection Report

Section A

State Permit Number ST|6|0|7|0| Municipal ☐ Industrial ☒ IUs ☐  
Recon ☐ Inspection ☒ Inspection ☐ Unpermitted ☐ Land Application ☐  
with Samples Facility

Permit Effective Date  
October 1, 2014  
Permit Expiration Date  
September 30, 2019

Section B

Name and Location of Facility Inspected  
Solvay Chemicals, Inc.  
3500 Industrial Way  
Longview, Washington 98632

County

Cowlitz

Inspection Date

June 24, 2015

Entry Time

1:00 PM

Exit Time

2:30 PM

Name(s) of On-Site Representative(s)

Duke Spencer

Title(s)

HSE Specialist

Phone Number(s)

(360) 636-7797

Name, Address of Responsible Official

Alicia Fuentes

3500 Industrial Way

Longview, Washington 98632

Phone

(360) 577-7566

Announced?

☐ Yes

☒ No

Title

Site Manager

Section C

(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

S	Permit	S	Flow Measurement	N	Pretreatment	S	Operations/Maint.
S	Records/Reports	N	Laboratory	N	Compliance Schedules	N	Sludge Disposal
S	Facility Site Review	N	Effluent/Receiving Waters	S	Self-Monitoring Program	N	Other:

Section D Summary of Findings

**Inspection Findings:** The inspection included a facility tour and review of inspection logs, training records, and calibration procedures. Buffer solutions for pH probe calibrations were inspected and were not expired. pH meter calibration records and calibration procedures were reviewed. Stormwater inspections were reviewed and complete. Cooling water and boiler treatment chemicals were emailed to Ecology on 7/6/2016 and reviewed.

**Recommended Actions:** No deficiencies were noted.

Name(s) and Signature(s) of Inspector(s)

Shingo Yamazaki

Section/Phone Number

Industrial / (360) 407-7563

Date

7/8/16

Signature of Reviewer

Stephanie Ogle, P.E.

Section/Phone Number

Industrial / (360) 407-6355

Date

7/8/16