



STATE OF WASHINGTON
DEPARTMENT OF ECOLOGY

Northwest Regional Office • 3190 160th Ave SE • Bellevue, WA 98008-5452 • 425-649-7000
711 for Washington Relay Service • Persons with a speech disability can call 877-833-6341

February 14, 2017

Mr. Robert Waddle
King County Wastewater Treatment Division - South Plant Reclaim Treatment Plant
1200 Monster Rd SW
Renton, WA 98055

Re: **WARNING LETTER** for National Pollutant Discharge Elimination System (NPDES)
Permit No. ST0007445 for King County Wastewater Treatment Division - South Plant Reclaim
Treatment Plant

Dear Mr. Waddle:

This letter is to inform you that your facility was out of compliance with the conditions in your wastewater discharge permit as listed below:

Month/ Year	Outfall	Monitoring Parameter	Type	Sample Measurement	Units	Min Limit	Max Limit
9/26/2016	RW1	Total Coliform	Single Sample	32	#/100ml	-	23


Non-compliance notifications are required by your permit. The checked item below indicates if further notification is required regarding the above violation(s).

- No further action is required. You have already submitted a notice of non-compliance or explained the cause of the violation(s) in your Discharge Monitoring Report (DMR). You have already complied with this requirement.
- You must submit this notice immediately. You have not submitted a notice of non-compliance for the violation(s) and have not explained the cause of the violation(s) in your DMR, then you are in violation of your permit. You may refer to your permit for more information about submitting a non-compliance notification.

Ecology uses the DMR to evaluate compliance with permit requirements. If you fail to comply with the conditions of your permit, Ecology may take formal administrative enforcement action, including issuing orders and penalties. Ecology's enforcement authority for NPDES permits is governed by Chapter 173-220-230 of the Washington Administrative Code (WAC). Ecology's enforcement authority for state waste discharge permits is governed by Chapter 173-216 of the Washington Administrative Code (WAC).

Please contact me at (425) 649-7195 or by email at ajan461@ecy.wa.gov if you have any further questions.

Sincerely,


Amy Jankowiak
Municipal Compliance Specialist
Water Quality Program

cc: Jeff Lafer, Water Quality Planner/Project Manager IV
Central Files: King County Wastewater Treatment Division - South Plant Reclaim Treatment Plant,
ST0007445, WQ 6.4

e-cc: Shawn Mckone, Permit Manager

