



1




7. IDENTIFICATION TAPE WILL BE AT LEAST 3 INCHES WIDE, 4.0 MILS THICK, HAVE WHITE OR BLACK LETTERING ON A PURPLE (PANTONE 512) FIELD, AND STATE: "CAUTION: RECLAIMED WATER - DO NOT DRINK." IDENTIFICATION TAPE WILL BE MADE OF AN INERT MATERIAL THAT IS RESISTANT TO CRACKING, PEELING, AND FADING DUE TO SUNLIGHT, HEAT, AND ENVIRONMENTAL CONDITIONS. THE IDENTIFICATION TAPE WILL BE INSTALLED ON TOP OF RECLAIMED WATER PIPELINES, FASTENED AT LEAST EVERY 10 FEET TO EACH PIPE LENGTH, AND RUN CONTINUOUSLY ALONG THE ENTIRE LENGTH OF THE PIPE.
8. ALL BELOW-GROUND RECLAIMED WATER PIPE WILL INCLUDE A LOCATING WIRE, WHICH WILL BE FASTENED BY PLASTIC ADHESIVE TAPE TO THE TOP CENTER OF THE PIPE. THE ADHESIVE TAPE WILL BE Banded AROUND BOTH THE PIPE AND WIRE AT NO MORE THAN 4-FOOT INTERVALS. THE WIRE WILL BE CONTINUOUS FOR THE ENTIRE LENGTH OF PIPE WITHOUT GAPS OR BREAKS. THE WIRE WILL TERMINATE ABOVE GROUND IN A VALVE RISER HOUSING.



1. PROVIDE FOR 1.5" LATERAL DEFLECTION OF PIPE EACH WAY.


SCALE:  $3/4" = 1' - 0"$



**DETAIL**  
**SCALE: NTS**



**carollo**  
Engineers...Working Wonders With Water™



CHECKED:	ALS
SCALE:	H: 1" = 20' V: 1" = 2'
CONTRACT NO:	C00036C06



## WETLANDS DISCHARGE DETAILS

DATE:	MARCH, 2006
FILE NO:	423557/
DRAWING NO:	C805
SHEET NO:	OF 43A 288