



STATE OF WASHINGTON
DEPARTMENT OF ECOLOGY

March 9, 2018

1250 W Alder St • Union Gap, WA 98903-0009 • (509) 575-2490

Barb Evans
Evans Fruit Company
PO Box 70
Coviche, WA 98923

RE: 2017 Annual Discharge Monitoring Report for Permit Nos. WAG435106

Dear Barb:

The Department of Ecology (Ecology) has reviewed your 2017 Annual Discharge Monitoring Report (DMR). The table below summarizes the permit violations found. The purpose of this letter is to provide you an opportunity to review these violations and submit corrections if the record is not accurate.

City Road Plant

Outfall No.	Parameter	Date	Reported Value	Permit Limitation
001	Chlorine, Total Residual	03/23/2017	0.6 mg/L	0.50 mg/L
		11/15/2017	34 mg/L	0.50 mg/L

If you believe that the information in the table is incorrect, please contact me at (509) 454-7864 as soon as possible so Ecology's records can be corrected.

Remedial Action Required

- Determine chlorine levels required to meet food safety requirements and utilize no more chlorine than is actually needed.
- Utilize the proper amount of deactivation product to sufficiently remove any remaining chlorine levels before discharge to the POTW.
- Reported Values highlighted above are considered 'significant violations' and are required to be reported to Ecology within 30 days of the facility becoming aware of the violation (Reference: General Condition 25 of the permit (G25)).

If you should have any questions or concerns, please contact me at (509) 454-7864, or email marcia.porter@ecy.wa.gov.

Sincerely,

Marcia Porter

Marcia Porter
General Permit Manager
Water Quality Program

