

RECEIVED

JUL 27 2018

Dept of Ecology
Central Regional Office

July 12, 2018

Coleman Miller, PE
Environmental Engineer
Water Quality Program
Department of Ecology
1250 W. Alder
Union Gap, WA 98903

Dear Coleman,

This is in response to the letter of June 25th in relation to DMR report where Community Sewer and Water Dist was in violation with the discharge reporting of PH in March, April, May and June 2018.

The PH probe used in the Wastewater plant is need of replacement, but due to the Upgrade of the plant this was not an option.

We feel the PH probe may have read lower than the water actually was and operator was not aware of daily calibrations.

Sincerely,



Sherry Dengate

Wastewater Operator

#8259