

Washington, Diana (ECY)

From: Dan Grogg <dangrogg@libertylake.org>
Sent: Wednesday, January 2, 2019 9:58 AM
To: Washington, Diana (ECY)
Cc: bijay@libertylake.org; dnesbitt@libertylake.org
Subject: Inspection Report Comments

Hi Diana,

Thank you for sending along our Compliance Inspection Report. We have begun initiating the necessary steps to begin implementation of the deficient items addressed in the report and should have most in place within the next month. I would like to bring to your attention some observations and commentary that may be construed as misleading, or more than likely just misunderstood as to our explanations, it was a long day. I have listed below those which are inaccurate.

Page 2 of 19

Second paragraph the anaerobic and anoxic selectors were part of our first upgrade completed in 2006

Regarding Industrial Users we do receive industrial waste none of which require industrial pretreatment or discharge permits from either DOE or the District. The majority of these dischargers underwent waste related submittal and review by the District's Engineer prior to issuance of connection

Page 4 of 19

Third paragraph our biosolids are not transported to a composting facility. For the past 12 years our biosolids have been transported to Boulder Park Inc. located in Mansfield WA. currently designated as a Beneficial Use Facility with the Department. They are contracted to transport, till and apply our Class B biosolids.

With the posting of the Inspection Report on PARIS, we would just like to make sure the public has the correct information and that the narrative was truly representative of our operations. Please let me know if you have any questions or require further clarification.

Best Regards,
Dan