



STATE OF WASHINGTON
DEPARTMENT OF ECOLOGY

1250 W Alder St • Union Gap, WA 98903-0009 • (509) 575-2490

April 4, 2019

James Foreman
Windy Point, LLC
183 Windy Point Drive
Wapato, WA 98951-8811

RE: Annual Discharge Monitoring Report for Windy Point, LLC—WAG435161

Dear James Foreman:

The Department of Ecology (Ecology) has reviewed your 2018 annual discharge monitoring report (DMR). The table below summarizes the permit violations found. The purpose of this letter is to provide you an opportunity to review these violations and submit corrections if the records are not accurate.

Monitoring Point	Parameter	Date	Reported Value	Permit Limit	
001	Total Dissolved Solids, mg/L	3/29/2018	1210	500	
	Total Dissolved Solids, mg/L	5/24/2018	680		
	Total Dissolved Solids, mg/L	9/27/2018	1000		
	Total Dissolved Solids, mg/L	11/13/2018	652		
002	pH, Standard Units			6.00-9.00	
	Total Dissolved Solids, mg/L	1/08/2018	9.13		
	pH, Standard Units	1/08/2018	1340		500
	Total Dissolved Solids, mg/L	8/23/2018	872		500
	Total Residual Chlorine, mg/L*	12/13/2018	9.23		6.00-9.00
		12/13/2018	880		500
003	Late DMR			10	
		12/13/2018	104		
All		Late DMR	Late DMR	Due By 1/31/2019	



James Foreman
April 5, 2019
Page 2

***If you are using PAA only, please have the laboratory not run chlorine residual tests because PAA will give you a false high positive. If the facility is utilizing chlorine based products, please update the record at Ecology for this monitoring point. If the 104 mg/L is a true reading of chlorine residual, please contact me at either the phone number or email below and clarify this reported value from 12/13/2018.**

If you believe that the information in the table is incorrect, please contact me at 509- 454-7864 as soon as possible so Ecology's records can be corrected.

I have some concerns with the levels of the pollutants listed in this table. It may be necessary for Windy Point, LLC to look at other treatment or disposal methods. I will plan to be there during packing operations. Please instruct your staff that I would like to be there during sampling events, I might be able to provide some technical assistance to help.

If you should have any questions or concerns please contact me at 509-454-7864, or email marcia.porter@ecy.wa.gov.

Sincerely,



Marcia Porter
Central Region General Permit Manager
Water Quality Program

By Certified Mail 7004 1160 0002 6158 1471