



STATE OF WASHINGTON  
DEPARTMENT OF ECOLOGY

Northwest Regional Office • 3190 160th Ave SE • Bellevue, WA 98008-5452 • 425-649-7000  
711 for Washington Relay Service • Persons with a speech disability can call 877-833-6341

May 23, 2019

Mr. Zeeshan Qazi  
ZYK Enterprises  
17658 W Snoqualmie River Rd NE  
Duvall WA 98019-9203

Re: **WARNING LETTER:** State Waste Discharge Permit Number ST0003974, ZYK Enterprises

Dear Mr. Qazi:

This letter is to inform you that your Discharge Monitoring Reports (DMR) show exceedances of the Total Coliform limit specified in Special Condition S1 of your state waste discharge permit number ST0003974. Table 1 shows the out of compliance values and dates of exceedance. Residual chlorine has not been monitored since chlorination was reinstated as the disinfectant for Outfall #003 (Table 2). In addition, several DMRs are missing or were submitted past their due date since 2017 (Table 3). These are monitoring and reporting violations according to Special Conditions S2 and S3 of your permit.

**Table 1. Effluent limit violations for Outfall #003**

<i>DMR</i>	<i>Parameter</i>	<i>Measurement</i>	<i>Limit</i>	<i>Units</i>	<i>Limit Type</i>
3 <sup>rd</sup> Quarter 2017	Total Coliform	4,000,000	1000	#/100ml	Quarterly Average
1 <sup>st</sup> Quarter 2018	Total Coliform	300,000	1000	#/100ml	Quarterly Average
3 <sup>rd</sup> Quarter 2018	Total Coliform	6,300 *	1000	#/100ml	Quarterly Average
4 <sup>th</sup> Quarter 2018	Total Coliform	15,000	1000	#/100ml	Quarterly Average

\* Fecal coliform measured instead of total coliform

**Table 2. Monitoring violations since UV light was replaced by Chlorination as disinfectant**

<i>DMR</i>	<i>Violation</i>	<i>Outfall</i>	<i>Parameter</i>
2 <sup>nd</sup> Quarter 2018	Analysis not conducted	003	Total Coliform
2 <sup>nd</sup> Quarter 2018	Analysis not conducted	003	Residual Chlorine
3 <sup>rd</sup> Quarter 2018	Analysis not conducted	003	Residual Chlorine
4 <sup>th</sup> Quarter 2018	Analysis not conducted	003	Residual Chlorine



**Table 3. Reporting violations for late or missing DMRs**

<i>DMR</i>	<i>Monitoring Period</i>	<i>DMR Due</i>	<i>Received</i>	<i>Days Late</i>
3 <sup>rd</sup> Quarter 2017	7/1/2017 - 9/30/2017	10/15/2018	10/30/2018	15
4 <sup>th</sup> Quarter 2017	10/1/2017 - 12/31/2017	1/15/2018		Missing
1 <sup>st</sup> Quarter 2018	1/1/2018 - 3/31/2018	4/15/2018	9/21/2018	159
February 2018	2/1/2018 - 2/28/2018	4/15/2018	6/7/2018	53
June 2018	6/1/2018 - 6/30/2018	7/15/2018	9/21/2018	68
3 <sup>rd</sup> Quarter 2018	7/1/2018 - 9/30/2018	10/15/2018	10/30/2018	15
4 <sup>th</sup> Quarter 2018	10/1/2018 - 12/31/2018	1/15/2019	3/14/2019	58
January 2019	1/1/2019 - 1/31/2019	4/15/2019		Missing
February 2019	2/1/2019 - 2/28/2019	4/15/2019		Missing
1 <sup>st</sup> Quarter 2019	1/1/2019 - 3/31/2019	4/15/2019		Missing

The DMR is the principal tool used to evaluate compliance with permit requirements. The Department of Ecology (Ecology) places great importance on **timely submittal of complete and accurate DMRs**. Non-compliance notifications are required by your permit. This part of your permit requirement has not been fulfilled.

Ecology notes that **total coliform exceedance and monitoring of residual chlorine are problems for your facility. These problems must be addressed as detailed in the new permit.** Further failures to comply with the conditions of your permit could result in Ecology taking formal administrative enforcement action, including issuing orders and penalties.

Sincerely,



Gretchen Onstad  
Water Quality Enforcement Specialist

cc: Central Files: ZYK Enterprises, ST0003974, WQ 6.4  
cc: Chris Martin, Permit Manager, Ecology  
Zeeshan Qazi, ZYK Enterprises, zyjenterprises786@gmail.com