

Issuance Date: December 28, 2018
Effective Date: February 1, 2019
Expiration Date: January 31, 2024

**National Pollutant Discharge Elimination System
Waste Discharge Permit No. WA0052132**

State of Washington
DEPARTMENT OF ECOLOGY
Central Regional Office
1250 West Alder Street
Union Gap, WA 98903

In compliance with the provisions of
The State of Washington Water Pollution Control Law
Chapter 90.48 Revised Code of Washington
and
The Federal Water Pollution Control Act
(The Clean Water Act)
Title 33 United States Code, Section 1342 et seq.

**Community of Buena Publicly Owned Treatment Works
Yakima County Public Services
128 N 2nd Street, Fourth Floor Courthouse
Yakima, WA 98901**

is authorized to discharge in accordance with the Special and General Conditions that follow.

| | |
|--|--|
| <u>Plant Location:</u> 1680 Buena Road Buena, WA 98921 | <u>Receiving Water:</u> Unnamed waterway, tributary to the Yakima River at river mile 91.4 <u>Discharge Location:</u> Latitude: 46.41702 Longitude: -120.31655 |
| <u>Treatment Type:</u> Septic Tank Effluent Gravity, Recirculating Gravel Filter and UV Disinfection | |



David B. Bowen
Section Manager
Water Quality Program
Central Regional Office
Washington State Department of Ecology

Table of Contents

| | |
|--|-----------|
| <i>Summary of Permit Report Submittals</i> | <i>4</i> |
| <i>Special Conditions.....</i> | <i>6</i> |
| S1. Discharge limits | 6 |
| S1.A. Effluent limits..... | 6 |
| S1.B. Mixing zone authorization | 7 |
| S2. Monitoring requirements | 8 |
| S2.A. Monitoring schedule..... | 8 |
| S2.B. Sampling and analytical procedures | 10 |
| S2.C. Flow measurement and continuous monitoring devices | 10 |
| S2.D. Laboratory accreditation..... | 11 |
| S2.E. Request for reduction in monitoring | 11 |
| S3. Reporting and recording requirements..... | 12 |
| S3.A. Discharge monitoring reports | 12 |
| S3.B. Permit submittals and schedules | 14 |
| S3.C. Records retention..... | 14 |
| S3.D. Recording of results | 14 |
| S3.E. Additional monitoring by the Permittee | 15 |
| S3.F. Reporting permit violations | 15 |
| S3.G. Other reporting..... | 17 |
| S3.H. Maintaining a copy of this permit | 17 |
| S4. Facility loading | 17 |
| S4.A. Design criteria | 17 |
| S4.B. Plans for maintaining adequate capacity..... | 18 |
| S4.C. Duty to mitigate..... | 18 |
| S4.D. Notification of new or altered sources | 18 |
| S4.E. Infiltration and inflow evaluation..... | 19 |
| S4.F. Wasteload assessment | 19 |
| S5. Operation and maintenance | 20 |
| S5.A. Certified operator..... | 20 |
| S5.B. Operation and maintenance program | 21 |
| S5.C. Short-term reduction | 21 |
| S5.D. Electrical power failure | 21 |
| S5.E. Prevent connection of inflow | 22 |
| S5.F. Bypass procedures | 22 |
| S5.G. Operations and maintenance (O&M) manual | 24 |
| S6. Pretreatment | 25 |
| S6.A. General requirements..... | 25 |
| S6.B. Duty to enforce discharge prohibitions | 25 |
| S6.C. Wastewater discharge permit required | 26 |
| S6.D. Identification and reporting of existing, new, and proposed industrial users | 27 |
| S7. Solid wastes | 27 |

| | | |
|-------------|--|-----------|
| S7.A. | Solid waste handling | 27 |
| S7.B. | Leachate | 27 |
| S8. | Application for permit renewal or modification for facility changes | 28 |
| S9. | Spill control plan | 28 |
| S9.A | Spill control plan submittals and requirements | 28 |
| S9.B. | Spill control plan components | 28 |
| S10. | Receiving water study | 29 |
| S11. | Outfall evaluation..... | 31 |
| | <i>General Conditions</i> | <i>31</i> |
| G1. | Signatory requirements | 31 |
| G2. | Right of inspection and entry | 33 |
| G3. | Permit actions..... | 33 |
| G4. | Reporting planned changes..... | 35 |
| G5. | Plan review required..... | 35 |
| G6. | Compliance with other laws and statutes | 35 |
| G7. | Transfer of this permit | 35 |
| G8. | Reduced production for compliance | 36 |
| G9. | Removed substances | 36 |
| G10. | Duty to provide information | 36 |
| G11. | Other requirements of 40 CFR..... | 37 |
| G12. | Additional monitoring | 37 |
| G13. | Payment of fees..... | 37 |
| G14. | Penalties for violating permit conditions | 37 |
| G15. | Upset..... | 37 |
| G16. | Property rights | 38 |
| G17. | Duty to comply | 38 |
| G18. | Toxic pollutants..... | 38 |
| G19. | Penalties for tampering | 39 |
| G20. | Compliance schedules | 39 |
| G21. | Service agreement review..... | 39 |
| | <i>Appendix A—List Of Pollutants With Analytical Methods, Detection Limits And Quantitation Levels</i> | <i>40</i> |

Summary of Permit Report Submittals

Refer to the Special and General Conditions of this permit for additional submittal requirements. The following table is for quick reference only. Enforceable submittal requirements are contained in the permit narrative.

| Permit Section | Submittal | Frequency | First Submittal Date |
|----------------|--|----------------|--|
| S3.A.3.a. | Monthly Discharge Monitoring Report (DMR) | Monthly | March 15, 2019 |
| S3.A.3.b. | Annual DMR | Annually | January 15, 2020 |
| S3.F | Reporting Permit Violations | As necessary | |
| S4.B | Plans for Maintaining Adequate Capacity | As necessary | |
| S4.D | Notification of New or Altered Sources | As necessary | |
| S4.E | Infiltration and Inflow Evaluation | 1/permit cycle | December 31, 2022 |
| S4.F | Wasteload Assessment | 1/permit cycle | December 31, 2022 |
| S5.F | Bypass Notification | As necessary | |
| S5.G.a.1 | Prepare a New Operations and Maintenance Manual | 1/permit cycle | January 1, 2021 |
| S5.G.a.2 | Operations and Maintenance Manual Review Letter to Ecology | 1/permit cycle | June 1, 2022 |
| S6.D | Notification of any proposed discharger which may be a SIU | As necessary | |
| S8 | Application for Permit Renewal | 1/permit cycle | January 31, 2023 |
| S9.A.1. | Spill Control Plan Submittal | 1/permit cycle | January 1, 2020 |
| S10.1. | Receiving Water Quality Assurance (QA) Project Plan Submittal | 1/permit cycle | August 1, 2019 |
| S10.4.d. | Submit the Critical Period Report into the Environmental Information Management System (EIM) | 3/permit cycle | October 15 for years 2020, 2021, 2022 |
| S11 | Outfall Evaluation | 1/permit cycle | February 1, 2020 |

THIS PAGE REVISED DECEMBER 10, 2019

| Permit Section | Submittal | Frequency | First Submittal Date |
|----------------|--|--------------|----------------------|
| G1.3 | Notice of Change in Authorization | As necessary | |
| G4 | Reporting Planned Changes | As necessary | |
| G5 | Engineering Report for Construction or Modification Activities | As necessary | |
| G7 | Notice of Permit Transfer | As necessary | |
| G10 | Duty to Provide Information | As necessary | |
| G20 | Compliance Schedules | As necessary | |
| G21 | Contract Submittal | As necessary | |

Special Conditions

S1. Discharge limits

S1.A. Effluent limits

All discharges and activities authorized by this permit must comply with the terms and conditions of this permit. The discharge of any of the following pollutants more frequently than, or at a level in excess of, that identified and authorized by this permit violates the terms and conditions of this permit.

Beginning on **February 1, 2019**, the Permittee may discharge treated domestic wastewater at the permitted location subject to compliance with the following limits:

| Effluent Limits: Outfall 001 Latitude: 46.41702 Longitude: -120.31655 | | |
|--|--|-----------------------------|
| Parameter | Average Monthly ^a | Average Weekly ^b |
| Biochemical Oxygen Demand (BOD ₅) | 30 mg/L 30 lbs/day 85% removal of influent BOD ₅ | 45 mg/L 45 lbs/day |
| Total Suspended Solids (TSS) | 30 mg/L 30 lbs/day 85% removal of influent TSS | 45 mg/L 45 lbs/day |
| Total Ammonia (as NH ₃ -N) | 3.1 mg/L | N/A |
| Parameter | Minimum | Maximum |
| pH | 6.0 standard units | 9.0 standard units |
| Parameter | Monthly Geometric Mean | Weekly Geometric Mean |
| Fecal Coliform Bacteria ^c | 200/100 milliliter (mL) | 400/100 mL |
| a | Average monthly effluent limit means the highest allowable average of daily discharges over a calendar month. To calculate the discharge value to compare to the limit, you add the value of each daily discharge measured during a calendar month and divide this sum by the total number of daily discharges measured. See footnote c for fecal coliform calculations. | |
| b | Average weekly discharge limit means the highest allowable average of daily discharges over a calendar week, calculated as the sum of all daily discharges measured during a calendar week divided by the number of daily discharges measured during that week. See footnote c for fecal coliform calculations. | |
| c | Ecology provides directions to calculate the monthly and the weekly geometric mean in publication No. 04-10-020, Information Manual for Treatment Plant Operators available at: https://fortress.wa.gov/ecy/publications/documents/0410020.pdf | |

S1.B. Mixing zone authorization

Mixing zone for Outfall 001

The paragraphs below defines the maximum boundaries of the mixing zones.

Chronic mixing zone

The width of the chronic mixing zone is limited to a distance of 3 feet. The length of the chronic mixing zone extends 300 feet downstream of the outfall. The mixing zone extends from the bottom to the top of the water column. The concentration of pollutants at the edge of the chronic zone must meet chronic aquatic life criteria and human health criteria.

Acute mixing zone

The width of the acute mixing zone is limited to a distance of 0.3 feet in any horizontal direction from the outfall. The length of the acute mixing zone extends 30 feet downstream of the outfall. The mixing zone extends from the bottom to the top of the water column. The concentration of pollutants at the edge of the acute zone must meet acute aquatic life criteria.

| Available Dilution (dilution factor) | |
|---|-----|
| Acute Aquatic Life Criteria | 1.2 |
| Chronic Aquatic Life Criteria | 3.0 |

S2. Monitoring requirements

S2.A. Monitoring schedule

The Permittee must monitor in accordance with the following schedule and the requirements specified in Appendix A.

| Parameter | Units & Speciation | Minimum Sampling Frequency | Sample Type |
|---|------------------------|----------------------------|------------------------------|
| (1) Wastewater influent | | | |
| Wastewater Influent means the raw sewage flow from the collection system into the treatment facility. Sample the wastewater entering the headworks of the treatment plant excluding any side-stream returns from inside the plant. | | | |
| Flow | MGD | Continuous ^a | 24-hr Measurement |
| Biochemical Oxygen Demand (BOD ₅) | mg/L | 1/week | 24-hr Composite ^b |
| BOD ₅ | lbs/day | 1/week | Calculation |
| Total Suspended Solids (TSS) | mg/L | 1/week | 24-hr Composite |
| TSS | lbs/day | 1/week | Calculation |
| (2) Final wastewater effluent | | | |
| Final Wastewater Effluent means wastewater exiting the last treatment process or operation. Typically, this is after or at the exit from the chlorine contact chamber or other disinfection process. The Permittee may take effluent samples for the BOD ₅ analysis before or after the disinfection process. If taken after, the Permittee must dechlorinate and reseed the sample. | | | |
| BOD ₅ ^c | mg/L | 1/week ^d | 24-hr Composite |
| BOD ₅ | lbs/day | 1/week | Calculation ^e |
| BOD ₅ | % removal ^f | 1/month ^h | Calculation |
| TSS | mg/L | 1/week | 24-hr Composite |
| TSS | lbs/day | 1/week | Calculation |
| TSS | % removal ^g | 1/month | Calculation |
| Fecal Coliform ⁱ | # /100 ml | 1/week | Grab ^j |
| pH ^k | Standard Units | 3/week ^l | Grab |
| Temperature ^m | °C | 3/week | Grab |
| Dissolved Oxygen ⁿ | mg/L | 3/week | Grab |
| Total Ammonia | mg/L as N | 1/month | Grab |

THIS PAGE REVISED ON APRIL 8, 2019

| Parameter | Units & Speciation | Minimum Sampling Frequency | Sample Type |
|--|--|----------------------------|-------------|
| (3) Permit renewal application requirements – final wastewater effluent | | | |
| The Permittee must record and report the wastewater treatment plant flow discharged on the day it collects the sample for priority pollutant testing with the discharge monitoring report. | | | |
| Total Kjeldahl Nitrogen | mg/L as N | Once per year ^o | Grab |
| Nitrate plus Nitrite | mg/L as N | Once per year | Grab |
| Oil and Grease | mg/L | Once per year | Grab |
| Phosphorus (Total) | mg/L as P | Once per year | Grab |
| Total Dissolved Solids | mg/L | Once per year | Grab |
| Total Hardness | mg/L | Once per year | Grab |
| Total Alkalinity | mg/L | Once per year | Grab |
| a | Continuous means uninterrupted except for brief lengths of time for calibration, power failure, or unanticipated equipment repair or maintenance. The time interval for the associated data logger must be no greater than 30 minutes. The Permittee must sample every hour during working hours when continuous monitoring is not possible. | | |
| b | 24-hour composite means a series of individual samples collected over a 24-hour period into a single container, and analyzed as one sample. | | |
| c | Take effluent samples for the BOD ₅ analysis after the disinfection process. | | |
| d | 1/week means one (1) time during each calendar week throughout the days of the week, except weekends and holidays. | | |
| e | Calculated means figured concurrently with the respective sample, using the following formula: Concentration (in mg/L) X Flow (in MGD) X Conversion Factor (8.34) = lbs/day | | |
| f | $\left[\left(\frac{\text{Influent Concentration}}{0.7} - \text{Effluent Concentration} \right) \div \frac{\text{Influent Conc.}}{0.7} \right] \times 100$ <p>Calculate the percent (%) removal of BOD₅ using the above equation.</p> | | |
| g | $\left[\left(\frac{\text{Influent Concentration}}{0.1} - \text{Effluent Concentration} \right) \div \frac{\text{Influent Conc.}}{0.1} \right] \times 100$ <p>Calculate the percent (%) removal of TSS using the above equation.</p> | | |
| h | 1/month means one (1) time every calendar month during alternating weeks. | | |
| i | Report a numerical value for fecal coliforms following the procedures in Ecology's <i>Information Manual for Wastewater Treatment Plant Operators</i> , Publication Number 04-10-020 available at: https://fortress.wa.gov/ecy/publications/SummaryPages/0410020.html . Do not report a result as too numerous to count (TNTC). | | |
| j | Grab means an individual sample collected over a fifteen (15) minute, or less, period. | | |

THIS PAGE REVISED ON APRIL 8, 2019

| Parameter | Units & Speciation | Minimum Sampling Frequency | Sample Type |
|-----------|--|----------------------------|-------------|
| k | Report the daily pH and the minimum and maximum for the monitoring period. | | |
| l | 3/week means one (3) times during each calendar week throughout the days of the week, except weekends and holidays. | | |
| m | Temperature grab sampling must occur when the effluent is at or near its daily maximum temperature, which usually occurs in the late afternoon. If measuring temperature continuously, the Permittee must determine and report a daily maximum from half-hour measurements in a 24-hour period. Continuous monitoring instruments must achieve an accuracy of 0.2 degrees C and the Permittee must verify accuracy annually. | | |
| n | Report the daily dissolved oxygen concentration and the minimum for the reporting period. | | |
| o | Once per year means one (1) time every calendar year during alternating months. | | |

S2.B. Sampling and analytical procedures

Samples and measurements taken to meet the requirements of this permit must represent the volume and nature of the monitored parameters. The Permittee must conduct representative sampling of any unusual discharge or discharge condition, including bypasses, upsets, and maintenance-related conditions that may affect effluent quality.

Sampling and analytical methods used to meet the monitoring requirements specified in this permit must conform to the latest revision of the *Guidelines Establishing Test Procedures for the Analysis of Pollutants* contained in 40 CFR Part 136 (or as applicable in 40 CFR subchapters N [Parts 400–471] or O [Parts 501-503]) unless otherwise specified in this permit. Ecology may only specify alternative methods for parameters without permit limits and for those parameters without an EPA approved test method in 40 CFR Part 136.

S2.C. Flow measurement and continuous monitoring devices

The Permittee must:

1. Select and use appropriate flow measurement, continuous monitoring devices and methods consistent with accepted scientific practices.
2. Install, calibrate, and maintain these devices to ensure the accuracy of the measurements is consistent with the accepted industry standard, the manufacturer's recommendation, and approved O&M manual procedures for the device and the wastestream.
3. Calibrate continuous monitoring instruments weekly unless it can demonstrate a longer period is sufficient based on monitoring records.

The Permittee:

- a. May calibrate apparatus for continuous monitoring of dissolved oxygen by air calibration.

- b. Must calibrate continuous pH measurement instruments using a grab sample analyzed in the lab with a pH meter calibrated with standard buffers and analyzed within 15 minutes of sampling.
 - c. Must calibrate continuous chlorine measurement instruments using a grab sample analyzed in the laboratory within 15 minutes of sampling.
4. Calibrate micro-recording temperature devices, known as thermistors, using protocols from Ecology's Quality Assurance Project Plan Development Tool (*Standard Operating Procedures for Continuous Temperature Monitoring of Fresh Water Rivers and Streams Version 1.0 10/26/2011*). This document is available online at:
<https://fortress.wa.gov/ecy/publications/documents/0903122.pdf>

Calibration as specified in this document is not required if the Permittee uses recording devices certified by the manufacturer.

5. Use field measurement devices as directed by the manufacturer and do not use reagents beyond their expiration dates.
6. Calibrate flow-monitoring devices at a minimum frequency of at least one calibration per year.
7. Maintain calibration records for at least three years.

S2.D. Laboratory accreditation

The Permittee must ensure that all monitoring data required by Ecology for permit specified parameters is prepared by a laboratory registered or accredited under the provisions of chapter 173-50 WAC, *Accreditation of Environmental Laboratories*.

Flow, temperature, settleable solids, conductivity, pH, and internal process control parameters are exempt from this requirement.

S2.E. Request for reduction in monitoring

The Permittee may request a reduction of the sampling frequency after twelve (12) months of monitoring. Ecology will review each request and at its discretion grant the request when it reissues the permit or by a permit modification.

The Permittee must:

1. Provide a written request.
2. Clearly state the parameters for which it is requesting reduced monitoring.
3. Clearly state the justification for the reduction.

S3. Reporting and recording requirements

The Permittee must monitor and report in accordance with the following conditions. Falsification of information submitted to Ecology is a violation of the terms and conditions of this permit.

S3.A. Discharge monitoring reports

The first monitoring period begins on **February 1, 2019** (unless otherwise specified). The Permittee must:

1. Summarize, report, and submit monitoring data obtained during each monitoring period on the electronic discharge monitoring report (DMR) form provided by Ecology within the Water Quality Permitting Portal. Include data for each of the parameters tabulated in Special Condition S2 and as required by the form. Report a value for each day sampling occurred (unless specifically exempted in the permit) and for the summary values (when applicable) included on the electronic form.

To find out more information and to sign up for the Water Quality Permitting Portal go to:

<http://www.ecy.wa.gov/programs/wq/permits/paris/webdmr.html>

2. Ensure that DMRs are electronically submitted no later than the dates specified below, unless otherwise specified in this permit.
3. Submit DMRs for parameters with the monitoring frequencies specified in S2 (monthly, quarterly, annual, etc.) at the reporting schedule identified below. The Permittee must:
 - a. Submit **monthly** DMRs by the 15th day of the following month.
 - b. Submit permit renewal application monitoring data **annually** by **January 15** for the previous calendar year, in WQWebDMR as required in Special Condition S2.
4. Enter the “No Discharge” reporting code for an entire DMR, for a specific monitoring point, or for a specific parameter as appropriate, if the Permittee did not discharge wastewater or a specific pollutant during a given monitoring period.

5. Report single analytical values below detection as “less than the detection level (DL)” by entering < followed by the numeric value of the detection level (e.g. < 2.0) on the DMR. If the method used did not meet the minimum DL and quantitation level (QL) identified in the permit, report the actual QL and DL in the comments or in the location provided.
6. Report single analytical values between the detection level (DL) and the quantitation level (QL) by entering the estimated value, the code for estimated value/below quantitation limit (j) and any additional information in the comments. Submit a copy of the laboratory report as an attachment using WQWebDMR.
7. **Not** report zero for bacteria monitoring. Report as required by the laboratory method.
8. Calculate and report an arithmetic average value for each day for bacteria if multiple samples were taken in one day.
9. Calculate the geometric mean values for bacteria (unless otherwise specified in the permit) using:
 - a. The reported numeric value for all bacteria samples measured above the detection value except when it took multiple samples in one day. If the Permittee takes multiple samples in one day it must use the arithmetic average for the day in the geometric mean calculation.
 - b. The detection value for those samples measured below detection.
10. Report the test method used for analysis in the comments if the laboratory used an alternative method not specified in the permit and as allowed in Appendix A.
11. Calculate average values and calculated total values (unless otherwise specified in the permit) using:
 - a. The reported numeric value for all parameters measured between the detection value and the quantitation value for the sample analysis.
 - b. One-half the detection value (for values reported below detection) if the lab detected the parameter in another sample from the same monitoring point for the reporting period.

- c. Zero (for values reported below detection) if the lab did not detect the parameter in another sample for the reporting period.
12. Report single-sample grouped parameters (for example: priority pollutants, PAHs, pulp and paper chlorophenolics, TTOs) on the WQWebDMR form and include: sample date, concentration detected, detection limit (DL) (as necessary), and laboratory quantitation level (QL) (as necessary).

S3.B. Permit submittals and schedules

The Permittee must use the Water Quality Permitting Portal – Permit Submittals application (unless otherwise specified in the permit) to submit all other written permit-required reports by the date specified in the permit.

When another permit condition requires submittal of a paper (hard-copy) report, the Permittee must ensure that it is postmarked or received by Ecology no later than the dates specified by this permit. Send these paper reports to Ecology at:

Water Quality Permit Coordinator
Department of Ecology
Central Regional Office
1250 West Alder Street
Union Gap, WA 98903

S3.C. Records retention

The Permittee must retain records of all monitoring information for a minimum of three (3) years. Such information must include all calibration and maintenance records and all original recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit. The Permittee must extend this period of retention during the course of any unresolved litigation regarding the discharge of pollutants by the Permittee or when requested by Ecology.

S3.D. Recording of results

For each measurement or sample taken, the Permittee must record the following information:

1. The date, exact place, method, and time of sampling or measurement.

2. The individual who performed the sampling or measurement.
3. The dates the analyses were performed.
4. The individual who performed the analyses.
5. The analytical techniques or methods used.
6. The results of all analyses.

S3.E. Additional monitoring by the Permittee

If the Permittee monitors any pollutant more frequently than required by Special Condition S2 of this permit, then the Permittee must include the results of such monitoring in the calculation and reporting of the data submitted in the Permittee's DMR unless otherwise specified by Special Condition S2.

S3.F. Reporting permit violations

The Permittee must take the following actions when it violates or is unable to comply with any permit condition:

1. Immediately take action to stop, contain, and cleanup unauthorized discharges or otherwise stop the noncompliance and correct the problem.
2. If applicable, immediately repeat sampling and analysis. Submit the results of any repeat sampling to Ecology within thirty (30) days of sampling.

a. Immediate reporting

The Permittee must immediately report to Ecology (at the numbers listed below), all:

- Failures of the disinfection system.
- Collection system overflows.
- Plant bypasses resulting in a discharge.
- Any other failures of the sewage system (pipe breaks, etc.).

| | |
|-------------------------|--------------|
| Central Regional Office | 509-575-2490 |
| Yakima Health District | 509-575-4040 |

b. Twenty-four-hour reporting

The Permittee must report the following occurrences of noncompliance by telephone, to Ecology at the telephone number listed above, within 24 hours from the time the Permittee becomes aware of any of the following circumstances:

1. Any noncompliance that may endanger health or the environment, unless previously reported under immediate reporting requirements.
2. Any unanticipated bypass that causes an exceedance of an effluent limit in the permit (See Part S5.F, "Bypass Procedures").
3. Any upset that causes an exceedance of an effluent limit in the permit (See G.15, "Upset").
4. Any violation of a maximum daily or instantaneous maximum discharge limit for any of the pollutants in Section S1.A of this permit.
5. Any overflow prior to the treatment works, whether or not such overflow endangers health or the environment or exceeds any effluent limit in the permit.

c. Report within five days

The Permittee must also submit a written report within five days of the time that the Permittee becomes aware of any reportable event under subparts a or b, above. The report must contain:

1. A description of the noncompliance and its cause.
2. The period of noncompliance, including exact dates and times.
3. The estimated time the Permittee expects the noncompliance to continue if not yet corrected.
4. Steps taken or planned to reduce, eliminate, and prevent recurrence of the noncompliance.
5. If the noncompliance involves an overflow prior to the treatment works, an estimate of the quantity (in gallons) of untreated overflow.

d. Waiver of written reports

Ecology may waive the written report required in subpart c, above, on a case-by-case basis upon request if the Permittee has submitted a timely oral report.

e. All other permit violation reporting

The Permittee must report all permit violations, which do not require immediate or within 24 hours reporting, when it submits monitoring reports for S3.A ("Reporting"). The reports must contain the information listed in subpart c, above. Compliance with these requirements does not relieve the Permittee from responsibility to maintain continuous compliance with the terms and conditions of this permit or the resulting liability for failure to comply.

S3.G. Other reporting

a. Spills of Oil or Hazardous Materials

The Permittee must report a spill of oil or hazardous materials in accordance with the requirements of RCW 90.56.280 and chapter 173-303-145. You can obtain further instructions at the following website: <https://ecology.wa.gov/About-us/Get-involved/Report-an-environmental-issue/Report-a-spill>.

b. Failure to submit relevant or correct facts

Where the Permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application, or in any report to Ecology, it must submit such facts or information promptly.

S3.H. Maintaining a copy of this permit

The Permittee must keep a copy of this permit at the facility and make it available upon request to Ecology inspectors.

S4. Facility loading

S4.A. Design criteria

The flows or waste loads for the permitted facility must not exceed the following design criteria:

| | |
|---|-------------|
| Maximum Month Design Flow (MMDF) | 0.120 MGD |
| BOD ₅ Influent Loading for Maximum Month | 214 lbs/day |
| TSS Influent Loading for Maximum Month | 126 lbs/day |

S4.B. Plans for maintaining adequate capacity

a. Conditions triggering plan submittal

The Permittee must submit a plan and a schedule for continuing to maintain capacity to Ecology when:

1. The actual flow or waste load reaches 85 percent of any one of the design criteria in S4.A for three consecutive months.
2. The projected plant flow or loading would reach design capacity within five years.

b. Plan and schedule content

The plan and schedule must identify the actions necessary to maintain adequate capacity for the expected population growth and to meet the limits and requirements of the permit. The Permittee must consider the following topics and actions in its plan.

1. Analysis of the present design and proposed process modifications
2. Reduction or elimination of excessive infiltration and inflow of uncontaminated ground and surface water into the sewer system
3. Limits on future sewer extensions or connections or additional waste loads
4. Modification or expansion of facilities
5. Reduction of industrial or commercial flows or waste loads

Engineering documents associated with the plan must meet the requirements of WAC 173-240-060, "Engineering Report," and be approved by Ecology prior to any construction.

S4.C. Duty to mitigate

The Permittee must take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this permit that has a reasonable likelihood of adversely affecting human health or the environment.

S4.D. Notification of new or altered sources

1. The Permittee must submit written notice to Ecology whenever any new discharge or a substantial change in volume or character of an

existing discharge into the wastewater treatment plant is proposed which:

- a. Would interfere with the operation of, or exceed the design capacity of, any portion of the wastewater treatment plant.
 - b. Is not part of an approved general sewer plan or approved plans and specifications.
 - c. Is subject to pretreatment standards under 40 CFR Part 403 and Section 307(b) of the Clean Water Act.
2. This notice must include an evaluation of the wastewater treatment plant's ability to adequately transport and treat the added flow and/or waste load, the quality and volume of effluent to be discharged to the treatment plant, and the anticipated impact on the Permittee's effluent [40 CFR 122.42(b)].

S4.E. Infiltration and inflow evaluation

1. The Permittee must conduct an infiltration and inflow evaluation. Refer to the U.S. EPA publication, I/I Analysis and Project Certification, available as Publication No. 97-03 at:
<https://fortress.wa.gov/ecy/publications/SummaryPages/9703.html>
2. The Permittee may use monitoring records to assess measurable infiltration and inflow.
3. The Permittee must prepare a report summarizing any measurable infiltration and inflow. If infiltration and inflow have increased by more than 15 percent from that found in the previous report based on equivalent rainfall, the report must contain a plan and a schedule to locate the sources of infiltration and inflow and to correct the problem.
4. The Permittee must submit a report summarizing the results of the evaluation and any recommendations for corrective actions by **December 31, 2022**.

S4.F. Wasteload assessment

The Permittee must conduct an annual assessment of its influent flow and waste load and submit a report to Ecology by **December 31, 2022**. The report must contain:

1. A description of compliance or noncompliance with the permit effluent limits.
2. A comparison between the existing and design:
 - a. Monthly average dry weather and wet weather flows.
 - b. Peak flows.
 - c. BOD₅ loading.
 - d. Total suspended solids loadings.
3. The percent change in the above parameters since the previous report (except for the first report).
4. The present and design population or population equivalent.
5. The projected population growth rate.
6. The estimated date upon which the Permittee expects the wastewater treatment plant to reach design capacity, according to the most restrictive of the parameters above.

Ecology may modify the interval for review and reporting if it determines that a different frequency is sufficient.

S5. Operation and maintenance

The Permittee must at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances), which are installed to achieve compliance with the terms and conditions of this permit. Proper operation and maintenance also includes keeping a daily operation logbook (paper or electronic), adequate laboratory controls, and appropriate quality assurance procedures. This provision of the permit requires the Permittee to operate backup or auxiliary facilities or similar systems only when the operation is necessary to achieve compliance with the conditions of this permit.

S5.A. Certified operator

This permitted facility must be operated by an operator certified by the state of Washington for at least a Class II plant. This operator must be in responsible charge of the day-to-day operation of the wastewater treatment plant. An operator certified for at least a Class I plant must be in charge during all regularly scheduled shifts. The Permittee must notify Ecology when the operator in charge at the facility changes. It must provide the new operator's name and certification level and provide the name of the operator leaving the facility.

S5.B. Operation and maintenance program

The Permittee must:

1. Institute an adequate operation and maintenance program for the entire sewage system.
2. Keep maintenance records on all major electrical and mechanical components of the treatment plant, as well as the sewage system and pumping stations. Such records must clearly specify the frequency and type of maintenance recommended by the manufacturer and must show the frequency and type of maintenance performed.
3. Make maintenance records available for inspection at all times.

S5.C. Short-term reduction

The Permittee must schedule any facility maintenance, which might require interruption of wastewater treatment and degrade effluent quality, during non-critical water quality periods and carry this maintenance out according to the approved O&M manual or as otherwise approved by Ecology.

If a Permittee contemplates a reduction in the level of treatment that would cause a violation of permit discharge limits on a short-term basis for any reason, and such reduction cannot be avoided, the Permittee must:

1. Give written notification to Ecology, if possible, thirty (30) days prior to such activities.
2. Detail the reasons for, length of time of, and the potential effects of the reduced level of treatment.

This notification does not relieve the Permittee of its obligations under this permit.

S5.D. Electrical power failure

The Permittee must ensure that adequate safeguards prevent the discharge of untreated wastes or wastes not treated in accordance with the requirements of this permit during electrical power failure at the treatment plant and/or sewage lift stations. Adequate safeguards include, but are not limited to, alternate power sources, standby generator(s), or retention of inadequately treated wastes.

The Permittee must maintain Reliability Class III (EPA 430-99-74-001) at the wastewater treatment plant. Reliability Class III requires a backup power source sufficient to operate the screening or comminution facilities, the main wastewater pumps, the primary sedimentation basins, the disinfection facility, and critical lighting and ventilation during peak wastewater flows.

S5.E. Prevent connection of inflow

The Permittee must strictly enforce its sewer ordinances and not allow the connection of inflow (roof drains, foundation drains, etc.) to the sanitary sewer system.

S5.F. Bypass procedures

A bypass is the intentional diversion of waste streams from any portion of a treatment facility. This permit prohibits all bypasses except when the bypass is for essential maintenance, as authorized in special condition S5.F.1, or is approved by Ecology as an anticipated bypass following the procedures in S5.F.2.

1. Bypass for essential maintenance without the potential to cause violation of permit limits or conditions.

This permit allows bypasses for essential maintenance of the treatment system when necessary to ensure efficient operation of the system. The Permittee may bypass the treatment system for essential maintenance only if doing so does not cause violations of effluent limits. The Permittee is not required to notify Ecology when bypassing for essential maintenance. However the Permittee must comply with the monitoring requirements specified in special condition S2.B.

2. Anticipated bypasses for non-essential maintenance

Ecology may approve an anticipated bypass under the conditions listed below. This permit prohibits any anticipated bypass that is not approved through the following process.

- a. If a bypass is for non-essential maintenance, the Permittee must notify Ecology, if possible, at least ten (10) days before the planned date of bypass. The notice must contain:

- A description of the bypass and the reason the bypass is necessary.
 - An analysis of all known alternatives which would eliminate, reduce, or mitigate the potential impacts from the proposed bypass.
 - A cost-effectiveness analysis of alternatives.
 - The minimum and maximum duration of bypass under each alternative.
 - A recommendation as to the preferred alternative for conducting the bypass.
 - The projected date of bypass initiation.
 - A statement of compliance with SEPA.
 - A request for modification of water quality standards as provided for in WAC 173-201A-410, if an exceedance of any water quality standard is anticipated.
 - Details of the steps taken or planned to reduce, eliminate, and prevent recurrence of the bypass.
- b. For probable construction bypasses, the Permittee must notify Ecology of the need to bypass as early in the planning process as possible. The Permittee must consider the analysis required above during the project planning and design process. The project-specific engineering report as well as the plans and specifications must include details of probable construction bypasses to the extent practical. In cases where the Permittee determines the probable need to bypass early, the Permittee must continue to analyze conditions up to and including the construction period in an effort to minimize or eliminate the bypass.
- c. Ecology will determine if the Permittee has met the conditions of special condition S5.F.2 a and b and consider the following prior to issuing a determination letter, an administrative order, or a permit modification as appropriate for an anticipated bypass:
- If the Permittee planned and scheduled the bypass to minimize adverse effects on the public and the environment.
 - If the bypass is unavoidable to prevent loss of life, personal injury, or severe property damage. "Severe property damage" means substantial physical damage to property, damage to the treatment facilities which would cause them to become inoperable, or substantial and permanent loss of natural

resources which can reasonably be expected to occur in the absence of a bypass.

- If feasible alternatives to the bypass exist, such as:
 - The use of auxiliary treatment facilities.
 - Retention of untreated wastes.
 - Stopping production.
 - Maintenance during normal periods of equipment downtime, but not if the Permittee should have installed adequate backup equipment in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventative maintenance.
 - Transport of untreated wastes to another treatment facility.

S5.G. Operations and maintenance (O&M) manual

a. O&M manual submittal and requirements

The Permittee must:

1. Prepare a new Operations and Maintenance (O&M) manual that meets the requirements of 173-240-080 WAC and submit it to Ecology for approval by **January 1, 2021**.
2. Review the O&M Manual at least once per permit cycle and confirm this review by letter to Ecology by **June 1, 2022**.
3. Submit to Ecology for review and approval substantial changes or updates to the O&M Manual whenever it incorporates them into the manual.
4. Keep the approved O&M Manual at the permitted facility.
5. Follow the instructions and procedures of this manual.

b. O&M manual components

In addition to the requirements of WAC 173-240-080(1) through (5), the O&M Manual must be consistent with the guidance in Table G1-3 in the *Criteria for Sewage Works Design* (Orange Book), 2008. The O&M Manual must include:

1. Emergency procedures for cleanup in the event of wastewater system upset or failure.

2. A review of system components which if failed could pollute surface water or could impact human health. Provide a procedure for a routine schedule of checking the function of these components.
3. Wastewater system maintenance procedures that contribute to the generation of process wastewater.
4. Reporting protocols for submitting reports to Ecology to comply with the reporting requirements in the discharge permit.
5. Any directions to maintenance staff when cleaning or maintaining other equipment or performing other tasks which are necessary to protect the operation of the wastewater system (for example, defining maximum allowable discharge rate for draining a tank, blocking all floor drains before beginning the overhaul of a stationary engine).
6. The treatment plant process control monitoring schedule.
7. Minimum staffing adequate to operate and maintain the treatment processes and carry out compliance monitoring required by the permit.
8. Flow meter calibration frequency.

S6. Pretreatment

S6.A. General requirements

The Permittee must work with Ecology to ensure that all commercial and industrial users of the publicly owned treatment works (POTW) comply with the pretreatment regulations in 40 CFR Part 403 and any additional regulations that the Environmental Protection Agency (U.S. EPA) may promulgate under Section 307(b) (pretreatment) and 308 (reporting) of the Federal Clean Water Act.

S6.B. Duty to enforce discharge prohibitions

1. Under federal regulations (40 CFR 403.5(a) and (b)), the Permittee must not authorize or knowingly allow the discharge of any pollutants into its POTW which may be reasonably expected to cause pass through or interference, or which otherwise violate general or specific discharge prohibitions contained in 40 CFR Part 403.5 or WAC 173-216-060.
2. The Permittee must not authorize or knowingly allow the introduction of any of the following into their treatment works:
 - a. Pollutants which create a fire or explosion hazard in the POTW (including, but not limited to waste streams with a closed cup flashpoint of less than 140 degrees Fahrenheit or 60 degrees Centigrade using the test methods specified in 40 CFR 261.21).

- b. Pollutants which will cause corrosive structural damage to the POTW, but in no case discharges with pH lower than 5.0, or greater than 11.0 standard units, unless the works are specifically designed to accommodate such discharges.
 - c. Solid or viscous pollutants in amounts that could cause obstruction to the flow in sewers or otherwise interfere with the operation of the POTW.
 - d. Any pollutant, including oxygen-demanding pollutants, (BOD₅, etc.) released in a discharge at a flow rate and/or pollutant concentration which will cause interference with the POTW.
 - e. Petroleum oil, non-biodegradable cutting oil, or products of mineral origin in amounts that will cause interference or pass through.
 - f. Pollutants which result in the presence of toxic gases, vapors, or fumes within the POTW in a quantity which may cause acute worker health and safety problems.
 - g. Heat in amounts that will inhibit biological activity in the POTW resulting in interference but in no case heat in such quantities such that the temperature at the POTW headworks exceeds 40 degrees Centigrade (104 degrees Fahrenheit) unless Ecology, upon request of the Permittee, approves, in writing, alternate temperature limits.
 - h. Any trucked or hauled pollutants, except at discharge points designated by the Permittee.
 - i. Wastewaters prohibited to be discharged to the POTW by the Dangerous Waste Regulations (chapter 173-303 WAC), unless authorized under the Domestic Sewage Exclusion (WAC 173-303-071).
3. The Permittee must also not allow the following discharges to the POTW unless approved in writing by Ecology:
- a. Noncontact cooling water in significant volumes.
 - b. Stormwater and other direct inflow sources.
 - c. Wastewaters significantly affecting system hydraulic loading, which do not require treatment, or would not be afforded a significant degree of treatment by the system.
4. The Permittee must notify Ecology if any industrial user violates the prohibitions listed in this section (S6.B), and initiate enforcement action to promptly curtail any such discharge.

S6.C. Wastewater discharge permit required

The Permittee must:

- 1. Establish a process for authorizing non-domestic wastewater discharges that ensures all SIUs in all tributary areas meet the

applicable state waste discharge permit (SWDP) requirements in accordance with chapter 90.48 RCW and chapter 173-216 WAC.

2. Immediately notify Ecology of any proposed discharge of wastewater from a source, which may be a significant industrial user (SIU) [see fact sheet definitions or refer to 40 CFR 403.3(v)(i)(ii)].
3. Require all SIUs to obtain a SWDP from Ecology prior to accepting their non-domestic wastewater, or require proof that Ecology has determined they do not require a permit.
4. Require the documentation as described in S6.C.3 at the earliest practicable date as a condition of continuing to accept non-domestic wastewater discharges from a previously undiscovered, currently discharging and unpermitted SIU.
5. Require sources of non-domestic wastewater, which do not qualify as SIUs but merit a degree of oversight, to apply for a SWDP and provide it a copy of the application and any Ecology responses.
6. Keep all records documenting that its users have met the requirements of S6.C.

S6.D. Identification and reporting of existing, new, and proposed industrial users

1. The Permittee must take continuous, routine measures to identify all existing, new, and proposed SIUs and potential significant industrial users (PSIUs) discharging or proposing to discharge to the Permittee's sewer system (see **Appendix C** of the fact sheet for definitions).
2. Within 30 days of becoming aware of an unpermitted existing, new, or proposed industrial user who may be a significant industrial user (SIU), the Permittee must notify such user by registered mail that, if classified as an SIU, they must apply to Ecology and obtain a State Waste Discharge Permit. The Permittee must send a copy of this notification letter to Ecology within this same 30-day period.
3. The Permittee must also notify all Potential SIUs (PSIUs), as they are identified, that if their classification should change to an SIU, they must apply to Ecology for a State Waste Discharge Permit within 30 days of such change.

S7. Solid wastes

S7.A. Solid waste handling

The Permittee must handle and dispose of all solid waste material in such a manner as to prevent its entry into state ground or surface water.

S7.B. Leachate

The Permittee must not allow leachate from its solid waste material to enter state waters without providing all known, available, and reasonable

methods of treatment, nor allow such leachate to cause violations of the State Surface Water Quality Standards, Chapter 173-201A WAC, or the State Ground Water Quality Standards, Chapter 173-200 WAC. The Permittee must apply for a permit or permit modification as may be required for such discharges to state ground or surface waters.

S8. Application for permit renewal or modification for facility changes

The Permittee must submit an application for renewal of this permit by **January 31, 2023**.

The Permittee must also submit a new application or addendum at least one hundred eighty (180) days prior to commencement of discharges, resulting from the activities listed below, which may result in permit violations. These activities include any facility expansions, production increases, or other planned changes, such as process modifications, in the permitted facility.

S9. Spill control plan

S9.A Spill control plan submittals and requirements

The Permittee must:

1. Submit to Ecology a spill control plan for the prevention, containment, and control of spills or unplanned releases of pollutants by **January 1, 2020**.
2. Review the plan at least annually and update the spill plan as needed.
3. Send changes to the plan to Ecology.
4. Follow the plan and any supplements throughout the term of the permit.

S9.B. Spill control plan components

The spill control plan must include the following:

1. A list of all oil and petroleum products and other materials used and/or stored on-site, which when spilled, or otherwise released into the environment, designate as Dangerous Waste (DW) or Extremely Hazardous Waste (EHW) by the procedures set forth in WAC 173-303-070. Include other materials used and/or stored on-site which may become pollutants or cause pollution upon reaching state's waters.

2. A description of preventive measures and facilities (including an overall facility plot showing drainage patterns) which prevent, contain, or treat spills of these materials.
3. A description of the reporting system the Permittee will use to alert responsible managers and legal authorities in the event of a spill.
4. A description of operator training to implement the plan.

The Permittee may submit plans and manuals required by 40 CFR Part 112, contingency plans required by Chapter 173-303 WAC, or other plans required by other agencies, which meet the intent of this section.

S10. Receiving water study

The Permittee must collect receiving water information necessary to determine if the effluent has a reasonable potential to cause a violation of the water quality standards. If reasonable potential to cause a violation of the standards exists, Ecology will use the study information to calculate effluent limits.

The Permittee must:

1. Submit a *sampling and quality assurance plan* for Ecology review and approval by **August 1, 2019**. Prepare all quality assurance plans in accordance with the guidelines given in *Guidelines for Preparing Quality Assurance Project Plans for Environmental Studies*, Ecology Publication 04-03-030. This document is available at: <https://fortress.wa.gov/ecy/publications/documents/0403030.pdf>. The *Plan* must consider options for continuous pH monitoring of the receiving water.
2. The receiving water study will be conducted during the critical season (**May-Sept**) of years **2020, 2021, 2022**.
3. Conduct all sampling and analysis in accordance with the approved quality assurance project plan.
 - a. Locate a receiving water sampling location outside the zone of influence of the effluent (upstream from the outfall).
 - b. Locate another receiving water sampling location downstream from the outfall where the effluent is completely mixed with the receiving waterway.
 - c. Use sampling station location accuracy requirements of ± 10 meters.
 - d. Sampling will be performed during the critical period (May-Sept).
 - e. Collect monthly receiving water grab samples (upstream and downstream) during each month of the critical period, and analyze the samples for dissolved oxygen, total suspended solids, fecal coliforms, total ammonia, total Kjeldahl nitrogen (TKN), Nitrate + Nitrite nitrogen (as N), total phosphorus, hardness, and alkalinity.
 - f. Collect weekly receiving water stream flow values. An Ecology published document (*Estimating Discharge and Stream Flows*, Ecology Publication

Number 05-10-070) contains protocols for measuring stream flows. This document is available online at

<https://fortress.wa.gov/ecy/publications/documents/0510070.pdf>

- g. Conduct all chemical analysis using the methods and the detection levels identified in Appendix A.
4. Measure temperature in the ambient water during the critical period (May-Sept) at the same locations determined above in (S10.3. a, b).
A model Quality Assurance Plan specific for temperature is available at <http://www.ecy.wa.gov/programs/wq/permits/guidance.html>.
 - a. Use micro-recording temperature devices known as thermistors to measure temperature. Ecology's Quality Assurance Project Plan Development Tool (*Standard Operating Procedures for Continuous Temperature Monitoring of Fresh Water Rivers and Streams*) contains protocols for continuous temperature sampling. This document is available online at http://www.ecy.wa.gov/programs/eap/qa/docs/ECY_EAP_SOP_Cont_Temp_Mon_Ambient_v1_0EAP080.pdf.

Calibrate the devices as specified in this document unless using recording devices certified by the manufacturer. Ecology does not require manufacture-specific equipment as given in this document; however, if the Permittee wishes to use measuring devices from another company, it must demonstrate the accuracy is equivalent.
 - b. Set the recording devices to record at one-half-hour intervals.
 - c. Report temperature monitoring data as: daily maximum, seven-day running average of the daily maximums, and the monthly maximum of the seven-day running average. The model Quality Assurance Plan shows an example of these calculations.
 - d. Submit the temperature data for each month at the time of submittal of the discharge monitoring reports during the critical period (May-Sept) (**October 15 for years 2020, 2021, 2022**). The discharge monitoring report will be modified to allow for proper reporting of temperature monitoring data to be reported (S10.4.c.).
5. Submit the critical period report conducted each year, summarizing the results of the study to Ecology by the 15th day of October of that sampling year. The report must document when the data was successfully loaded into Environmental Information Management System (EIM)
6. Data must be submitted to EIM. Data must be submitted to EIM according to the instructions on the EIM website. The data submittal portion of the EIM website (<https://ecology.wa.gov/Research-Data/Data-resources/Environmental-Information-Management-database/EIM-submit-data>) provides information and help on formats and requirements for

submitting tabular data. Specific questions about data submittal may be directed to the EIM Data Coordinator.

Any subsequent sampling and analysis must also meet these requirements. The Permittee may conduct a cooperative receiving water study with other NPDES Permittees discharging in the same vicinity.

S11. Outfall evaluation

The Permittee must inspect, once per permit cycle, the submerged portion of the outfall line and diffuser to document its integrity and continued function. If conditions allow for a photographic verification, the Permittee must include such verification in the report.

The Permittee must submit the outfall evaluation to Ecology through the Water Quality Permitting Portal – Permit Submittals application by **February 1, 2020**.

The inspector must at minimum:

- Assess the physical condition of the outfall pipe, diffuser, and associated couplings.
- Determine the extent of sediment accumulation in the vicinity of the diffuser.
- Ensure the diffuser port is free of obstructions and are allowing uniform flow.
- Confirm physical location (latitude/longitude) and depth of the diffuser section of the outfall.

General Conditions

G1. Signatory requirements

1. All applications submitted to Ecology must be signed and certified.
 - a. In the case of corporations, by a responsible corporate officer. For the purpose of this section, a responsible corporate officer means:
 - A president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy or decision making functions for the corporation, or
 - The manager of one or more manufacturing, production, or operating facilities, provided, the manager is authorized to make management decisions which govern the operation of the regulated facility including

having the explicit or implicit duty of making major capital investment recommendations, and initiating and directing other comprehensive measures to assure long-term environmental compliance with environmental laws and regulations; the manager can ensure that the necessary systems are established or actions taken to gather complete and accurate information for permit application requirements; and where authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures.

- b. In the case of a partnership, by a general partner.
- c. In the case of sole proprietorship, by the proprietor.
- d. In the case of a municipal, state, or other public facility, by either a principal executive officer or ranking elected official.

Applications for permits for domestic wastewater facilities that are either owned or operated by, or under contract to, a public entity shall be submitted by the public entity.

- 2. All reports required by this permit and other information requested by Ecology must be signed by a person described above or by a duly authorized representative of that person. A person is a duly authorized representative only if:
 - a. The authorization is made in writing by a person described above and submitted to Ecology.
 - b. The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility, such as the position of plant manager, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters. (A duly authorized representative may thus be either a named individual or any individual occupying a named position.)
- 3. Changes to authorization. If an authorization under paragraph G1.2, above, is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of paragraph G1.2, above, must be submitted to Ecology prior to or together with any reports, information, or applications to be signed by an authorized representative.
- 4. Certification. Any person signing a document under this section must make the following certification:

"I certify under penalty of law, that this document and all attachments were

prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gathered and evaluated the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.”

G2. Right of inspection and entry

The Permittee must allow an authorized representative of Ecology, upon the presentation of credentials and such other documents as may be required by law:

1. To enter upon the premises where a discharge is located or where any records must be kept under the terms and conditions of this permit.
2. To have access to and copy, at reasonable times and at reasonable cost, any records required to be kept under the terms and conditions of this permit.
3. To inspect, at reasonable times, any facilities, equipment (including monitoring and control equipment), practices, methods, or operations regulated or required under this permit.
4. To sample or monitor, at reasonable times, any substances or parameters at any location for purposes of assuring permit compliance or as otherwise authorized by the Clean Water Act.

G3. Permit actions

This permit may be modified, revoked and reissued, or terminated either at the request of any interested person (including the Permittee) or upon Ecology's initiative. However, the permit may only be modified, revoked and reissued, or terminated for the reasons specified in 40 CFR 122.62, 40 CFR 122.64 or WAC 173-220-150 according to the procedures of 40 CFR 124.5.

1. The following are causes for terminating this permit during its term, or for denying a permit renewal application:
 - a. Violation of any permit term or condition.
 - b. Obtaining a permit by misrepresentation or failure to disclose all relevant facts.
 - c. A material change in quantity or type of waste disposal.

- d. A determination that the permitted activity endangers human health or the environment, or contributes to water quality standards violations and can only be regulated to acceptable levels by permit modification or termination.
 - e. A change in any condition that requires either a temporary or permanent reduction, or elimination of any discharge or sludge use or disposal practice controlled by the permit.
 - f. Nonpayment of fees assessed pursuant to RCW 90.48.465.
 - g. Failure or refusal of the Permittee to allow entry as required in RCW 90.48.090.
2. The following are causes for modification but not revocation and reissuance except when the Permittee requests or agrees:
- a. A material change in the condition of the waters of the state.
 - b. New information not available at the time of permit issuance that would have justified the application of different permit conditions.
 - c. Material and substantial alterations or additions to the permitted facility or activities which occurred after this permit issuance.
 - d. Promulgation of new or amended standards or regulations having a direct bearing upon permit conditions, or requiring permit revision.
 - e. The Permittee has requested a modification based on other rationale meeting the criteria of 40 CFR Part 122.62.
 - f. Ecology has determined that good cause exists for modification of a compliance schedule, and the modification will not violate statutory deadlines.
 - g. Incorporation of an approved local pretreatment program into a municipality's permit.
3. The following are causes for modification or alternatively revocation and reissuance:
- a. When cause exists for termination for reasons listed in 1.a through 1.g of this section, and Ecology determines that modification or revocation and reissuance is appropriate.
 - b. When Ecology has received notification of a proposed transfer of the permit. A permit may also be modified to reflect a transfer after the effective date of an automatic transfer (General Condition G7) but will not be revoked and reissued after the effective date of the transfer except upon the request of the new Permittee.

G4. Reporting planned changes

The Permittee must, as soon as possible, but no later than one hundred eighty (180) days prior to the proposed changes, give notice to Ecology of planned physical alterations or additions to the permitted facility, production increases, or process modification which will result in:

1. The permitted facility being determined to be a new source pursuant to 40 CFR 122.29(b).
2. A significant change in the nature or an increase in quantity of pollutants discharged.
3. A significant change in the Permittee's sludge use or disposal practices. Following such notice, and the submittal of a new application or supplement to the existing application, along with required engineering plans and reports, this permit may be modified, or revoked and reissued pursuant to 40 CFR 122.62(a) to specify and limit any pollutants not previously limited. Until such modification is effective, any new or increased discharge in excess of permit limits or not specifically authorized by this permit constitutes a violation.

G5. Plan review required

Prior to constructing or modifying any wastewater control facilities, an engineering report and detailed plans and specifications must be submitted to Ecology for approval in accordance with chapter 173-240 WAC. Engineering reports, plans, and specifications must be submitted at least one hundred eighty (180) days prior to the planned start of construction unless a shorter time is approved by Ecology. Facilities must be constructed and operated in accordance with the approved plans.

G6. Compliance with other laws and statutes

Nothing in this permit excuses the Permittee from compliance with any applicable federal, state, or local statutes, ordinances, or regulations.

G7. Transfer of this permit

In the event of any change in control or ownership of facilities from which the authorized discharge emanate, the Permittee must notify the succeeding owner or controller of the existence of this permit by letter, a copy of which must be forwarded to Ecology.

1. Transfers by Modification

Except as provided in paragraph (2) below, this permit may be transferred by the Permittee to a new owner or operator only if this permit has been modified or revoked and reissued under 40 CFR 122.62(b)(2), or a minor modification made under 40 CFR 122.63(d), to identify the new Permittee and incorporate such other requirements as may be necessary under the Clean Water Act.

2. Automatic Transfers

This permit may be automatically transferred to a new Permittee if:

- a. The Permittee notifies Ecology at least thirty (30) days in advance of the proposed transfer date.
- b. The notice includes a written agreement between the existing and new Permittees containing a specific date transfer of permit responsibility, coverage, and liability between them.
- c. Ecology does not notify the existing Permittee and the proposed new Permittee of its intent to modify or revoke and reissue this permit. A modification under this subparagraph may also be minor modification under 40 CFR 122.63. If this notice is not received, the transfer is effective on the date specified in the written agreement.

G8. Reduced production for compliance

The Permittee, in order to maintain compliance with its permit, must control production and/or all discharges upon reduction, loss, failure, or bypass of the treatment facility until the facility is restored or an alternative method of treatment is provided. This requirement applies in the situation where, among other things, the primary source of power of the treatment facility is reduced, lost, or fails.

G9. Removed substances

Collected screenings, grit, solids, sludges, filter backwash, or other pollutants removed in the course of treatment or control of wastewaters must not be resuspended or reintroduced to the final effluent stream for discharge to state waters.

G10. Duty to provide information

The Permittee must submit to Ecology, within a reasonable time, all information which Ecology may request to determine whether cause exists for modifying,

revoking and reissuing, or terminating this permit or to determine compliance with this permit. The Permittee must also submit to Ecology upon request, copies of records required to be kept by this permit.

G11. Other requirements of 40 CFR

All other requirements of 40 CFR 122.41 and 122.42 are incorporated in this permit by reference.

G12. Additional monitoring

Ecology may establish specific monitoring requirements in addition to those contained in this permit by administrative order or permit modification.

G13. Payment of fees

The Permittee must submit payment of fees associated with this permit as assessed by Ecology.

G14. Penalties for violating permit conditions

Any person who is found guilty of willfully violating the terms and conditions of this permit is deemed guilty of a crime, and upon conviction thereof shall be punished by a fine of up to ten thousand dollars (\$10,000) and costs of prosecution, or by imprisonment in the discretion of the court. Each day upon which a willful violation occurs may be deemed a separate and additional violation.

Any person who violates the terms and conditions of a waste discharge permit may incur, in addition to any other penalty as provided by law, a civil penalty in the amount of up to ten thousand dollars (\$10,000) for every such violation. Each and every such violation is a separate and distinct offense, and in case of a continuing violation, every day's continuance is deemed to be a separate and distinct violation.

G15. Upset

Definition – “Upset” means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limits because of factors beyond the reasonable control of the Permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of

preventive maintenance, or careless or improper operation.

An upset constitutes an affirmative defense to an action brought for noncompliance with such technology-based permit effluent limits if the requirements of the following paragraph are met.

A Permittee who wishes to establish the affirmative defense of upset must demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:

1. An upset occurred and that the Permittee can identify the cause(s) of the upset.
2. The permitted facility was being properly operated at the time of the upset.
3. The Permittee submitted notice of the upset as required in Special Condition S3.F.
4. The Permittee complied with any remedial measures required under S3.F of this permit.

In any enforcement action the Permittee seeking to establish the occurrence of an upset has the burden of proof.

G16. Property rights

This permit does not convey any property rights of any sort, or any exclusive privilege.

G17. Duty to comply

The Permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the Clean Water Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or denial of a permit renewal application.

G18. Toxic pollutants

The Permittee must comply with effluent standards or prohibitions established under Section 307(a) of the Clean Water Act for toxic pollutants within the time provided in the regulations that establish those standards or prohibitions, even if this permit has not yet been modified to incorporate the requirement.

G19. Penalties for tampering

The Clean Water Act provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than two (2) years per violation, or by both.

If a conviction of a person is for a violation committed after a first conviction of such person under this condition, punishment shall be a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than four (4) years, or by both.

G20. Compliance schedules

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit must be submitted no later than fourteen (14) days following each schedule date.

G21. Service agreement review

The Permittee must submit to Ecology any proposed service agreements and proposed revisions or updates to existing agreements for the operation of any wastewater treatment facility covered by this permit. The review is to ensure consistency with chapters 90.46 and 90.48 RCW as required by RCW 70.150.040(9). In the event that Ecology does not comment within a thirty-day (30) period, the Permittee may assume consistency and proceed with the service agreement or the revised/updated service agreement.

Appendix A—List Of Pollutants With Analytical Methods, Detection Limits And Quantitation Levels

The Permittee must use the specified analytical methods, detection limits (DLs) and quantitation levels (QLs) in the following table for permit and application required monitoring unless:

- Another permit condition specifies other methods, detection levels, or quantitation levels.
- The method used produces measurable results in the sample and EPA has listed it as an EPA-approved method in 40 CFR Part 136.

If the Permittee uses an alternative method, not specified in the permit and as allowed above, it must report the test method, DL, and QL on the discharge monitoring report or in the required report.

If the Permittee is unable to obtain the required DL and QL in its effluent due to matrix effects, the Permittee must submit a matrix-specific detection limit (MDL) and a quantitation limit (QL) to Ecology with appropriate laboratory documentation.

When the permit requires the Permittee to measure the base neutral compounds in the list of priority pollutants, it must measure all of the base neutral pollutants listed in the table below. The list includes EPA required base neutral priority pollutants and several additional polynuclear aromatic hydrocarbons (PAHs). The Water Quality Program added several PAHs to the list of base neutrals below from Ecology's Persistent Bioaccumulative Toxics (PBT) List. It only added those PBT parameters of interest to Appendix A that did not increase the overall cost of analysis unreasonably.

Ecology added this appendix to the permit in order to reduce the number of analytical "non-detects" in permit-required monitoring and to measure effluent concentrations near or below criteria values where possible at a reasonable cost.

The lists below include conventional pollutants (as defined in CWA section 502(6) and 40 CFR Part 122.), toxic or priority pollutants as defined in CWA section 307(a)(1) and listed in 40 CFR Part 122 Appendix D, 40 CFR Part 401.15 and 40 CFR Part 423 Appendix A), and nonconventionals. 40 CFR Part 122 Appendix D (Table V) also identifies toxic pollutants and hazardous substances which are required to be reported by dischargers if expected to be present. This permit appendix A list does not include those parameters.

CONVENTIONAL POLLUTANTS

| Pollutant | CAS Number (if available) | Recommended Analytical Protocol | Detection (DL) ¹ µg/L unless specified | Quantitation Level (QL) ² µg/L unless specified |
|--|---------------------------|---------------------------------|---|--|
| Biochemical Oxygen Demand | | SM5210-B | | 2 mg/L |
| Biochemical Oxygen Demand, Soluble | | SM5210-B ³ | | 2 mg/L |
| Fecal Coliform | | SM 9221E,9222 | N/A | Specified in method - sample aliquot dependent |
| Oil and Grease (HEM) (Hexane Extractable Material) | | 1664 A or B | 1,400 | 5,000 |
| pH | | SM4500-H ⁺ B | N/A | N/A |
| Total Suspended Solids | | SM2540-D | | 5 mg/L |

NONCONVENTIONAL POLLUTANTS

| Pollutant & CAS No. (if available) | CAS Number (if available) | Recommended Analytical Protocol | Detection (DL) ¹ µg/L unless specified | Quantitation Level (QL) ² µg/L unless specified |
|--|---------------------------|---|---|--|
| Alkalinity, Total | | SM2320-B | | 5 mg/L as CaCO ₃ |
| Aluminum, Total | 7429-90-5 | 200.8 | 2.0 | 10 |
| Ammonia, Total (as N) | | SM4500-NH ₃ -B and C/D/E/G/H | | 20 |
| Barium Total | 7440-39-3 | 200.8 | 0.5 | 2.0 |
| BTEX (benzene +toluene + ethylbenzene + m,o,p xylenes) | | EPA SW 846 8021/8260 | 1 | 2 |
| Boron, Total | 7440-42-8 | 200.8 | 2.0 | 10.0 |
| Chemical Oxygen Demand | | SM5220-D | | 10 mg/L |
| Chloride | | SM4500-Cl B/C/D/E and SM4110 B | | Sample and limit dependent |
| Chlorine, Total Residual | | SM4500 Cl G | | 50.0 |
| Cobalt, Total | 7440-48-4 | 200.8 | 0.05 | 0.25 |
| Color | | SM2120 B/C/E | | 10 color units |

NONCONVENTIONAL POLLUTANTS

| Pollutant & CAS No. (if available) | CAS Number (if available) | Recommended Analytical Protocol | Detection (DL)¹ µg/L unless specified | Quantitation Level (QL)² µg/L unless specified |
|---|----------------------------------|--|---|--|
| Dissolved oxygen | | SM4500-OC/OG | | 0.2 mg/L |
| Flow | | Calibrated device | | |
| Fluoride | 16984-48-8 | SM4500-F E | 25 | 100 |
| Hardness, Total | | SM2340B | | 200 as CaCO ₃ |
| Iron, Total | 7439-89-6 | 200.7 | 12.5 | 50 |
| Magnesium, Total | 7439-95-4 | 200.7 | 10 | 50 |
| Manganese, Total | 7439-96-5 | 200.8 | 0.1 | 0.5 |
| Molybdenum, Total | 7439-98-7 | 200.8 | 0.1 | 0.5 |
| Nitrate + Nitrite Nitrogen (as N) | | SM4500-NO ₃ - E/F/H | | 100 |
| Nitrogen, Total Kjeldahl (as N) | | SM4500-N _{org} B/C and SM4500NH ₃ - B/C/D/EF/G/H | | 300 |
| NWTPH Dx ⁴ | | Ecology NWTPH Dx | 250 | 250 |
| NWTPH Gx ⁵ | | Ecology NWTPH Gx | 250 | 250 |
| Phosphorus, Total (as P) | | SM 4500 PB followed by SM4500-PE/PF | 3 | 10 |
| Salinity | | SM2520-B | | 3 practical salinity units or scale (PSU or PSS) |
| Settleable Solids | | SM2540 -F | | Sample and limit dependent |
| Soluble Reactive Phosphorus (as P) | | SM4500-P E/F/G | 3 | 10 |
| Sulfate (as mg/L SO ₄) | | SM4110-B | | 0.2 mg/L |
| Sulfide (as mg/L S) | | SM4500-S ² F/D/E/G | | 0.2 mg/L |
| Sulfite (as mg/L SO ₃) | | SM4500-SO ₃ B | | 2 mg/L |
| Temperature (max. 7-day avg.) | | Analog recorder or Use micro- recording devices known as thermistors | | 0.2° C |
| Tin, Total | 7440-31-5 | 200.8 | 0.3 | 1.5 |
| Titanium, Total | 7440-32-6 | 200.8 | 0.5 | 2.5 |

NONCONVENTIONAL POLLUTANTS

| Pollutant & CAS No. (if available) | CAS Number (if available) | Recommended Analytical Protocol | Detection (DL)¹ µg/L unless specified | Quantitation Level (QL)² µg/L unless specified |
|---|----------------------------------|--|---|--|
| Total Coliform | | SM 9221B, 9222B, 9223B | N/A | Specified in method - sample aliquot dependent |
| Total Organic Carbon | | SM5310-B/C/D | | 1 mg/L |
| Total dissolved solids | | SM2540 C | | 20 mg/L |

| <i>PRIORITY POLLUTANTS</i> | PP # | CAS Number (if available) | Recommended Analytical Protocol | Detection (DL)¹ µg/L unless specified | Quantitation Level (QL)² µg/L unless specified |
|--|-------------|----------------------------------|--|---|--|
| METALS, CYANIDE & TOTAL PHENOLS | | | | | |
| Antimony, Total | 114 | 7440-36-0 | 200.8 | 0.3 | 1.0 |
| Arsenic, Total | 115 | 7440-38-2 | 200.8 | 0.1 | 0.5 |
| Beryllium, Total | 117 | 7440-41-7 | 200.8 | 0.1 | 0.5 |
| Cadmium, Total | 118 | 7440-43-9 | 200.8 | 0.05 | 0.25 |
| Chromium (hex) dissolved | 119 | 18540-29-9 | SM3500-Cr C | 0.3 | 1.2 |
| Chromium, Total | 119 | 7440-47-3 | 200.8 | 0.2 | 1.0 |
| Copper, Total | 120 | 7440-50-8 | 200.8 | 0.4 | 2.0 |
| Lead, Total | 122 | 7439-92-1 | 200.8 | 0.1 | 0.5 |
| Mercury, Total | 123 | 7439-97-6 | 1631E | 0.0002 | 0.0005 |
| Nickel, Total | 124 | 7440-02-0 | 200.8 | 0.1 | 0.5 |
| Selenium, Total | 125 | 7782-49-2 | 200.8 | 1.0 | 1.0 |
| Silver, Total | 126 | 7440-22-4 | 200.8 | 0.04 | 0.2 |
| Thallium, Total | 127 | 7440-28-0 | 200.8 | 0.09 | 0.36 |
| Zinc, Total | 128 | 7440-66-6 | 200.8 | 0.5 | 2.5 |
| Cyanide, Total | 121 | 57-12-5 | 335.4 | 5 | 10 |
| Cyanide, Weak Acid Dissociable | 121 | | SM4500-CN I | 5 | 10 |
| Cyanide, Free Amenable to Chlorination (Available Cyanide) | 121 | | SM4500-CN G | 5 | 10 |

| <i>PRIORITY POLLUTANTS</i> | PP # | CAS Number (if available) | Recommended Analytical Protocol | Detection (DL)¹ µg/L unless specified | Quantitation Level (QL)² µg/L unless specified |
|--|-------------|--------------------------------------|--|---|--|
| METALS, CYANIDE & TOTAL PHENOLS | | | | | |
| Phenols, Total | 65 | | EPA 420.1 | | 50 |

| <i>PRIORITY POLLUTANTS</i> | PP # | CAS Number (if available) | Recommended Analytical Protocol | Detection (DL)¹ µg/L unless specified | Quantitation Level (QL)² µg/L unless specified |
|--|-------------|--------------------------------------|--|---|--|
| ACID COMPOUNDS | | | | | |
| 2-Chlorophenol | 24 | 95-57-8 | 625 | 1.0 | 2.0 |
| 2,4-Dichlorophenol | 31 | 120-83-2 | 625 | 0.5 | 1.0 |
| 2,4-Dimethylphenol | 34 | 105-67-9 | 625 | 0.5 | 1.0 |
| 4,6-dinitro-o-cresol (2-methyl-4,6,-dinitrophenol) | 60 | 534-52-1 | 625/1625B | 2.0 | 4.0 |
| 2,4 dinitrophenol | 59 | 51-28-5 | 625 | 1.5 | 3.0 |
| 2-Nitrophenol | 57 | 88-75-5 | 625 | 0.5 | 1.0 |
| 4-Nitrophenol | 58 | 100-02-7 | 625 | 1.0 | 2.0 |
| Parachlorometa cresol (4-chloro-3-methylphenol) | 22 | 59-50-7 | 625 | 1.0 | 2.0 |
| Pentachlorophenol | 64 | 87-86-5 | 625 | 0.5 | 1.0 |
| Phenol | 65 | 108-95-2 | 625 | 2.0 | 4.0 |
| 2,4,6-Trichlorophenol | 21 | 88-06-2 | 625 | 2.0 | 4.0 |

| <i>PRIORITY POLLUTANTS</i> | PP # | CAS Number (if available) | Recommended Analytical Protocol | Detection (DL)¹ µg/L unless specified | Quantitation Level (QL)² µg/L unless specified |
|-----------------------------------|-------------|--------------------------------------|--|---|--|
| VOLATILE COMPOUNDS | | | | | |
| Acrolein | 2 | 107-02-8 | 624 | 5 | 10 |
| Acrylonitrile | 3 | 107-13-1 | 624 | 1.0 | 2.0 |
| Benzene | 4 | 71-43-2 | 624 | 1.0 | 2.0 |
| Bromoform | 47 | 75-25-2 | 624 | 1.0 | 2.0 |

| <i>PRIORITY POLLUTANTS</i> | PP # | CAS Number (if available) | Recommended Analytical Protocol | Detection (DL)¹ µg/L unless specified | Quantitation Level (QL)² µg/L unless specified |
|---|-------------|--------------------------------------|--|---|--|
| VOLATILE COMPOUNDS | | | | | |
| Carbon tetrachloride | 6 | 56-23-5 | 624/601 or SM6230B | 1.0 | 2.0 |
| Chlorobenzene | 7 | 108-90-7 | 624 | 1.0 | 2.0 |
| Chloroethane | 16 | 75-00-3 | 624/601 | 1.0 | 2.0 |
| 2-Chloroethylvinyl Ether | 19 | 110-75-8 | 624 | 1.0 | 2.0 |
| Chloroform | 23 | 67-66-3 | 624 or SM6210B | 1.0 | 2.0 |
| Dibromochloromethane (chlordibromomethane) | 51 | 124-48-1 | 624 | 1.0 | 2.0 |
| 1,2-Dichlorobenzene | 25 | 95-50-1 | 624 | 1.9 | 7.6 |
| 1,3-Dichlorobenzene | 26 | 541-73-1 | 624 | 1.9 | 7.6 |
| 1,4-Dichlorobenzene | 27 | 106-46-7 | 624 | 4.4 | 17.6 |
| Dichlorobromomethane | 48 | 75-27-4 | 624 | 1.0 | 2.0 |
| 1,1-Dichloroethane | 13 | 75-34-3 | 624 | 1.0 | 2.0 |
| 1,2-Dichloroethane | 10 | 107-06-2 | 624 | 1.0 | 2.0 |
| 1,1-Dichloroethylene | 29 | 75-35-4 | 624 | 1.0 | 2.0 |
| 1,2-Dichloropropane | 32 | 78-87-5 | 624 | 1.0 | 2.0 |
| 1,3-dichloropropene (mixed isomers) (1,2-dichloropropylene) ⁶ | 33 | 542-75-6 | 624 | 1.0 | 2.0 |
| Ethylbenzene | 38 | 100-41-4 | 624 | 1.0 | 2.0 |
| Methyl bromide (Bromomethane) | 46 | 74-83-9 | 624/601 | 5.0 | 10.0 |
| Methyl chloride (Chloromethane) | 45 | 74-87-3 | 624 | 1.0 | 2.0 |
| Methylene chloride | 44 | 75-09-2 | 624 | 5.0 | 10.0 |
| 1,1,2,2-Tetrachloroethane | 15 | 79-34-5 | 624 | 1.9 | 2.0 |
| Tetrachloroethylene | 85 | 127-18-4 | 624 | 1.0 | 2.0 |
| Toluene | 86 | 108-88-3 | 624 | 1.0 | 2.0 |
| 1,2-Trans-Dichloroethylene (Ethylene dichloride) | 30 | 156-60-5 | 624 | 1.0 | 2.0 |
| 1,1,1-Trichloroethane | 11 | 71-55-6 | 624 | 1.0 | 2.0 |
| 1,1,2-Trichloroethane | 14 | 79-00-5 | 624 | 1.0 | 2.0 |
| Trichloroethylene | 87 | 79-01-6 | 624 | 1.0 | 2.0 |
| Vinyl chloride | 88 | 75-01-4 | 624/SM6200B | 1.0 | 2.0 |

| PRIORITY POLLUTANTS | PP # | CAS Number (if available) | Recommended Analytical Protocol | Detection (DL)¹ µg/L unless specified | Quantitation Level (QL)² µg/L unless specified |
|--|-------------|--------------------------------------|--|---|--|
| BASE/NEUTRAL COMPOUNDS (compounds in bold are Ecology PBTs) | | | | | |
| Acenaphthene | 1 | 83-32-9 | 625 | 0.2 | 0.4 |
| Acenaphthylene | 77 | 208-96-8 | 625 | 0.3 | 0.6 |
| Anthracene | 78 | 120-12-7 | 625 | 0.3 | 0.6 |
| Benidine | 5 | 92-87-5 | 625 | 20 | 40 |
| Benzyl butyl phthalate | 67 | 85-68-7 | 625 | 0.3 | 0.6 |
| Benzo(a)anthracene | 72 | 56-55-3 | 625 | 0.3 | 0.6 |
| Benzo(b)fluoranthene (3,4-benzofluoranthene) ⁷ | 74 | 205-99-2 | 610/625 | 0.8 | 1.6 |
| Benzo(j)fluoranthene ⁷ | | 205-82-3 | 625 | 0.5 | 1.0 |
| Benzo(k)fluoranthene (11,12-benzofluoranthene) ⁷ | 75 | 207-08-9 | 610/625 | 0.8 | 1.6 |
| Benzo(r,s,t)pentaphene | | 189-55-9 | 625 | 1.3 | 5.0 |
| Benzo(a)pyrene | 73 | 50-32-8 | 610/625 | 0.5 | 1.0 |
| Benzo(ghi)Perylene | 79 | 191-24-2 | 610/625 | 0.5 | 1.0 |
| Bis(2-chloroethoxy)methane | 43 | 111-91-1 | 625 | 5.3 | 21.2 |
| Bis(2-chloroethyl)ether | 18 | 111-44-4 | 611/625 | 0.3 | 1.0 |
| Bis(2-chloroisopropyl)ether | 42 | 39638-32-9 | 625 | 0.5 | 1.0 |
| Bis(2-ethylhexyl)phthalate | 66 | 117-81-7 | 625 | 0.3 | 1.0 |
| 4-Bromophenyl phenyl ether | 41 | 101-55-3 | 625 | 0.3 | 0.5 |
| 2-Chloronaphthalene | 20 | 91-58-7 | 625 | 0.3 | 0.6 |
| 4-Chlorophenyl phenyl ether | 40 | 7005-72-3 | 625 | 0.3 | 0.5 |
| Chrysene | 76 | 218-01-9 | 610/625 | 0.3 | 0.6 |
| Dibenzo (a,h)acridine | | 226-36-8 | 610M/625M | 2.5 | 10.0 |
| Dibenzo (a,j)acridine | | 224-42-0 | 610M/625M | 2.5 | 10.0 |
| Dibenzo(a-h)anthracene (1,2,5,6-dibenzanthracene) | 82 | 53-70-3 | 625 | 0.8 | 1.6 |
| Dibenzo(a,e)pyrene | | 192-65-4 | 610M/625M | 2.5 | 10.0 |
| Dibenzo(a,h)pyrene | | 189-64-0 | 625M | 2.5 | 10.0 |
| 3,3-Dichlorobenzidine | 28 | 91-94-1 | 605/625 | 2.0 | 14.0 |
| Diethyl phthalate | 70 | 84-66-2 | 625 | 1.9 | 7.6 |
| Dimethyl phthalate | 71 | 131-11-3 | 625 | 1.6 | 6.4 |

| PRIORITY POLLUTANTS | PP # | CAS Number (if available) | Recommended Analytical Protocol | Detection (DL)¹ µg/L unless specified | Quantitation Level (QL)² µg/L unless specified |
|--|-------------|--------------------------------------|--|---|--|
| BASE/NEUTRAL COMPOUNDS (compounds in bold are Ecology PBTs) | | | | | |
| Di-n-butyl phthalate | 68 | 84-74-2 | 625 | 0.5 | 1.0 |
| 2,4-dinitrotoluene | 35 | 121-14-2 | 609/625 | 1.0 | 2.0 |
| 2,6-dinitrotoluene | 36 | 606-20-2 | 609/625 | 1.0 | 2.0 |
| Di-n-octyl phthalate | 69 | 117-84-0 | 625 | 0.3 | 0.6 |
| 1,2-Diphenylhydrazine (<i>as Azobenzene</i>) | 37 | 122-66-7 | 1625B | 5.0 | 20 |
| Fluoranthene | 39 | 206-44-0 | 625 | 0.3 | 0.6 |
| Fluorene | 80 | 86-73-7 | 625 | 0.3 | 0.6 |
| Hexachlorobenzene | 9 | 118-74-1 | 612/625 | 0.3 | 0.6 |
| Hexachlorobutadiene | 52 | 87-68-3 | 625 | 0.5 | 1.0 |
| Hexachlorocyclopentadiene | 53 | 77-47-4 | 1625B/625 | 2.0 | 4.0 |
| Hexachloroethane | 12 | 67-72-1 | 625 | 0.5 | 1.0 |
| Indeno(1,2,3-cd)Pyrene | 83 | 193-39-5 | 610/625 | 0.5 | 1.0 |
| Isophorone | 54 | 78-59-1 | 625 | 0.5 | 1.0 |
| 3-Methyl cholanthrene | | 56-49-5 | 625 | 2.0 | 8.0 |
| Naphthalene | 55 | 91-20-3 | 625 | 0.4 | 0.75 |
| Nitrobenzene | 56 | 98-95-3 | 625 | 0.5 | 1.0 |
| N-Nitrosodimethylamine | 61 | 62-75-9 | 607/625 | 2.0 | 4.0 |
| N-Nitrosodi-n-propylamine | 63 | 621-64-7 | 607/625 | 0.5 | 1.0 |
| N-Nitrosodiphenylamine | 62 | 86-30-6 | 625 | 1.0 | 2.0 |
| Perylene | | 198-55-0 | 625 | 1.9 | 7.6 |
| Phenanthrene | 81 | 85-01-8 | 625 | 0.3 | 0.6 |
| Pyrene | 84 | 129-00-0 | 625 | 0.3 | 0.6 |
| 1,2,4-Trichlorobenzene | 8 | 120-82-1 | 625 | 0.3 | 0.6 |

| <i>PRIORITY POLLUTANT</i> | PP # | CAS Number (if available) | Recommended Analytical Protocol | Detection (DL)¹ µg/L unless specified | Quantitation Level (QL)² µg/L unless specified |
|--|-------------|--------------------------------------|--|---|--|
| DIOXIN | | | | | |
| 2,3,7,8-Tetra-Chlorodibenzo-P-Dioxin (2,3,7,8 TCDD) | 129 | 1746-01-6 | 1613B | 1.3 pg/L | 5 pg/L |

| <i>PRIORITY POLLUTANTS</i> | PP # | CAS Number (if available) | Recommended Analytical Protocol | Detection (DL)¹ µg/L unless specified | Quantitation Level (QL)² µg/L unless specified |
|-----------------------------------|-------------|--------------------------------------|--|---|--|
| PESTICIDES/PCBs | | | | | |
| Aldrin | 89 | 309-00-2 | 608 | 0.025 | 0.05 |
| alpha-BHC | 102 | 319-84-6 | 608 | 0.025 | 0.05 |
| beta-BHC | 103 | 319-85-7 | 608 | 0.025 | 0.05 |
| gamma-BHC (Lindane) | 104 | 58-89-9 | 608 | 0.025 | 0.05 |
| delta-BHC | 105 | 319-86-8 | 608 | 0.025 | 0.05 |
| Chlordane ⁸ | 91 | 57-74-9 | 608 | 0.025 | 0.05 |
| 4,4'-DDT | 92 | 50-29-3 | 608 | 0.025 | 0.05 |
| 4,4'-DDE | 93 | 72-55-9 | 608 | 0.025 | 0.05 |
| 4,4' DDD | 94 | 72-54-8 | 608 | 0.025 | 0.05 |
| Dieldrin | 90 | 60-57-1 | 608 | 0.025 | 0.05 |
| alpha-Endosulfan | 95 | 959-98-8 | 608 | 0.025 | 0.05 |
| beta-Endosulfan | 96 | 33213-65-9 | 608 | 0.025 | 0.05 |
| Endosulfan Sulfate | 97 | 1031-07-8 | 608 | 0.025 | 0.05 |
| Endrin | 98 | 72-20-8 | 608 | 0.025 | 0.05 |
| Endrin Aldehyde | 99 | 7421-93-4 | 608 | 0.025 | 0.05 |
| Heptachlor | 100 | 76-44-8 | 608 | 0.025 | 0.05 |
| Heptachlor Epoxide | 101 | 1024-57-3 | 608 | 0.025 | 0.05 |
| PCB-1242 ⁹ | 106 | 53469-21-9 | 608 - Modified | 0.05 | 0.2 |
| PCB-1254 | 107 | 11097-69-1 | 608 - Modified | 0.05 | 0.2 |
| PCB-1221 | 108 | 11104-28-2 | 608 - Modified | 0.05 | 0.2 |

| <i>PRIORITY POLLUTANTS</i> | PP # | CAS Number (if available) | Recommended Analytical Protocol | Detection (DL)¹ µg/L unless specified | Quantitation Level (QL)² µg/L unless specified |
|-----------------------------------|-------------|--------------------------------------|--|---|--|
| PESTICIDES/PCBs | | | | | |
| PCB-1232 | 109 | 11141-16-5 | 608 - Modified | 0.05 | 0.2 |
| PCB-1248 | 110 | 12672-29-6 | 608 - Modified | 0.05 | 0.2 |
| PCB-1260 | 111 | 11096-82-5 | 608 - Modified | 0.05 | 0.2 |
| PCB-1016 ⁹ | 112 | 12674-11-2 | 608 - Modified | 0.05 | 0.2 |
| Toxaphene | 113 | 8001-35-2 | 608 | 0.24 | 0.5 |

1. Detection level (DL) or detection limit means the minimum concentration of an analyte (substance) that can be measured and reported with a 99% confidence that the analyte concentration is greater than zero as determined by the procedure given in 40 CFR part 136, Appendix B.
2. Quantitation Level (QL) also known as Minimum Level of Quantitation (ML) – The lowest level at which the entire analytical system must give a recognizable signal and acceptable calibration point for the analyte. It is equivalent to the concentration of the lowest calibration standard, assuming that the lab has used all method-specified sample weights, volumes, and cleanup procedures. The QL is calculated by multiplying the MDL by 3.18 and rounding the result to the number nearest to (1, 2, or 5) x 10ⁿ, where n is an integer. (64 FR 30417).
 ALSO GIVEN AS:
 The smallest detectable concentration of analyte greater than the Detection Limit (DL) where the accuracy (precision & bias) achieves the objectives of the intended purpose. (Report of the Federal Advisory Committee on Detection and Quantitation Approaches and Uses in Clean Water Act Programs Submitted to the US Environmental Protection Agency December 2007).
3. Soluble Biochemical Oxygen Demand method note: First, filter the sample through a Millipore Nylon filter (or equivalent) - pore size of 0.45-0.50 µm (prep all filters by filtering 250 ml of laboratory grade deionized water through the filter and discard). Then, analyze sample as per method 5210-B.
4. NWTPH Dx - Northwest Total Petroleum Hydrocarbons Diesel Extended Range – see <http://www.ecy.wa.gov/biblio/97602.html>

5. NWTPH Gx - Northwest Total Petroleum Hydrocarbons Gasoline Extended Range – see <http://www.ecy.wa.gov/biblio/97602.html>
6. 1, 3-dichloroproylene (mixed isomers) You may report this parameter as two separate parameters: cis-1, 3-dichloropropene (10061-01-5) and trans-1, 3-dichloropropene (10061-02-6).
7. Total Benzofluoranthenes - Because Benzo(b)fluoranthene, Benzo(j)fluoranthene and Benzo(k)fluoranthene co-elute you may report these three isomers as total benzofluoranthenes.
8. Chlordane – You may report alpha-chlordane (5103-71-9) and gamma-chlordane (5103-74-2) in place of chlordane (57-74-9). If you report alpha and gamma-chlordane, the DL/PQLs that apply are 0.025/0.050.
9. PCB 1016 & PCB 1242 – You may report these two PCB compounds as one parameter called PCB 1016/1242.