



STATE OF WASHINGTON
DEPARTMENT OF ECOLOGY

1250 West Alder Street • Union Gap, Washington 98903-0009 • (509) 575-2490

April 10, 2020

James Foreman
Windy Point LLC
183 Windy Point Drive
Wapato, WA 98951-8811

RE: Discharge Monitoring Reports for Windy Point, LLC—WAG435161

Dear James Foreman:

Ecology has reviewed your 2019 annual discharge monitoring report (DMR). The table below summarize the permit violations found. The purpose of this letter is to provide you an opportunity to review these violations and submit corrections if the records are not accurate.

WAG435161—Windy Point LLC

Outfall No(s).	Parameter	Date	Reported Value	Permit Limit
DMR	Late Submittal of DMR	Due by January 31, 2020	N/A	N/A
001	Total Dissolved Solids, mg/L	3/26/2019 12/3/2019	771 618	500
002	Total Dissolved Solids, mg/L	3/13/2019	860	500
	pH, Standard Units	10/11/2019	9.32	6.0-9.0

If the above information is incorrect or if you have any questions, please contact me at 509-454-7864, or email marcia.porter@ecy.wa.gov. Thank you.

Sincerely,

Marcia Porter

Marcia Porter
General Permit Manager
Water Quality Program