

Issuance Date: __?_
Effective Date: __?_
Expiration Date: __?_

**National Pollutant Discharge Elimination System
Waste Discharge Permit No. WA0030805**

State of Washington
DEPARTMENT OF ECOLOGY
Northwest Regional Office
3190 160th Avenue SE
Bellevue, WA 98008-5452

In compliance with the provisions of
The State of Washington Water Pollution Control Law
Chapter 90.48 Revised Code of Washington
and
The Federal Water Pollution Control Act
(The Clean Water Act)
Title 33 United States Code, Section 1342 et seq.

BROOKS MANUFACTURING CO.
2120 Pacific Street
Bellingham, Washington 98229

is authorized to discharge in accordance with the Special and General Conditions that follow.

Facility Location:
2120 Pacific Street
Bellingham, WA 98229

Treatment Type:
Settling, Evaporation

Industry Type:
Pressure Wood Treating

Receiving Water:
Stormwater Drainage Ditch to Whatcom Creek

SIC Code: 2491
NAICS Code: 321114

Categorical Industry: 40 CFR Part 429, subpart H
for Wood Preserving – Boulton subcategory

Rachel McCrea
Water Quality Section Manager
Northwest Regional Office
Washington State Department of Ecology

DRAFT

Table of Contents

Summary of Permit Report Submittals.....	5
Special Conditions	7
S1. Discharge limits.....	7
S1.A. Stormwater discharges	7
S2. Monitoring requirements	9
S2.A. Monitoring schedule.....	9
S2.B. Sampling and analytical procedures	10
S2.C. Flow measurement	10
S2.D. Laboratory accreditation	11
S2.E. Request for reduction in monitoring	11
S3. Reporting and recording requirements	11
S3.A. Discharge monitoring reports	11
S3.B. Permit Submittals and Schedules	13
S3.C. Records retention	13
S3.D. Recording of results.....	13
S3.E. Additional monitoring by the Permittee.....	14
S3.F. Reporting permit violations	14
S3.G. Other reporting	16
S3.H. Maintaining a copy of this permit.....	16
S4. Operation and maintenance	16
S4.A. Operations and maintenance (O&M) manual	17
S4.B. Bypass procedures	18
S5. Solid wastes.....	20
S5.A. Solid waste handling	20
S5.B. Leachate.....	20
S6. Application for permit renewal or modification for facility changes.....	21
S7. Spill control plan	21
S7.A. Spill control plan submittals and requirements	21
S7.B. Spill control plan components	21
S8. Stormwater pollution prevention plan	22
S9. Best management practices	22
S10. Acute toxicity	23
S10.A.Effluent characterization	23
S10.B.Sampling and reporting requirements.....	24
S11. Chronic toxicity	25
S11.A.Effluent characterization	25
S11.B.Sampling and reporting requirements.....	26
S12. Compliance schedule for Outfall 001.....	27

General Conditions	28
G1. Signatory requirements	28
G2. Right of inspection and entry	29
G3. Permit actions.....	30
G4. Reporting planned changes	31
G5. Plan review required	31
G6. Compliance with other laws and statutes	32
G7. Transfer of this permit	32
G8. Reduced production for compliance	32
G9. Removed substances.....	32
G10. Duty to provide information.....	33
G11. Other requirements of 40 CFR.....	33
G12. Additional monitoring	33
G13. Payment of fees	33
G14. Penalties for violating permit conditions	33
G15. Upset	33
G16. Property rights.....	34
G17. Duty to comply.....	34
G18. Toxic pollutants	34
G19. Penalties for tampering.....	34
G20. Reporting requirements applicable to existing manufacturing, commercial, mining, and silvicultural dischargers	35
G21. Compliance schedules.....	35
Appendix A	36
List Of Pollutants With Analytical Methods, Detection Limits And Quantitation Levels	36
Table 5: Conventional Pollutants	37
Table 6: NonConventional Pollutants	37
Priority Pollutants	40
Table 7: Metals, Cyanide & Total Phenols	40
Table 8: Acid Compounds.....	42
Table 9: Volatile Compounds	42
Table 10: Base/Neutral Compounds (Compounds in Bold are Ecology PBTS)	44

Table 11: Dioxin.....	47
Table 12: Pesticides/PCBS.....	47
Table 13: Pulp & Paper Pollutants (40CFR Part 430).....	49
Table 14: Nonconventionals – Dioxin & Furan Congeners.....	50
Analytical Methods.....	53

List of Tables

Table 1 Summary of Permit Report Submittals	5
Table 2 Effluent Limits: Outfall 001 ^c	7
Table 3 — Acute Toxicity Tests.....	24
Table 4 — Freshwater Chronic Test.....	26

Summary of Permit Report Submittals

Refer to the Special and General Conditions of this permit for additional submittal requirements.

Table 1 Summary of Permit Report Submittals

Permit Section	Submittal	Frequency	First Submittal Date
S3.A	Monthly Discharge Monitoring Report (DMR)	Monthly	<u>Enter a specific date</u>
S3.F	Reporting Permit Violations	As necessary	
S4.A	Operations and Maintenance Manual Update & Treatment System Operating Plan Update	1/permit cycle	<u>Enter the application date from S6</u>
S4.B	Reporting Bypasses	As necessary	
S6.	Application for Permit Renewal	1/permit cycle	<u>Insert date from S6</u>
S7.	Spill Plan Update	1/permit cycle, updates submitted as necessary	
S8.	Stormwater Pollution Prevention Plan Update	1/permit cycle	
S10.A	Acute Toxicity: Characterization Written Report	Annually	<u>Enter specific dates included in Special Condition</u>
S11.A	Chronic Toxicity: Characterization Written Report	Annually	<u>Enter specific dates included in Special Condition</u>
S12.1 (1)	Progress Report on Seeking laboratory to analyze DCOI	1/6 months	<u>Every 6 months</u>
S12.1 (2)	Final Laboratory Report for DCOI analysis		<u>Xxxxx (24 months from effective date)</u>
G1	Notice of Change in Authorization	As necessary	

Permit Section	Submittal	Frequency	First Submittal Date
G4	Permit Application for Substantive Changes to the Discharge	As necessary	
G5	Engineering Report for Construction or Modification Activities	As necessary	
G7	Notice of Permit Transfer	As necessary	
G10	Duty to Provide Information	As necessary	
G21	Compliance Schedules	As necessary	

Special Conditions

S1. Discharge limits

S1.A. Stormwater discharges

All discharges and activities authorized by this permit must be consistent with the terms and conditions of this permit.

The discharge of any of the following pollutants more frequently than, or at a level in excess of that identified and authorized by this permit violates the terms and conditions of this permit. The discharge of process wastewater to surface water is prohibited.

Beginning on the effective date of this permit, the Permittee is authorized to discharge treated stormwater to the drainage ditch, tributary to Whatcom Creek at the permitted location subject to complying with the following limits:

Table 2 Effluent Limits: Outfall 001^c

Latitude 48.756595 Longitude -122.459098

Parameter	Average Monthly ^a	Maximum Daily ^b
Total Petroleum Hydrocarbons-Diesel (TPH-Dx)	N/A	500 µg/L
Total Suspended Solids (TSS)	50 mg/L	--
Parameter	Minimum	Maximum
pH	6.0 standard units	9.0 standard units
Interim Numeric Effluent Limits Under Compliance Schedule (S12) Effective xxx, 2020 through xxxx, 2025		
Parameter	12-Month Rolling Average Limit ^a	Maximum Daily ^b
Pentachlorophenol ^e	9 µg/L ^d	20 µg/L
Final Numeric Effluent Limit – Water Quality-Based Effective xxxxx, 2025		
Parameter	Average Monthly ^a	Maximum Daily ^b
Pentachlorophenol ^e	6.2	9.1 µg/L
Footnote	Information	
^a	Average monthly (intermittent) effluent limit means the highest allowable average of daily discharges over a calendar month. To calculate the discharge value to compare to the limit, you add the value of each daily discharge measured during a calendar month	

Parameter	Average Monthly ^a	Maximum Daily ^b
	and divide this sum by the total number of samples taken in the month. If only one sample is taken during the month, the average monthly effluent limitation applies.	
b	Maximum daily effluent limit is the highest allowable daily discharge. The daily discharge is the average discharge of a pollutant measured during a calendar day. The average daily measurement does not apply to pH.	
c	Outfall #001 is defined as the discharge point from the southern stormwater pond, located at the southwest corner of the Brooks Manufacturing Company property.	
d	<p>The Monthly Average effluent limit for Pentachlorophenol is a 12-Month Rolling Average, calculated by taking the current month plus the previous 11 months of sampling data and dividing by 12. If more than one sample is taken in a month, they can be averaged for purposes of the rolling monthly average.</p> <p>Months where no sampling takes place due to non-qualifying storm events must not be considered for the purpose of calculating the rolling monthly average.</p>	
e	The Permittee must comply with the interim and final effluent limits while Pentachlorophenol (PCP) preservative chemical is used on-site. After the Permittee ceases the use of PCP, the interim and final effluent limits will be removed from the permit via permit modification upon verification and approval by Ecology.	

S2. Monitoring requirements

S2.A. Monitoring schedule

The Permittee must monitor in accordance with the following schedule and the requirements specified in **Appendix A (except DCOI)**.

Table 3 Stormwater Effluent

Parameter	Units & Speciation	Minimum Sampling Frequency	Sample Type
Stormwater Pond Discharges, Outfall #001 ^a			
Flow	gpd	For storm event sampled ^b	Calculated ^c
Total Petroleum Hydrocarbons - Diesel (TPH-Dx)	µg/L	Monthly ^d	Grab ^e
Total Suspended Solids (TSS)	mg/L	Monthly	Grab
Pentachlorophenol (PCP) ^f	µg/L	Monthly	Grab
pH	Std Units	Monthly	pH Meter ^g
Copper (total)	µg/L	Quarterly	Grab
Zinc (total)	µg/L	Quarterly	Grab
Acute Toxicity Testing	See S10	Yearly	Grab
Chronic Toxicity Testing	See S11	Yearly	Grab
Testing and reporting required after analysis at an accredited laboratory becomes available (See S12).			
4.5 Dichloro-2-N-Octyl-4-Isothiazolin-3-One (DCOI) ^h HM(1)TJ(2)SJ(3)	µg/L	Monthly(conditional) ^h	Grab
Footnote ^[SJ(4)]	Information		
a	Outfall #001 is the discharge point from the southern stormwater pond, located at the southwest corner of the Brooks Manufacturing Co. property, into the stormwater ditch.		
b	The sampling frequency for storm water must be once every month for twelve months of the year. All samples must be collected from the discharge resulting from a storm event that is greater than 0.1 inches in magnitude and that occurs at least 48 hours from the previously significant storm event. The grab sample must be taken during the first 60 minutes of discharge. If the collection of a grab sample is impractical within the first 60 minutes of a rainfall event, a grab sample can be taken during the first two hours of discharge, and the Permittee must submit with the monitoring report a description of why a grab sample was not possible during the first hour.		

Parameter	Units & Speciation	Minimum Sampling Frequency	Sample Type
Stormwater Pond Discharges, Outfall #001 ^a			
c	Total flow must be estimated for Outfall 001 based upon rainfall measurements or estimates, storm water collection area and an estimate of the runoff coefficient of the drainage area [e.g., low (under 40%), medium (40-65%), or high (above 65%)] for each storm event sampled.		
d	Monthly means once every calendar month. During months where flooding precludes representative sampling, enter "conditional-not required" on the DMR form.		
e	Grab means an individual sample collected over a fifteen (15)-minute, or less, period.		
f	PCP must be quantified using EPA Test Method 625. The method detection limit must be no greater than 0.5 ug/L. The permittee may request a reduction in this monitoring requirement per S2.E 12 months after ceasing use of pentachlorophenol.		
g	Due to the holding time for pH analysis is short, pH must be measured using a pH meter in the field. The calibration frequency specifications and method must be followed in accordance with the manufacturer's recommendations. A logbook must be kept to log all the readings and must be made available for Ecology's inspector(s) during inspections.		
h	Monitoring is required no later than 45 days after the Permittee is able to use an accredited laboratory to analyze DCOI analyte in the discharge. See S12 for detail of this requirement. In the interim, NWTPH-Dx will serve as a surrogate.		

S2.B. Sampling and analytical procedures

Samples and measurements taken to meet the requirements of this permit must represent the volume and nature of the monitored parameters, including representative sampling of any unusual discharge or discharge condition, including bypasses, upsets, and maintenance-related conditions affecting effluent quality.

Sampling and analytical methods used to meet the monitoring requirements specified in this permit must conform to the latest revision of the [Guidelines Establishing Test Procedures for the Analysis of Pollutants](#) contained in [40 CFR Part 136](#) (or as applicable in [40 CFR subchapter N](#) [Parts 400–471] or [40 CFR subchapter O](#) [Parts 501-503]) unless otherwise specified in this permit. Ecology may only specify alternative methods for parameters without limits and for those parameters without an EPA approved test method in [40 CFR Part 136](#).

S2.C. Flow measurement

The Permittee must calculate total flow for Outfall 001 based upon rainfall measurements or estimates, storm water collection area and an estimate of the runoff coefficient of the drainage area [e.g., low (under

40%), medium (40-65%), or high (above 65%)] for each storm event sampled.

S2.D. Laboratory accreditation

The Permittee must ensure that all monitoring data required by Ecology for permit specified parameters is prepared by a laboratory registered or accredited under the provisions of [chapter 173-50 WAC, Accreditation of Environmental Laboratories](#). Flow, temperature, settleable solids, conductivity, pH, and internal process control parameters are exempt from this requirement.

S2.E. Request for reduction in monitoring

The Permittee may request a reduction of the sampling frequency after twelve (12) months of monitoring. Ecology will review each request and at its discretion grant the request when it reissues the permit or by a permit modification.

The Permittee must:

1. Provide a written request.
2. Clearly state the parameters for which it is requesting reduced monitoring.
3. Clearly state the justification for the reduction.

S3. Reporting and recording requirements

The Permittee must monitor and report in accordance with the following conditions. Falsification of information submitted to Ecology is a violation of the terms and conditions of this permit.

S3.A. Discharge monitoring reports

The first monitoring period begins on the effective date of the permit (unless otherwise specified). The Permittee must:

1. Summarize, report, and submit monitoring data obtained during each monitoring period on the electronic discharge monitoring report (DMR) form provided by Ecology within the Water Quality Permitting Portal. Include data for each of the parameters tabulated in Special Condition S2 and as required by the form. Report a value for each day sampling occurred (unless specifically exempted in the permit) and for the summary values (when applicable) included on the electronic form.

To find out more information and to sign up for the [Water Quality Permitting Portal](http://ecyapwq/wqwebportal/) go to: <http://ecyapwq/wqwebportal/>

2. Ensure that DMRs are electronically submitted no later than the dates specified below, unless otherwise specified in this permit.
3. Submit DMRs for parameters with the monitoring frequencies specified in S2 (monthly, quarterly, annual, etc.) at the reporting schedule identified below. The Permittee must:
 - a. Submit **monthly** DMRs by the 28th day of the following month.
4. Enter the “No Discharge” reporting code for an entire DMR, for a specific monitoring point, or for a specific parameter as appropriate, if the Permittee did not discharge stormwater or a specific pollutant during a given monitoring period.
5. Report single analytical values below detection as “less than the detection level (DL)” by entering < followed by the numeric value of the detection level (e.g. < 2.0) on the DMR. If the method used did not meet the minimum DL and quantitation level (QL) identified in the permit, report the actual QL and DL in the comments or in the location provided.
6. Report single analytical values between the detection level (DL) and the quantitation level (QL) by entering the estimated value, the code for estimated value/below quantitation limit (j) and any additional information in the comments. Submit a copy of the laboratory report as an attachment using WQWebDMR.
7. Report the test method used for analysis in the comments if the laboratory used an alternative method not specified in the permit and as allowed in S2.
8. Calculate average values and calculated total values (unless otherwise specified in the permit) using:
 - a. The reported numeric value for all parameters measured between the detection value and the quantitation value for the sample analysis.
 - b. One-half the detection value (for values reported below detection) if the lab detected the parameter in another sample from the same monitoring point for the reporting period.
 - c. Zero (for values reported below detection) if the lab did not detect the parameter in another sample for the reporting period.
9. Report single-sample grouped parameters (for example: priority pollutants, PAHs, pulp and paper chlorophenolics, TTOs) on the

WQWebDMR form and include: sample date, concentration detected, detection limit (DL) (as necessary), and laboratory quantitation level (QL) (as necessary).

The Permittee must also submit an electronic copy of the laboratory report as an attachment using WQWebDMR. The contract laboratory reports must also include information on the chain of custody, QA/QC results, and documentation of accreditation for the parameter.

S3.B. Permit Submittals and Schedules

The Permittee must use the Water Quality Permitting Portal – Permit Submittals application (unless otherwise specified in the permit) to submit all other written permit-required reports by the date specified in the permit.

When another permit condition requires submittal of a paper (hard-copy) report, the Permittee must ensure that it is postmarked or received by Ecology no later than the dates specified by this permit. Send these paper reports to Ecology at:

Water Quality Permit Coordinator
Department of Ecology
Northwest Regional Office
3190 160th Avenue SE
Bellevue, WA 98008-5452

S3.C. Records retention

The Permittee must retain records of all monitoring information for a minimum of three (3) years. Such information must include all calibration and maintenance records and all original recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit. The Permittee must extend this period of retention during the course of any unresolved litigation regarding the discharge of pollutants by the Permittee or when requested by Ecology.

S3.D. Recording of results

For each measurement or sample taken, the Permittee must record the following information:

1. The date, exact place, method, and time of sampling or measurement.
2. The individual who performed the sampling or measurement.
3. The dates the analyses were performed.
4. The individual who performed the analyses.
5. The analytical techniques or methods used.
6. The results of all analyses.

S3.E. Additional monitoring by the Permittee

If the Permittee monitors any pollutant more frequently than required by Special Condition S2 of this permit, then the Permittee must include the results of such monitoring in the calculation and reporting of the data submitted in the Permittee's DMR unless otherwise specified by Special Condition S2.

S3.F. Reporting permit violations

The Permittee must take the following actions when it violates or is unable to comply with any permit condition:

1. Immediately take action to stop, contain, and cleanup unauthorized discharges or otherwise stop the noncompliance and correct the problem.
2. If applicable, immediately repeat sampling and analysis. Submit the results of any repeat sampling to Ecology within thirty (30) days of sampling.

a. Immediate reporting

The Permittee must **immediately** report to the Department of Ecology

Spills of chemicals or petroleum products to surface water

Northwest Regional Office 425-649-7000

b. Twenty-four-hour reporting

The Permittee must report the following occurrences of noncompliance by telephone, to Ecology at 425-649-7000, within 24 hours from the time the Permittee becomes aware of any of the following circumstances:

1. Any noncompliance that may endanger health or the environment, unless previously reported under immediate reporting requirements.
2. Any unanticipated bypass that causes an exceedance of any effluent limit in the permit (See Part S4.B., "Bypass Procedures").
3. Any upset that causes an exceedance of an effluent limit in the permit (See G.15, "Upset").
4. Any violation of a maximum daily or instantaneous maximum discharge limit for any of the pollutants in Section S1.A of this permit.
5. Any overflow prior to the treatment works, whether or not such overflow endangers health or the environment or exceeds any effluent limit in the permit. This requirement does not include industrial process wastewater overflows to impermeable surfaces which are collected and routed to the treatment works.

c. Report within five days

The Permittee must also submit a written report within five days of the time that the Permittee becomes aware of any reportable event under subparts a or b, above. The report must contain:

1. A description of the noncompliance and its cause.
2. The period of noncompliance, including exact dates and times.
3. The estimated time the Permittee expects the noncompliance to continue if not yet corrected.
4. Steps taken or planned to reduce, eliminate, and prevent recurrence of the noncompliance.
5. If the noncompliance involves an overflow prior to the treatment works, an estimate of the quantity (in gallons) of untreated overflow.

d. Waiver of written reports

Ecology may waive the written report required in subpart c, above, on a case-by-case basis upon request if the Permittee has submitted a timely oral report.

e. All other permit violation reporting

The Permittee must report all permit violations, which do not require immediate or within 24 hours reporting, when it submits monitoring reports for S3.A ("Reporting"). The reports must contain the information listed in subpart c, above. Compliance with these requirements does not relieve the Permittee from responsibility to maintain continuous compliance with the terms and conditions of this permit or the resulting liability for failure to comply.

S3.G. Other reporting

a. Spills of Oil or Hazardous Materials

The Permittee must report a spill of oil or hazardous materials in accordance with the requirements of [RCW 90.56.280](#) and [chapter 173-303-145 WAC](#). You can obtain further instructions on [How to Report a Spill](#) at: <https://ecology.wa.gov/About-us/Get-involved/Report-an-environmental-issue/Report-a-spill>

b. Failure to submit relevant or correct facts

Where the Permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application, or in any report to Ecology, it must submit such facts or information promptly.

S3.H. Maintaining a copy of this permit

The Permittee must keep a copy of this permit at the facility and make it available upon request to Ecology inspectors.

S4. Operation and maintenance

The Permittee must, at all times, properly operate and maintain all facilities or systems of treatment and control (and related appurtenances), which are installed to achieve compliance with the terms and conditions of this permit. Proper operation and maintenance also includes keeping a daily operation logbook (paper or electronic), adequate laboratory controls, and appropriate quality assurance procedures. This provision of the permit requires the Permittee to operate backup or auxiliary facilities or similar systems only when the operation is necessary to achieve compliance with the conditions of this permit.

The Permittee must schedule any facility maintenance, which might require interruption of wastewater treatment and degrade effluent quality, during non-

critical water quality periods and carry this maintenance out according to the approved O&M manual or as otherwise approved by Ecology.

S4.A. Operations and maintenance (O&M) manual

a. O&M manual submittal and requirements

The Permittee must:

1. Update the O&M Manual that meets the requirements of [173-240-150 WAC](#) and submit it to Ecology for review by (180 days prior to expiration date) with the permit renewal application.
2. Review the O&M Manual at least annually.
3. Submit to Ecology for review substantial changes or updates to the O&M Manual whenever it incorporates them into the manual.
4. Keep the approved O&M Manual at the permitted facility.
5. Follow the instructions and procedures of this manual.

b. O&M manual components [HM(5)] [TJ(6)]

In addition to the requirements of [WAC 173-240-150](#), the O&M Manual must include:

1. Emergency procedures for plant shutdown and cleanup in the event of a wastewater system upset or failure.
2. A review of system components which if failed could pollute surface water. Provide a procedure for a routine schedule of checking the function of these components.
3. Stormwater sampling protocols and procedures for compliance with the sampling and reporting requirements in the discharge permit.
4. Minimum staffing adequate to operate and maintain the treatment processes and carry out compliance monitoring required by the permit.
5. Treatment plant process control monitoring schedule.
6. A detailed discussion on how solids will be handled in the stormwater treatment system.

c. Treatment system operating plan

The Permittee must summarize the following information in the initial chapter of the O&M Manual entitled the "Treatment System Operating Plan." For the purposes of this permit, a Treatment System Operating

Plan (TSOP) is a concise summary of specifically defined elements of the O&M Manual.

The Permittee must update and submit the TSOP, as necessary, to include requirements for any major modifications of the treatment system.

The TSOP must not conflict with the O&M Manual and must include the following information:

1. A baseline operating condition, which describes the operating parameters and procedures, used to meet the effluent limits of S1 at the production levels used in developing these limits.
2. In the event of production rates, which are below the baseline levels used to establish these limits, the plan must describe the operating procedures and conditions needed to maintain design treatment efficiency. The monitoring and reporting must be described in the plan.
3. In the event of an upset, due to plant maintenance activities, severe stormwater events, startups or shut downs, or other causes, the plan must describe the operating procedures and conditions employed to mitigate the upset. The monitoring and reporting must be described in the plan.
4. A description of any regularly scheduled maintenance or repair activities at the facility which would affect the volume or character of the wastes discharged to the wastewater treatment system and a plan for monitoring and treating/controlling the discharge of maintenance-related materials (such as cleaners, degreasers, solvents, etc.).[HM(7)]TJ(8]

S4.B. Bypass procedures

A bypass is the intentional diversion of waste streams from any portion of a treatment facility. This permit prohibits all bypasses except when the bypass is for essential maintenance, as authorized in special condition S4.B.1, or is approved by Ecology as an anticipated bypass following the procedures in S4.B.2.

1. Bypass for essential maintenance without the potential to cause violation of permit limits or conditions.

This permit allows bypasses for essential maintenance of the treatment system when necessary to ensure efficient operation of the system. The Permittee may bypass the treatment system for essential maintenance only if doing so does not cause violations of effluent limits. The Permittee

is not required to notify Ecology when bypassing for essential maintenance. However the Permittee must comply with the monitoring requirements specified in special condition S2.B.

2. Anticipated bypasses for non-essential maintenance

Ecology may approve an anticipated bypass under the conditions listed below. This permit prohibits any anticipated bypass that is not approved through the following process.

- a. If a bypass is for non-essential maintenance, the Permittee must notify Ecology, if possible, at least ten (10) days before the planned date of bypass. The notice must contain:
 - A description of the bypass and the reason the bypass is necessary.
 - An analysis of all known alternatives which would eliminate, reduce, or mitigate the potential impacts from the proposed bypass.
 - A cost-effectiveness analysis of alternatives.
 - The minimum and maximum duration of bypass under each alternative.
 - A recommendation as to the preferred alternative for conducting the bypass.
 - The projected date of bypass initiation.
 - A statement of compliance with SEPA.
 - A request for modification of water quality standards as provided for in [WAC 173-201A-410](#), if an exceedance of any water quality standard is anticipated.
 - Details of the steps taken or planned to reduce, eliminate, and prevent recurrence of the bypass.
- b. For probable construction bypasses, the Permittee must notify Ecology of the need to bypass as early in the planning process as possible. The Permittee must consider the analysis required above during the project planning and design process. The project-specific engineering report as well as the plans and specifications must include details of probable construction bypasses to the extent practical. In cases where the Permittee determines the probable need to bypass early, the Permittee must continue to analyze conditions up to and including the construction period in an effort to minimize or eliminate the bypass.

- c. Ecology will determine if the Permittee has met the conditions of special condition S4.B.2 a and b and consider the following prior to issuing a determination letter, an administrative order, or a permit modification as appropriate for an anticipated bypass:
- If the Permittee planned and scheduled the bypass to minimize adverse effects on the public and the environment.
 - If the bypass is unavoidable to prevent loss of life, personal injury, or severe property damage. "Severe property damage" means substantial physical damage to property, damage to the treatment facilities which would cause them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.
 - If feasible alternatives to the bypass exist, such as:
 - The use of auxiliary treatment facilities.
 - Retention of untreated wastes.
 - Stopping production.
 - Maintenance during normal periods of equipment downtime, but not if the Permittee should have installed adequate backup equipment in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventative maintenance.
 - Transport of untreated wastes to another treatment facility.

S5. Solid wastes

S5.A. Solid waste handling

The Permittee must handle and dispose of all solid waste material in such a manner as to prevent its entry into state ground or surface water.

S5.B. Leachate

The Permittee must not allow leachate from its solid waste material to enter state waters without providing all known, available, and reasonable methods of treatment, nor allow such leachate to cause violations of the [State Surface Water Quality Standards, Chapter 173-201A WAC](#), or the [State Ground Water Quality Standards, Chapter 173-200 WAC](#).

The Permittee must apply for a permit or permit modification as may be required for such discharges to state ground or surface waters.

S6. Application for permit renewal or modification for facility changes

The Permittee must submit an application for renewal of this permit by Insert Date (180 days prior to expiration date).

The Permittee must also submit a new application or addendum at least one hundred eighty (180) days prior to commencement of discharges, resulting from the activities listed below, which may result in permit violations. These activities include any facility expansions, production increases, or other planned changes, such as process modifications, in the permitted facility.

S7. Spill control plan

S7.A. Spill control plan submittals and requirements

The Permittee must:

1. Submit to Ecology an update of the existing spill control plan by XXXXInsert date.
2. Review the plan at least annually and update the spill plan as needed.
3. Send changes to the plan to Ecology.
4. Follow the plan and any supplements throughout the term of the permit.

S7.B. Spill control plan components

The spill control plan must include the following:

1. A list of all oil and petroleum products and other materials used and/or stored on-site, which when spilled, or otherwise released into the environment, designate as Dangerous Waste (DW) or Extremely Hazardous Waste (EHW) by the procedures set forth in WAC 173-303-070. Include other materials used and/or stored on-site which may become pollutants or cause pollution upon reaching state's waters.
2. A description of preventive measures and facilities (including an overall facility plot showing drainage patterns) which prevent, contain, or treat spills of these materials.

3. A description of the reporting system the Permittee will use to alert responsible managers and legal authorities in the event of a spill.
4. A description of operator training to implement the plan.

The Permittee may submit plans and manuals required by [40 CFR Part 112](#), contingency plans required by [Chapter 173-303 WAC](#), or other plans required by other agencies, which meet the intent of this section. Approval of the Spill Control Plan with respect to this requirement does not constitute approval of the plans and manuals with respect to the underlying requirement.

S8. Stormwater pollution prevention plan

The Permittee must submit to Ecology an update to the existing Stormwater Pollution Prevention Plan (SWPPP) by **xxxx, 2021**.

The Permittee must modify the existing SWPPP whenever there is a change in design, construction, operation or maintenance, which causes the SWPPP to be less effective in controlling pollutants. Whenever the description of potential pollutant sources or the pollution prevention measures and controls identified in the SWPPP are inadequate, the SWPPP must be modified, as appropriate, within two (2) weeks of such determination. The proposed modification to the SWPPP must be submitted to Ecology at least thirty (30) days in advance of implementing the proposed changes in the plan unless Ecology approves immediate implementation. The Permittee must provide for implementation of any modifications to the SWPPP in a timely manner.

S9. Best management practices

The Permittee must fully implement the following Best Management Practices (BMPs) throughout the life of this permit. The Permittee must

1. Provide appropriate containment, drainage control, and/or diversionary structures where treatment chemicals including treatment formulation precursors (except uncontaminated water) are received, stored, processed or otherwise handled, to prevent storm water run-on and contamination. Such structures may include: roofs, covers, curbing, culverts, gutters, or similar structures to prevent the contact of uncontaminated storm water with process wastewater or process pollutants.
2. Provide secondary containment for all liquid chemical storage and process areas that is sufficient to contain the capacity of the largest single tank or vessel plus ten percent. Secondary containment systems must be sufficiently impervious to contain spilled chemicals until they can be removed or treated.

3. Ensure that treated product, upon the removal from the retort, remain on the drip pad until it has ceased dripping as defined in 40 CFR part 264.573 (k) and 40 CFR part 265.443 (k). Treated product must be periodically manipulated while on the drip pad to allow the removal of excess treating solution from cracks, checks, and from within bundles or units of wood.
4. Design, install and operate drip pads in accordance with the requirements for drip pads contained in 40 CFR part 264 and 40 CFR part 265.
5. Separate material handling equipment (fork lifts, pettibones, etc.) used for treated and untreated wood whenever feasible. When separate material handling equipment is not feasible actions must be taken to ensure that process pollutants are not tracked to the untreated wood (white wood) storage yard.
6. Divert storm water originating from areas outside the treated product storage area(s) away from the treated product storage area(s). Runoff from the treated product storage area must be collected or channeled to one or more discrete discharge points to facilitate storm water sample collection.
7. Store untreated and treated wood separately to the maximum extent practicable,
8. Store trams in such a manner that they will not come into contact with storm water, when not in use.
9. Not discharge detergents and emulsifiers used for equipment cleaning, maintenance, and repair to waters of the state unless adequate treatment is provided. Oil/water separators and/or sedimentation are not considered adequate treatment.
10. Prevent infiltration of storm water runoff from the treated product storage areas to the maximum extent practicable.

S10. Acute toxicity

S10.A. Effluent characterization

The Permittee must:

1. Conduct acute toxicity testing on the final effluent annually in September. The first testing starts in September 2021. If no discharge occurs during the required month, the Permittee must notify Ecology by the end of the month and conduct sampling on the next representative discharge that occurs in the following month.
2. Submit a yearly written report to Ecology within 45 days of sampling and starting no later than November 15th. Each subsequent yearly

report is due on that date. Further instructions on testing conditions and test report content are in Section G below.

3. Use a dilution series consisting of a minimum of five concentrations and a control. The five concentrations should include the ACEC of 100% effluent.
4. Conduct the following three acute toxicity tests on each sample:

Table 3 — Acute Toxicity Tests

Acute Toxicity Tests	Species	Method
Fathead minnow 96-hour static-renewal test	<i>Pimephales promelas</i>	EPA-821-R-02-012
Daphnid 48-hour static test	<i>Ceriodaphnia dubia</i> , <i>Daphnia pulex</i> , OR <i>Daphnia magna</i>	EPA-821-R-02-012
Rainbow trout 96-hour static-renewal test	<i>Oncorhynchus mykiss</i>	EPA-821-R-02-012

S10.B. Sampling and reporting requirements

1. The Permittee must submit all reports for toxicity testing in accordance with the most recent version of [Ecology Publication No. WQ-R-95-80, Laboratory Guidance and Whole Effluent Toxicity Test Review Criteria](#). Reports must contain toxicity data, bench sheets, and reference toxicant results for test methods. In addition, the Permittee must submit toxicity test data in electronic format (CETIS export file preferred) for entry into Ecology's database.
2. The Permittee must collect grab samples for toxicity testing. The Permittee must cool the samples to 0 - 6 degrees Celsius during collection and send them to the lab immediately upon completion. The lab must begin the toxicity testing as soon as possible but no later than 36 hours after sampling was completed.
3. The laboratory must conduct water quality measurements on all samples and test solutions for toxicity testing, as specified in the most recent version of [Ecology Publication No. WQ-R-95-80, Laboratory Guidance and Whole Effluent Toxicity Test Review Criteria](#).
4. All toxicity tests must meet quality assurance criteria and test conditions specified in the most recent versions of the EPA methods listed in Subsection C and the [Ecology Publication No. WQ-R-95-80, Laboratory Guidance and Whole Effluent Toxicity Test Review](#)

Criteria. If Ecology determines any test results to be invalid or anomalous, the Permittee must repeat the testing with freshly collected effluent.

5. The laboratory must use control water and dilution water meeting the requirements of the EPA methods listed in Section A or pristine natural water of sufficient quality for good control performance.
6. The Permittee may sample receiving water at the same time as the effluent and instruct the lab to measure the hardness of both and increase the hardness of the effluent sample to match the hardness of the receiving water sample prior to beginning the toxicity test. Otherwise, the Permittee must conduct whole effluent toxicity tests on an unmodified sample of final effluent.
7. The Permittee may choose to conduct a full dilution series test during compliance testing in order to determine dose response. In this case, the series must have a minimum of five effluent concentrations and a control. The series of concentrations must include the acute critical effluent concentration (ACEC). The ACEC equals 100% effluent.
8. All whole effluent toxicity tests, effluent screening tests, and rapid screening tests that involve hypothesis testing must comply with the acute statistical power standard of 29% as defined in WAC 173-205-020. If the test does not meet the power standard, the Permittee must repeat the test on a fresh sample with an increased number of replicates to increase the power.

S11. Chronic toxicity

S11.A. Effluent characterization

The Permittee must:

1. Conduct yearly chronic toxicity testing on the final effluent starting in September 2021. If no discharge occurs during the required month, the Permittee must notify Ecology by the end of the month and conduct sampling on the next representative discharge that occurs in the following month.
2. Submit the yearly written report to Ecology within 45 days of sampling and starting no later than November 15th. Each subsequent yearly report is due on that date. Further instructions on testing conditions and test report content are in Section G below.
3. Conduct chronic toxicity testing during effluent characterization on a series of at least five concentrations of effluent and a control. This series of dilutions must include the acute critical effluent

concentration (ACEC). The ACEC equals 100% effluent. The series of dilutions should also contain the CCEC of 100% effluent.

4. Conduct the following three chronic toxicity tests on each sample:

Table 4 — Freshwater Chronic Test

Freshwater Chronic Test	Species	Method
Fathead minnow survival and growth	<i>Pimephales promelas</i>	EPA-821-R-02-013
Water flea survival and reproduction	<i>Ceriodaphnia dubia</i>	EPA-821-R-02-013
Alga	<i>Pseudokirchneriella subcapitata</i> (formerly <i>Selenastrum capricornutum</i>)	EPA-821-R-02-013

S11.B. Sampling and reporting requirements

1. The Permittee must submit all reports for toxicity testing in accordance with the most recent version of [Ecology Publication No. WQ-R-95-80, Laboratory Guidance and Whole Effluent Toxicity Test Review Criteria](#). Reports must contain toxicity data, bench sheets, and reference toxicant results for test methods. In addition, the Permittee must submit toxicity test data in electronic format (CETIS export file preferred) for entry into Ecology's database.
2. The Permittee must collect grab samples for toxicity testing. The Permittee must cool the samples to 0 - 6 degrees Celsius during collection and send them to the lab immediately upon completion. The lab must begin the toxicity testing as soon as possible but no later than 36 hours after sampling was completed.
3. The laboratory must conduct water quality measurements on all samples and test solutions for toxicity testing, as specified in the most recent version of [Ecology Publication No. WQ-R-95-80, Laboratory Guidance and Whole Effluent Toxicity Test Review Criteria](#).
4. All toxicity tests must meet quality assurance criteria and test conditions specified in the most recent versions of the EPA methods listed in Section C. and the [Ecology Publication No. WQ-R-95-80, Laboratory Guidance and Whole Effluent Toxicity Test Review Criteria](#). If Ecology determines any test results to be invalid or

anomalous, the Permittee must repeat the testing with freshly collected effluent.

5. The laboratory must use control water and dilution water meeting the requirements of the EPA methods listed in Subsection C. or pristine natural water of sufficient quality for good control performance.
6. The Permittee must conduct whole effluent toxicity tests on an unmodified sample of final effluent.
7. The Permittee may sample receiving water at the same time as the effluent and instruct the lab to measure the hardness of both and increase the hardness of the effluent sample to match the hardness of the receiving water sample prior to beginning the toxicity test. Otherwise, the Permittee must conduct whole effluent toxicity tests on an unmodified sample of final effluent.
8. The Permittee may choose to conduct a full dilution series test during compliance testing in order to determine dose response. In this case, the series must have a minimum of five effluent concentrations and a control. The series of concentrations must include the CCEC and the ACEC. The CCEC and the ACEC may either substitute for the effluent concentrations that are closest to them in the dilution series or be extra effluent concentrations. The CCEC equals 100% effluent. The ACEC equals 100% effluent.
9. All whole effluent toxicity tests that involve hypothesis testing must comply with the chronic statistical power standard of 39% as defined in [WAC 173-205-020](#). If the test does not meet the power standard, the Permittee must repeat the test on a fresh sample with an increased number of replicates to increase the power.

S12. Compliance schedule for Outfall 001

The Permittee must achieve compliance with the following items:

Task No.	Task Description	Due By
1	Seek an accredited laboratory to analyze DCOI analyte The Permittee must procure a laboratory to analyze DCOI concentration in the discharge and request the laboratory seek accreditation from Ecology. High-performance liquid chromatography (HPLC) is a credible analytical test method for the analysis of wide variety of pesticides. Work with the chemical maker or provider, the selected laboratory, and Ecology's lab accreditation unit (https://ecology.wa.gov/Regulations-Permits/Permits-certifications/Laboratory-Accreditation/Applying-for-	Xxxxx, 2022 (2 yrs)

Task No.	Task Description	Due By
	<p>laboratory-accreditation) to modify the HPLC test method as necessary to analyze DCOI analyte, preferably EPA-approved method in 40 CFR Part 136.</p> <p><u>Deliverable:</u></p> <p>1) The Permittee must submit a progress report every 6 months. 2) The Permittee must submit the final report detailing the test method, detection level, or quantitation level to Ecology by the due date. Monitoring for DCOI commences 45 days after the final report is submitted as specified in S2, footnote h.</p> <p>If the Permittee is unable to find an accredited lab to analyze DCOI analyte, the Permittee must submit a letter detailing the effort that has been under taken to reach that conclusion.</p>	
2	<p>Comply with WQ-based Effluent Limitation for Pentachlorophenol (PCP) in S1.A. The Permittee expects to phase out PCP at this facility. End the use of this chemical, or employ additional treatment, or implement additional BMPs as necessary to comply with the final effluent limit for PCP.</p>	<p>xxxx, 2025 (5 yr)</p>

General Conditions

G1. Signatory requirements

1. All applications submitted to Ecology must be signed and certified.
 - a. In the case of corporations, by a responsible corporate officer. For the purpose of this section, a responsible corporate officer means:
 - A president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy or decision making functions for the corporation, or
 - The manager of one or more manufacturing, production, or operating facilities, provided, the manager is authorized to make management decisions which govern the operation of the regulated facility including having the explicit or implicit duty of making major capital investment recommendations, and initiating and directing other comprehensive measures to assure long-term environmental compliance with environmental laws and regulations; the manager can ensure that the necessary systems are established or actions taken to gather complete and accurate information for permit application requirements; and where authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures.
 - In the case of a partnership, by a general partner.
 - In the case of sole proprietorship, by the proprietor.

- In the case of a municipal, state, or other public facility, by either a principal executive officer or ranking elected official.

Applications for permits for domestic wastewater facilities that are either owned or operated by, or under contract to, a public entity shall be submitted by the public entity.

2. All reports required by this permit and other information requested by Ecology must be signed by a person described above or by a duly authorized representative of that person. A person is a duly authorized representative only if:
 - a. The authorization is made in writing by a person described above and submitted to Ecology.
 - b. The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility, such as the position of plant manager, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters. (A duly authorized representative may thus be either a named individual or any individual occupying a named position.)
3. Changes to authorization. If an authorization under paragraph G1.2, above, is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of paragraph G1.2, above, must be submitted to Ecology prior to or together with any reports, information, or applications to be signed by an authorized representative.
4. Certification. Any person signing a document under this section must make the following certification:

"I certify under penalty of law, that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gathered and evaluated the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

G2. Right of inspection and entry

The Permittee must allow an authorized representative of Ecology, upon the presentation of credentials and such other documents as may be required by law:

1. To enter upon the premises where a discharge is located or where any records must be kept under the terms and conditions of this permit.
2. To have access to and copy, at reasonable times and at reasonable cost, any records required to be kept under the terms and conditions of this permit.

3. To inspect, at reasonable times, any facilities, equipment (including monitoring and control equipment), practices, methods, or operations regulated or required under this permit.
4. To sample or monitor, at reasonable times, any substances or parameters at any location for purposes of assuring permit compliance or as otherwise authorized by the Clean Water Act.

G3. Permit actions

This permit may be modified, revoked and reissued, or terminated either at the request of any interested person (including the permittee) or upon Ecology's initiative. However, the permit may only be modified, revoked and reissued, or terminated for the reasons specified in [40 CFR 122.62](#), [40 CFR 122.64](#) or [WAC 173-220-150](#) according to the procedures of [40 CFR 124.5](#).

1. The following are causes for terminating this permit during its term, or for denying a permit renewal application:
 - a. Violation of any permit term or condition.
 - b. Obtaining a permit by misrepresentation or failure to disclose all relevant facts.
 - c. A material change in quantity or type of waste disposal.
 - d. A determination that the permitted activity endangers human health or the environment, or contributes to water quality standards violations and can only be regulated to acceptable levels by permit modification or termination.
 - e. A change in any condition that requires either a temporary or permanent reduction, or elimination of any discharge or sludge use or disposal practice controlled by the permit.
 - f. Nonpayment of fees assessed pursuant to [RCW 90.48.465](#).
 - g. Failure or refusal of the Permittee to allow entry as required in [RCW 90.48.090](#).
2. The following are causes for modification but not revocation and reissuance except when the Permittee requests or agrees:
 - a. A material change in the condition of the waters of the state.
 - b. New information not available at the time of permit issuance that would have justified the application of different permit conditions.
 - c. Material and substantial alterations or additions to the permitted facility or activities which occurred after this permit issuance.
 - d. Promulgation of new or amended standards or regulations having a direct bearing upon permit conditions, or requiring permit revision.

- e. The Permittee has requested a modification based on other rationale meeting the criteria of [40 CFR Part 122.62](#).
 - f. Ecology has determined that good cause exists for modification of a compliance schedule, and the modification will not violate statutory deadlines.
 - g. Incorporation of an approved local pretreatment program into a municipality's permit.
3. The following are causes for modification or alternatively revocation and reissuance:
- a. When cause exists for termination for reasons listed in 1.a through 1.g of this section, and Ecology determines that modification or revocation and reissuance is appropriate.
 - b. When Ecology has received notification of a proposed transfer of the permit. A permit may also be modified to reflect a transfer after the effective date of an automatic transfer (General Condition G7) but will not be revoked and reissued after the effective date of the transfer except upon the request of the new Permittee.

G4. Reporting planned changes

The Permittee must, as soon as possible, but no later than one hundred eighty (180) days prior to the proposed changes, give notice to Ecology of planned physical alterations or additions to the permitted facility, production increases, or process modification which will result in:

- 1. The permitted facility being determined to be a new source pursuant to [40 CFR 122.29\(b\)](#).
- 2. A significant change in the nature or an increase in quantity of pollutants discharged.
- 3. A significant change in the Permittee's sludge use or disposal practices. Following such notice, and the submittal of a new application or supplement to the existing application, along with required engineering plans and reports, this permit may be modified, or revoked and reissued pursuant to [40 CFR 122.62\(a\)](#) to specify and limit any pollutants not previously limited. Until such modification is effective, any new or increased discharge in excess of permit limits or not specifically authorized by this permit constitutes a violation.

G5. Plan review required

Prior to constructing or modifying any wastewater control facilities, an engineering report and detailed plans and specifications must be submitted to Ecology for approval in accordance with [chapter 173-240 WAC](#). Engineering reports, plans, and specifications must be submitted at least one hundred eighty (180) days prior to the planned start of construction unless a shorter time is approved by Ecology. Facilities must be constructed and operated in accordance with the approved plans.

G6. Compliance with other laws and statutes

Nothing in this permit excuses the Permittee from compliance with any applicable federal, state, or local statutes, ordinances, or regulations.

G7. Transfer of this permit

In the event of any change in control or ownership of facilities from which the authorized discharge emanate, the Permittee must notify the succeeding owner or controller of the existence of this permit by letter, a copy of which must be forwarded to Ecology.

1. Transfers by Modification

Except as provided in paragraph (2) below, this permit may be transferred by the Permittee to a new owner or operator only if this permit has been modified or revoked and reissued under [40 CFR 122.62\(b\)\(2\)](#), or a minor modification made under [40 CFR 122.63\(d\)](#), to identify the new Permittee and incorporate such other requirements as may be necessary under the Clean Water Act.

2. Automatic Transfers

This permit may be automatically transferred to a new Permittee if:

- a. The Permittee notifies Ecology at least thirty (30) days in advance of the proposed transfer date.
- b. The notice includes a written agreement between the existing and new Permittees containing a specific date transfer of permit responsibility, coverage, and liability between them.
- c. Ecology does not notify the existing Permittee and the proposed new Permittee of its intent to modify or revoke and reissue this permit. A modification under this subparagraph may also be minor modification under [40 CFR 122.63](#). If this notice is not received, the transfer is effective on the date specified in the written agreement.

G8. Reduced production for compliance

The Permittee, in order to maintain compliance with its permit, must control production and/or all discharges upon reduction, loss, failure, or bypass of the treatment facility until the facility is restored or an alternative method of treatment is provided. This requirement applies in the situation where, among other things, the primary source of power of the treatment facility is reduced, lost, or fails.

G9. Removed substances

Collected screenings, grit, solids, sludges, filter backwash, or other pollutants removed in the course of treatment or control of wastewaters must not be resuspended or reintroduced to the final effluent stream for discharge to state waters.

G10. Duty to provide information

The Permittee must submit to Ecology, within a reasonable time, all information which Ecology may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit or to determine compliance with this permit. The Permittee must also submit to Ecology upon request, copies of records required to be kept by this permit.

G11. Other requirements of 40 CFR

All other requirements of [40 CFR 122.41](#) and [40 CFR 122.42](#) are incorporated in this permit by reference.

G12. Additional monitoring

Ecology may establish specific monitoring requirements in addition to those contained in this permit by administrative order or permit modification.

G13. Payment of fees

The Permittee must submit payment of fees associated with this permit as assessed by Ecology.

G14. Penalties for violating permit conditions

Any person who is found guilty of willfully violating the terms and conditions of this permit is deemed guilty of a crime, and upon conviction thereof shall be punished by a fine of up to ten thousand dollars (\$10,000) and costs of prosecution, or by imprisonment in the discretion of the court. Each day upon which a willful violation occurs may be deemed a separate and additional violation.

Any person who violates the terms and conditions of a waste discharge permit may incur, in addition to any other penalty as provided by law, a civil penalty in the amount of up to ten thousand dollars (\$10,000) for every such violation. Each and every such violation is a separate and distinct offense, and in case of a continuing violation, every day's continuance is deemed to be a separate and distinct violation.

G15. Upset

Definition – “Upset” means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limits because of factors beyond the reasonable control of the Permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.

An upset constitutes an affirmative defense to an action brought for noncompliance with such technology-based permit effluent limits if the requirements of the following paragraph are met.

A Permittee who wishes to establish the affirmative defense of upset must demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:

1. An upset occurred and that the Permittee can identify the cause(s) of the upset.
2. The permitted facility was being properly operated at the time of the upset.
3. The Permittee submitted notice of the upset as required in Special Condition S3.F.
4. The Permittee complied with any remedial measures required under S3.F of this permit.

In any enforcement action the Permittee seeking to establish the occurrence of an upset has the burden of proof.

G16. Property rights

This permit does not convey any property rights of any sort, or any exclusive privilege.

G17. Duty to comply

The Permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the Clean Water Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or denial of a permit renewal application.

G18. Toxic pollutants

The Permittee must comply with effluent standards or prohibitions established under Section 307(a) of the Clean Water Act for toxic pollutants within the time provided in the regulations that establish those standards or prohibitions, even if this permit has not yet been modified to incorporate the requirement.

G19. Penalties for tampering

The Clean Water Act provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than two (2) years per violation, or by both. If a conviction of a person is for a violation committed after a first conviction of such person under this condition, punishment shall be a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than four (4) years, or by both.

G20. Reporting requirements applicable to existing manufacturing, commercial, mining, and silvicultural dischargers

The Permittee belonging to the categories of existing manufacturing, commercial, mining, or silviculture must notify Ecology as soon as they know or have reason to believe:

1. That any activity has occurred or will occur which would result in the discharge, on a routine or frequent basis, of any toxic pollutant which is not limited in this permit, if that discharge will exceed the highest of the following “notification levels:”
 - a. One hundred micrograms per liter (100 µg/L).
 - b. Two hundred micrograms per liter (200 µg/L) for acrolein and acrylonitrile; five hundred micrograms per liter (500 µg/L) for 2,4-dinitrophenol and for 2-methyl-4,6-dinitrophenol; and one milligram per liter (1 mg/L) for antimony.
 - c. Five (5) times the maximum concentration value reported for that pollutant in the permit application in accordance with [40 CFR 122.21\(g\)\(7\)](#).
 - d. The level established by the Director in accordance with [40 CFR 122.44\(f\)](#).
2. That any activity has occurred or will occur which would result in any discharge, on a non-routine or infrequent basis, of a toxic pollutant which is not limited in this permit, if that discharge will exceed the highest of the following “notification levels:”
 - a. Five hundred micrograms per liter (500µg/L).
 - b. One milligram per liter (1 mg/L) for antimony.
 - c. Ten (10) times the maximum concentration value reported for that pollutant in the permit application in accordance with [40 CFR 122.21\(g\)\(7\)](#).
 - d. The level established by the Director in accordance with [40 CFR 122.44\(f\)](#).

G21. Compliance schedules

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit must be submitted no later than fourteen (14) days following each schedule date.

Appendix A

List Of Pollutants With Analytical Methods, Detection Limits And Quantitation Levels

The Permittee must use the specified analytical methods, detection limits (DLs) and quantitation levels (QLs) in the following table for permit and application required monitoring unless:

- Another permit condition specifies other methods, detection levels, or quantitation levels.
- The method used produces measurable results in the sample and EPA has listed it as an EPA-approved method in 40 CFR Part 136

If the Permittee uses an alternative method, not specified in the permit and as allowed above, it must report the test method, DL, and QL on the discharge monitoring report or in the required report.

If the Permittee is unable to obtain the required DL and QL in its effluent due to matrix effects, the Permittee must submit a matrix-specific detection limit (MDL) and a quantitation limit (QL) to Ecology with appropriate laboratory documentation.

When the permit requires the Permittee to measure the base neutral compounds in the list of priority pollutants, it must measure all of the base neutral pollutants listed in the table below. The list includes EPA required base neutral priority pollutants and several additional polynuclear aromatic hydrocarbons (PAHs). The Water Quality Program added several PAHs to the list of base neutrals below from Ecology's Persistent Bioaccumulative Toxics (PBT) List. It only added those PBT parameters of interest to Appendix A that did not increase the overall cost of analysis unreasonably.

Ecology added this appendix to the permit in order to reduce the number of analytical "non-detects" in permit-required monitoring and to measure effluent concentrations near or below criteria values where possible at a reasonable cost.

The lists below include conventional pollutants (as defined in CWA section 502(6) and 40 CFR Part 122.), toxic or priority pollutants as defined in CWA section 307(a)(1) and listed in 40 CFR Part 122 Appendix D, 40 CFR Part 401.15 and 40 CFR Part 423 Appendix A), and nonconventionals. 40 CFR Part 122 Appendix D (Table V) also identifies toxic pollutants and hazardous substances which are required to be reported by dischargers if expected to be present. This permit appendix A list does not include those parameters. The list also includes pulp and paper pollutants identified in 40 CFR Part 430 and the dioxin and furan congeners identified using EPA Method 1613.

Table 5: Conventional Pollutants

Pollutant	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL)¹ $\mu\text{g/L}$ Unless specified	Quantitation Level (QL)² $\mu\text{g/L}$ Unless specified
Biochemical Oxygen Demand		SM5210-B		2 mg/L
Biochemical Oxygen Demand, Soluble		SM5210-B ³		2 mg/L
Fecal Coliform		SM 9221E,9222	N/A	Specified in method sample aliquot dependent
Oil and Grease (HEM) (Hexane Extractable Material)		1664 A or B	1,400	5,000
pH		SM4500-H ⁺ B	N/A	N/A
Total Suspended Solids		SM2540-D		5 mg/L

Table 6: NonConventional Pollutants

Pollutant	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL)¹ $\mu\text{g/L}$ Unless specified	Quantitation Level (QL)² $\mu\text{g/L}$ Unless specified
Alkalinity, Total		SM2320-B		5 mg/L as CaCO ₃
Aluminum, Total	7429-90-5	200.8	2.0	10
Ammonia, Total (as N)		SM4500-NH ₃ -B and C/D/E/G/H		20
Barium Total	7440-39-3	200.8	0.5	2.0
BTEX (benzene +toluene + ethylbenzene + m,o,p xylenes)		EPA SW 846 8021/8260	1	2

Pollutant	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL)¹ $\mu\text{g/L}$ Unless specified	Quantitation Level (QL)² $\mu\text{g/L}$ Unless specified
Boron, Total	7440-42-8	200.8	2.0	10.0
Chemical Oxygen Demand		SM5220-D		10 mg/L
Chloride		SM4500-Cl B/C/D/E and SM4110 B		Sample and limit dependent
Chlorine, Total Residual		SM4500 Cl G		50.0
Cobalt, Total	7440-48-4	200.8	0.05	0.25
Color		SM2120 B/C/E		10 color units
Dissolved oxygen		SM4500-OC/OG		0.2 mg/L
E.coli		SM 9221B, 9221F, 9223B	N/A	Specified in method - sample aliquot dependent
Enterococci		SM 9230B, 9230C, 9230D	N/A	Specified in method - sample aliquot dependent
Flow		Calibrated device		
Fluoride	16984-48-8	SM4500-F E	25	100
Hardness, Total		SM2340B		200 as CaCO ₃
Iron, Total	7439-89-6	200.7	12.5	50
Magnesium, Total	7439-95-4	200.7	10	50
Manganese, Total	7439-96-5	200.8	0.1	0.5
Molybdenum, Total	7439-98-7	200.8	0.1	0.5

DRAFT

Pollutant	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL)¹ $\mu\text{g/L}$ Unless specified	Quantitation Level (QL)² $\mu\text{g/L}$ Unless specified
Nitrate + Nitrite Nitrogen (as N)		SM4500-NO ₃ -E/F/H		100
Nitrogen, Total Kjeldahl (as N)		SM4500-N _{org} B/C and SM4500NH ₃ -B/C/D/EF/G/H		300
NWTPH Dx ⁴		Ecology NWTPH Dx	250	250
NWTPH Gx ⁵		Ecology NWTPH Gx	250	250
Phosphorus, Total (as P)		SM 4500 PB followed by SM4500-PE/PF	3	10
Salinity		SM2520-B		3 practical salinity units or scale (PSU or PSS)
Settleable Solids		SM2540 -F		Sample and limit dependent
Soluble Reactive Phosphorus (as P)		SM4500-P E/F/G	3	10
Sulfate (as mg/L SO ₄)		SM4110-B		0.2 mg/L
Sulfide (as mg/L S)		SM4500-S ² F/D/G		0.2 mg/L
Sulfite (as mg/L SO ₃)		SM4500-SO ₃ B		2 mg/L
Temperature (max. 7-day avg.)		Analog recorder or Use micro-recording devices known as thermistors		0.2° C

Pollutant	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL)¹ $\mu\text{g/L}$ Unless specified	Quantitation Level (QL)² $\mu\text{g/L}$ Unless specified
Tin, Total	7440-31-5	200.8	0.3	1.5
Titanium, Total	7440-32-6	200.8	0.5	2.5
Total Coliform		SM 9221B, 9222B, 9223B	N/A	Specified in method - sample aliquot dependent
Total Organic Carbon		SM5310-B/C/D		1 mg/L
Total dissolved solids		SM2540 C		20 mg/L

Priority Pollutants

Table 7: Metals, Cyanide & Total Phenols

Priority Pollutants	PP #	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL)¹ $\mu\text{g/L}$ Unless specified	Quantitation Level (QL)² $\mu\text{g/L}$ Unless specified
Antimony, Total	114	7440-36-0	200.8	0.3	1.0
Arsenic, Total	115	7440-38-2	200.8	0.1	0.5
Beryllium, Total	117	7440-41-7	200.8	0.1	0.5
Cadmium, Total	118	7440-43-9	200.8	0.05	0.25
Chromium (hex) dissolved	119	18540-29-9	SM3500-Cr C	0.3	1.2
Chromium, Total	119	7440-47-3	200.8	0.2	1.0

DRAFT

Priority Pollutants	PP #	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL) ¹ $\mu\text{g/L}$ <i>Unless specified</i>	Quantitation Level (QL) ² $\mu\text{g/L}$ <i>Unless specified</i>
Copper, Total	120	7440-50-8	200.8	0.4	2.0
Lead, Total	122	7439-92-1	200.8	0.1	0.5
Mercury, Total	123	7439-97-6	1631E	0.0002	0.0005
Nickel, Total	124	7440-02-0	200.8	0.1	0.5
Selenium, Total	125	7782-49-2	200.8	1.0	1.0
Silver, Total	126	7440-22-4	200.8	0.04	0.2
Thallium, Total	127	7440-28-0	200.8	0.09	0.36
Zinc, Total	128	7440-66-6	200.8	0.5	2.5
Cyanide, Total	121	57-12-5	335.4	5	10
Cyanide, Weak Acid Dissociable	121		SM4500-CN I	5	10
Cyanide, Free Amenable to Chlorination (Available Cyanide)	121		SM4500-CN G	5	10
Phenols, Total	65		EPA 420.1		50

Table 8: Acid Compounds

Priority Pollutants	PP #	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL)¹ $\mu\text{g/L}$ <i>Unless specified</i>	Quantitation Level (QL)² $\mu\text{g/L}$ <i>Unless specified</i>
2-Chlorophenol	24	95-57-8	625.1	3.3	9.9
2,4-Dichlorophenol	31	120-83-2	625.1	2.7	8.1
2,4-Dimethylphenol	34	105-67-9	625.1	2.7	8.1
4,6-dinitro-o-cresol (2-methyl-4,6-dinitrophenol)	60	534-52-1	625.1/1625B	24	72
2,4 dinitrophenol	59	51-28-5	625.1	42	126
2-Nitrophenol	57	88-75-5	625.1	3.6	10.8
4-Nitrophenol	58	100-02-7	625.1	2.4	7.2
Parachlorometa cresol (4-chloro-3-methylphenol)	22	59-50-7	625.1	3.0	9.0
Pentachlorophenol	64	87-86-5	625.1	3.6	10.8
Phenol	65	108-95-2	625.1	1.5	4.5
2,4,6-Trichlorophenol	21	88-06-2	625.1	2.7	8.1

Table 9: Volatile Compounds

Priority Pollutants	PP #	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL)¹ $\mu\text{g/L}$ <i>Unless specified</i>	Quantitation Level (QL)² $\mu\text{g/L}$ <i>Unless specified</i>
Acrolein	2	107-02-8	624.1	5	10
Acrylonitrile	3	107-13-1	624.1	1.0	2.0
Benzene	4	71-43-2	624.1	4.4	13.2
Bromoform	47	75-25-2	624.1	4.7	14.1

Priority Pollutants	PP #	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL) ¹ $\mu\text{g/L}$ <i>Unless specified</i>	Quantitation Level (QL) ² $\mu\text{g/L}$ <i>Unless specified</i>
Carbon tetrachloride	6	56-23-5	624.1/601 or SM6230B	2.8	8.4
Chlorobenzene	7	108-90-7	624.1	6.0	18.0
Chloroethane	16	75-00-3	624/601	1.0	2.0
2-Chloroethylvinyl Ether	19	110-75-8	624.1	1.0	2.0
Chloroform	23	67-66-3	624.1 or SM6210B	1.6	4.8
Dibromochloromethane (chlordibromomethane)	51	124-48-1	624.1	3.1	9.3
1,2-Dichlorobenzene	25	95-50-1	624.1	1.9	7.6
1,3-Dichlorobenzene	26	541-73-1	624.1	1.9	7.6
1,4-Dichlorobenzene	27	106-46-7	624.1	4.4	17.6
Dichlorobromomethane	48	75-27-4	624.1	2.2	6.6
1,1-Dichloroethane	13	75-34-3	624.1	4.7	14.1
1,2-Dichloroethane	10	107-06-2	624.1	2.8	8.4
1,1-Dichloroethylene	29	75-35-4	624.1	2.8	8.4
1,2-Dichloropropane	32	78-87-5	624.1	6.0	18.0
1,3-dichloropropene (mixed isomers) (1,2-dichloropropylene) ⁶	33	542-75-6	624.1	5.0	15.0
Ethylbenzene	38	100-41-4	624.1	7.2	21.6
Methyl bromide (Bromomethane)	46	74-83-9	624/601	5.0	10.0
Methyl chloride (Chloromethane)	45	74-87-3	624.1	1.0	2.0
Methylene chloride	44	75-09-2	624.1	2.8	8.4

Priority Pollutants	PP #	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL) ¹ $\mu\text{g/L}$ <i>Unless specified</i>	Quantitation Level (QL) ² $\mu\text{g/L}$ <i>Unless specified</i>
1,1,2,2-Tetrachloroethane	15	79-34-5	624.1	6.9	20.7
Tetrachloroethylene	85	127-18-4	624.1	4.1	12.3
Toluene	86	108-88-3	624.1	6.0	18.0
1,2-Trans-Dichloroethylene (Ethylene dichloride)	30	156-60-5	624.1	1.6	4.8
1,1,1-Trichloroethane	11	71-55-6	624.1	3.8	11.4
1,1,2-Trichloroethane	14	79-00-5	624.1	5.0	15.0
Trichloroethylene	87	79-01-6	624.1	1.9	5.7
Vinyl chloride	88	75-01-4	624/SM6200B	1.0	2.0

Table 10: Base/Neutral Compounds (Compounds in **Bold** are Ecology PBTS)

Priority Pollutants	PP #	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL) ¹ $\mu\text{g/L}$ <i>Unless specified</i>	Quantitation Level (QL) ² $\mu\text{g/L}$ <i>Unless specified</i>
Acenaphthene	1	83-32-9	625.1	1.9	5.7
Acenaphthylene	77	208-96-8	625.1	3.5	10.5
Anthracene	78	120-12-7	625.1	1.9	5.7
Benzidine	5	92-87-5	625.1	44	132
Benzyl butyl phthalate	67	85-68-7	625.1	2.5	7.5
Benzo(a)anthracene	72	56-55-3	625.1	7.8	23.4
Benzo(b)fluoranthene (3,4-benzofluoranthene) 7	74	205-99-2	610/625.1	4.8	14.4

Priority Pollutants	PP #	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL) ¹ $\mu\text{g/L}$ Unless specified	Quantitation Level (QL) ² $\mu\text{g/L}$ Unless specified
Benzo(j)fluoranthene ⁷		205-82-3	625	0.5	1.0
Benzo(k)fluoranthene (11,12-benzofluoranthene) ⁷	75	207-08-9	610/625.1	2.5	7.5
Benzo(r,s,t)pentaphene		189-55-9	625	1.3	5.0
Benzo(a)pyrene	73	50-32-8	610/625.1	2.5	7.5
Benzo(ghi)Perylene	79	191-24-2	610/625.1	4.1	12.3
Bis(2-chloroethoxy)methane	43	111-91-1	625.1	5.3	15.9
Bis(2-chloroethyl)ether	18	111-44-4	611/625.1	5.7	17.1
Bis(2-chloro-1-methylethyl)Ether (Bis(2-chloroisopropyl)ether) ¹⁰	42	108-60-1	625.1	5.7	17.1
Bis(2-ethylhexyl)phthalate	66	117-81-7	625.1	2.5	7.5
4-Bromophenyl phenyl ether	41	101-55-3	625.1	1.9	5.7
2-Chloronaphthalene	20	91-58-7	625.1	1.9	5.7
4-Chlorophenyl phenyl ether	40	7005-72-3	625.1	4.2	12.6
Chrysene	76	218-01-9	610/625.1	2.5	7.5
Dibenzo (a,h)acridine		226-36-8	610M/625M	2.5	10.0
Dibenzo (a,i)acridine		224-42-0	610M/625M	2.5	10.0

Priority Pollutants	PP #	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL) ¹ $\mu\text{g/L}$ <i>Unless specified</i>	Quantitation Level (QL) ² $\mu\text{g/L}$ <i>Unless specified</i>
Dibenzo(a-h)anthracene (1,2,5,6-dibenzanthracene)	82	53-70-3	625.1	2.5	7.5
Dibenzo(a,e)pyrene		192-65-4	610M/625M	2.5	10.0
Dibenzo(a,h)pyrene		189-64-0	625M	2.5	10.0
3,3-Dichlorobenzidine	28	91-94-1	605/625.1	16.5	49.5
Diethyl phthalate	70	84-66-2	625.1	1.9	5.7
Dimethyl phthalate	71	131-11-3	625.1	1.6	4.8
Di-n-butyl phthalate	68	84-74-2	625.1	2.5	7.5
2,4-dinitrotoluene	35	121-14-2	609/625.1	5.7	17.1
2,6-dinitrotoluene	36	606-20-2	609/625.1	1.9	5.7
Di-n-octyl phthalate	69	117-84-0	625.1	2.5	7.5
1,2-Diphenylhydrazine (as Azobenzene)	37	122-66-7	1625B/625.1	5.0	20
Fluoranthene	39	206-44-0	625.1	2.2	6.6
Fluorene	80	86-73-7	625.1	1.9	5.7
Hexachlorobenzene	9	118-74-1	612/625.1	1.9	5.7
Hexachlorobutadiene	52	87-68-3	625.1	0.9	2.7
Hexachlorocyclopentadiene	53	77-47-4	1625B/625.1	2.0	4.0
Hexachloroethane	12	67-72-1	625.1	1.6	4.8
Indeno(1,2,3-cd)Pyrene	83	193-39-5	610/625.1	3.7	11.1
Isophorone	54	78-59-1	625.1	2.2	6.6
3-Methyl cholanthrene		56-49-5	625	2.0	8.0
Naphthalene	55	91-20-3	625.1	1.6	4.8

Priority Pollutants	PP #	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL) ¹ $\mu\text{g/L}$ <i>Unless specified</i>	Quantitation Level (QL) ² $\mu\text{g/L}$ <i>Unless specified</i>
Nitrobenzene	56	98-95-3	625.1	1.9	5.7
N-Nitrosodimethylamine	61	62-75-9	607/625.1	2.0	4.0
N-Nitrosodi-n-propylamine	63	621-64-7	607/625.1	0.5	1.0
N-Nitrosodiphenylamine	62	86-30-6	625.1	1.0	2.0
Perylene		198-55-0	625	1.9	7.6
Phenanthrene	81	85-01-8	625.1	5.4	16.2
Pyrene	84	129-00-0	625.1	1.9	5.7
1,2,4-Trichlorobenzene	8	120-82-1	625.1	1.9	5.7

Table 11: Dioxin

Priority Pollutant	PP #	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL) ¹ $\mu\text{g/L}$ <i>Unless specified</i>	Quantitation Level (QL) ² $\mu\text{g/L}$ <i>Unless specified</i>
2,3,7,8-Tetra-Chlorodibenzo-P-Dioxin (2,3,7,8 TCDD)	129	1746-01-6	1613B	1.3 pg/L	5 pg/L

Table 12: Pesticides/PCBS

Priority Pollutants	PP #	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL) ¹ $\mu\text{g/L}$ <i>Unless specified</i>	Quantitation Level (QL) ² $\mu\text{g/L}$ <i>Unless specified</i>
Aldrin	89	309-00-2	608.3	4.0 ng/L	12 ng/L
alpha-BHC	102	319-84-6	608.3	3.0 ng/L	9.0 ng/L
beta-BHC	103	319-85-7	608.3	6.0 ng/L	18 ng/L

Priority Pollutants	PP #	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL) ¹ $\mu\text{g/L}$ <i>Unless specified</i>	Quantitation Level (QL) ² $\mu\text{g/L}$ <i>Unless specified</i>
gamma-BHC (Lindane)	104	58-89-9	608.3	4.0 ng/L	12 ng/L
delta-BHC	105	319-86-8	608.3	9.0 ng/L	27 ng/L
Chlordane ⁸	91	57-74-9	608.3	14 ng/L	42 ng/L
4,4'-DDT	92	50-29-3	608.3	12 ng/L	36 ng/L
4,4'-DDE	93	72-55-9	608.3	4.0 ng/L	12 ng/L
4,4' DDD	94	72-54-8	608.3	11ng/L	33 ng/L
Dieldrin	90	60-57-1	608.3	2.0 ng/L	6.0 ng/L
alpha-Endosulfan	95	959-98-8	608.3	14 ng/L	42 ng/L
beta-Endosulfan	96	33213-65-9	608.3	4.0 ng/L	12 ng/L
Endosulfan Sulfate	97	1031-07-8	608.3	66 ng/L	198 ng/L
Endrin	98	72-20-8	608.3	6.0 ng/L	18 ng/L
Endrin Aldehyde	99	7421-93-4	608.3	23 ng/L	70 ng/L
Heptachlor	100	76-44-8	608.3	3.0 ng/L	9.0 ng/L
Heptachlor Epoxide	101	1024-57-3	608.3	83 ng/L	249 ng/L
PCB-1242 ⁹	106	53469-21-9	608.3	0.065	0.195
PCB-1254	107	11097-69-1	608.3	0.065	0.195
PCB-1221	108	11104-28-2	608.3	0.065	0.195
PCB-1232	109	11141-16-5	608.3	0.065	0.195
PCB-1248	110	12672-29-6	608.3	0.065	0.195

DRAFT

Priority Pollutants	PP #	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL) ¹ $\mu\text{g/L}$ <i>Unless specified</i>	Quantitation Level (QL) ² $\mu\text{g/L}$ <i>Unless specified</i>
PCB-1260	111	11096-82-5	608.3	0.065	0.195
PCB-1016 ⁹	112	12674-11-2	608.3	0.065	0.195
Toxaphene	113	8001-35-2	608.3	240 ng/L	720 ng/L

Table 13: Pulp & Paper Pollutants (40CFR Part 430)

Pollutant	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL) ¹ $\mu\text{g/L}$ <i>Unless specified</i>	Quantitation Level (QL) ² $\mu\text{g/L}$ <i>Unless specified</i>
Adsorbable Organic Halides (AOX)		EPA 1650		20
2,3,7,8- Tetrachlorodibenzo-p-dioxin (TCDD) (this is also priority pollutant and is listed above)	1746-01-6	EPA 1613	1.3 pg/L	5 pg/L
2,3,7,8-Tetrachlorodibenzofuran (TCDF)	51207-31-9	EPA 1613	1.3 pg/L	5 pg/L
Trichlorosyringol		EPA 1653		2.5
3,4,5-Trichlorocatechol		EPA 1653		5.0
3,4,6-Trichlorocatechol		EPA 1653		5.0
3,4,5-Trichloroguaiacol		EPA 1653		2.5
3,4,6-Trichloroguaiacol		EPA 1653		2.5
4,5,6-Trichloroguaiacol		EPA 1653		2.5
2,4,5-Trichlorophenol		EPA 1653		2.5

Pollutant	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL)¹ µg/L Unless specified	Quantitation Level (QL)² µg/L Unless specified
2,4,6-Trichlorophenol		EPA 1653		2.5
Tetrachlorocatechol		EPA 1653		5.0
Tetrachloroguaiacol		EPA 1653		5.0
2,3,4,6-Tetrachlorophenol		EPA 1653		2.5
Pentachlorophenol (this is also priority pollutant and is listed above)		EPA 1653		5.0

Table 14: Nonconventionals – Dioxin & Furan Congeners

Pollutant	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL)¹ µg/L Unless specified	Quantitation Level (QL)² µg/L Unless specified
2,3,7,8- Tetrachlorodibenzo-p-dioxin (TCDD) (this is a priority pollutant and is also listed above)	1746-01-6	EPA 1613	1.3 pg/L	5 pg/L
Total TCDD	41903-57-5			
2,3,7,8-Tetrachlorodibenzofuran (TCDF)	51207-31-9		1.3 pg/L	5 pg/L
Total-TCDF	55722-27-5			
1,2,3,7,8- Pentachlorodibenzo-p-dioxin (PeCDD)	40321-76-4			
Total-PeCDD	36088-22-9			

Pollutant	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL)¹ $\mu\text{g/L}$ Unless specified	Quantitation Level (QL)² $\mu\text{g/L}$ Unless specified
1,2,3,7,8- Pentachlorodibenzofuran (PeCDF)	57117- 41-6			
2,3,4,7,8-PeCDF	57117- 31-4			
Total-PeCDF	30402- 15-4			
1,2,3,4,7,8- Hexachlorodibenzo-p-dioxin (HxCDD)	39227- 28-6			
1,2,3,6,7,8-HxCDD	57653- 85-7			
1,2,3,7,8,9-HxCDD	19408- 74-3			
Total-HxCDD	34465- 46-8			
1,2,3,4,7,8- Hexachlorodibenzofuran (HxCDF)	70648- 26-9			
1,2,3,6,7,8-HxCDF	57117- 44-9			
1,2,3,7,8,9-HxCDF	72918- 21-9			
2,3,4,6,7,8-HxCDF	60851- 34-5			
Total-HxCDF	55684- 94-1			
1,2,3,4,6,7,8- Heptachlorodibenzo-p-dioxin (HpCDD)	35822- 46-9			

Pollutant	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL)¹ $\mu\text{g/L}$ <i>Unless specified</i>	Quantitation Level (QL)² $\mu\text{g/L}$ <i>Unless specified</i>
Total-HpCDD	37871-00-4			
1,2,3,4,6,7,8-Heptachlorodibenzofuran (HpCDF)	67562-39-4			
1,2,3,4,7,8,9-HpCDF	55673-89-7			
Total-HpCDF	38998-75-3			
Octachlorodibenzo-p-dioxin (OCDD)	3268-87-9			
Octachlorodibenzofuran (OCDF)	39001-02-0			

Analytical Methods

1. **Detection level (DL)** – or detection limit means the minimum concentration of an analyte (substance) that can be measured and reported with a 99% confidence that the analyte concentration is greater than zero as determined by the procedure given in 40 CFR part 136, Appendix B.
2. **Quantitation Level (QL)** – also known as Minimum Level of Quantitation (ML) – The lowest level at which the entire analytical system must give a recognizable signal and acceptable calibration point for the analyte. It is equivalent to the concentration of the lowest calibration standard, assuming that the lab has used all method-specified sample weights, volumes, and cleanup procedures. The QL is calculated by multiplying the MDL by 3.18 and rounding the result to the number nearest to $(1, 2, \text{ or } 5) \times 10^n$, where n is an integer. (64 FR 30417).
Also Given As: The smallest detectable concentration of analyte greater than the Detection Limit (DL) where the accuracy (precision & bias) achieves the objectives of the intended purpose. (Report of the Federal Advisory Committee on Detection and Quantitation Approaches and Uses in Clean Water Act Programs Submitted to the US Environmental Protection Agency December 2007).
3. **Soluble Biochemical Oxygen Demand** – method note: First, filter the sample through a Millipore Nylon filter (or equivalent) - pore size of 0.45-0.50 μm (prep all filters by filtering 250 ml of laboratory grade deionized water through the filter and discard). Then, analyze sample as per method 5210-B.
4. **Northwest Total Petroleum Hydrocarbons Diesel Extended Range OR NWTPH Dx** – [Analytical Methods for Petroleum Hydrocarbons](https://fortress.wa.gov/ecy/publications/documents/97602.pdf)
<https://fortress.wa.gov/ecy/publications/documents/97602.pdf>
5. **Northwest Total Petroleum Hydrocarbons Gasoline Extended Range OR NWTPH Gx** – [Analytical Methods for Petroleum Hydrocarbons](https://fortress.wa.gov/ecy/publications/documents/97602.pdf)
<https://fortress.wa.gov/ecy/publications/documents/97602.pdf>
6. **1, 3-dichloropropylene (mixed isomers)** – You may report this parameter as two separate parameters: cis-1, 3-dichloropropene (10061-01-5) and trans-1, 3-dichloropropene (10061-02-6).
7. **Total Benzofluoranthenes** – Because Benzo(b)fluoranthene, Benzo(j)fluoranthene and Benzo(k)fluoranthene co-elute you may report these three isomers as total benzofluoranthenes.

8. **Chlordane** – You may report alpha-chlordane (5103-71-9) and gamma-chlordane (5103-74-2) in place of chlordane (57-74-9). If you report alpha and gamma-chlordane, the DL/PQLs that apply are 14/42 ng/L.
9. **PCB 1016 & PCB 1242** – You may report these two PCB compounds as one parameter called PCB 1016/1242.
10. **Bis(2-Chloro-1-Methylethyl) Ether** – This compound was previously listed as Bis(2-Chloroisopropyl) Ether (39638-32-9)