



Water Quality Program

Permit Submittal Electronic Certification

Permittee: SPECIFIED FITTINGS INC

Permit Number: WAR011142

Site Address: 164 W SMITH RD
BELLINGHAM, WA 98226

Submittal Name: 2020 Annual Report (covers 2020 calendar year)

Version: 1

Due Date: 5/15/2021

Comments: A total of 8 (eight) samples were taken over the 2020 reporting session. Out of the 8 (eight) samples, 2 (two) of these exceeded the bench mark parameter for turbidity on 09/25/2020 and 12/08/2020. These were both due to excessive rain activity that washed sediment from offsite roadways that cross contaminated with the sample point on this site.

I certify under penalty of law, that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Jerry Peterson

3/22/2021 8:09:24 AM

Signature

Date