



National Food

RE: Permit # ST0045510. Letter of explanation for non compliance.

Event date: 7/1/2020 to 7/31/2020

Monitoring Point	Parameter	Sample Date/ Statistical Base	Value	Notes/Comment
	001	Flow Gallons/Day (gpd)	7/9/2020 4911.5	Not sure if the clouded meter could have been read improperly
	001	Flow Gallons/Day (gpd)	7/24/2020 4038.4	Not sure if the clouded meter could have been read improperly
	001	Fecal Coliform MPN/100 mL	Average 1600	Cleaned and replaced sand in sand filter
	001	Fecal Coliform MPN/100 mL	Daily Maximum 1600	Cleaned and replaced sand in sand filter

The system was shut down and pumped to tanker .The sand filters were back flushed, cleaned started back and retested for coli form within the required period. Waste water generated for this permit is only wash water for the eggs and sanitation of the processor. The Coliform would have come from clumped manure that could be conveyed to the wash or cage free organic eggs that are considerably dirtier than eggs from caged hens.