



STATE OF WASHINGTON  
DEPARTMENT OF ECOLOGY  
1250 West Alder Street • Union Gap, Washington 98903-0009 • (509) 575-2490

February 11, 2022

VIA EMAIL  
Laura Rockstad  
WP Packing, Inc.  
183 Windy Point Drive  
Wapato, WA 98951-8811

Dear Laura Rockstad:

RE: **2020-2021 Discharge Monitoring Report for WP Packing, Inc.,--WAG435161**


Ecology has reviewed your **2020 and 2021** annual discharge monitoring reports (DMR's). The table below summarizes the permit violations found. The purpose of this letter is to provide you an opportunity to review these violations and submit corrections if the records are not accurate.

**2020 and 2021-WAG435161—WP Packing**

Outfall No(s).	Parameter	Date	Reported Value	Permit Limit
<b>2020</b> 002	Total Dissolved Solids, mg/L	1/14/2020	902	500
<b>2021</b> 001	Total Dissolved Solids, mg/L	12/9/2021	630	500
002	Total Dissolved Solids, mg/L	1/6/2021	710	500
		12/14/2021	606	500
003	Total Residual Chlorine, mg/L	1/6/2021	35.6	10

Total dissolved solids continues to be an issue at your facility. Please consider operational changes to control these discharge levels. Other than to make any corrections to the table above, no further response from your facility is required.

If you have any questions or concerns please contact me at 509-406-6624 (cell), or email [marcia.porter@ecy.wa.gov](mailto:marcia.porter@ecy.wa.gov).

Sincerely,  
  
Marcia Porter  
General Permit Manager  
Central Region

e.c. Fred Lopez, WP Packing