



STATE OF WASHINGTON
DEPARTMENT OF ECOLOGY

Southwest Regional Office

PO Box 47775, Olympia, WA 98504-7775 • 360-407-6300

August 16, 2022

The Honorable David Olson
Mayor of Cathlamet
375 2nd Street
Cathlamet, WA 98612

RE: Noncompliance Notification for National Pollutant Discharge Elimination System (NPDES) Permit No. WA0022667, Town of Cathlamet Wastewater Treatment Plant

Dear Mayor David Olson:

NPDES Permit No. WA0022667 requires that monitoring data obtained during each monitoring period shall be summarized, reported, and submitted on a Discharge Monitoring Report (DMR) form provided, or otherwise approved, or through our WQWebDMR. DMR forms shall be received/submitted no later than the 15th day of the month following the completed monitoring period, unless otherwise specified in this permit.

Your DMR for **June 2022** was due no later than July 15, 2022, and was not submitted until July 18, 2022.

Your **June 2022** DMR also indicates that your discharge did not comply with your permit requirements.

Your permit requires that: Effluent Ammonia is to be monitored and reported monthly.

But, based on your DMR: Effluent Ammonia was not reported for the month of June 2022.

Failures to sample or report sample results are violations of your NPDES Permit. You should be aware that violations are subject to enforcement action, including Administrative Orders, to correct the problem and/or Civil Penalties, in accordance with [Washington Administrative Code \(WAC\) 173-220-230](#).

If you have any questions regarding this matter (or if our information is incorrect), please contact your facility manager, Eleanor Ott, at eleanor.ott@ecy.wa.gov or by phone at (360) 280-5624 (cell); or you can contact me at ginger.reddig@ecy.wa.gov or by phone at (360) 789-5425 (cell).

If you need technical assistance, please contact your facility manager or our technical assistance specialist, Shane Cooper, at shane.cooper@ecy.wa.gov or by phone at (360) 870-6297 (cell).

Sincerely,

Ginger Reddig
Compliance Specialist
Water Quality Program
Southwest Regional Office

GR:CC(0022667)

cc: Jay Watson, Town of Cathlamet
Permit Compliance File