

November 12, 2021

Chris Martin
Department of Ecology, Northwest Regional Office
3190 160th Ave. SE
Bellevue, WA 98008-5452

Re: Effluent Limit Exceedances in Wastewater at ZYK Enterprises

Dear Mr. Martin,

ZYK Enterprises discharges wastewater to a drain field adjacent to the Snoqualmie River under Washington State Department of Ecology (Ecology) State Waste Discharge Permit Number ST0003974. This letter serves as a formal report to Ecology documenting ZYK Enterprises' effluent limit exceedances for wastewater discharge during the month of October.

The following effluent limit exceedances occurred for Outfall 003 on 10/19/21 at 1135:

Total residual chlorine: 2.87 mg/L
Fecal coliform: 180,000 CFU/100 mL
Total coliform: 860,000 CFU/100 mL



These exceedances were likely caused by low chlorine in the treatment process. No overflow or bypass of the treatment system occurred. ZYK Enterprises plans to adjust the chlorination and de-chlorination procedures by the next compliance monitoring event in November of 2021 to prevent future exceedances. ZYK Enterprises will notify Ecology immediately upon becoming aware of any future non-compliances or exceedances of the parameters listed in the Permit.

If you have any questions, please reach out to me at the phone number listed below.

Sincerely,

Waqar Qazi
206-307-4705
waqarq24@gmail.com