



STATE OF WASHINGTON
DEPARTMENT OF ECOLOGY

Southwest Region Office
PO Box 47775, Olympia, WA 98504-7775 • 360-407-6300

October 24, 2022

Todd Felton
Fort Columbia State Park
PO Box 300
Chinook, WA 98614

RE: Noncompliance Notification for National Pollutant Discharge Elimination System (NPDES) Permit No. WA0038709, Fort Columbia State Park Wastewater Treatment Plant

Dear Todd Felton:

Your **August 2022** Discharge Monitoring Report (DMR) indicates that your discharge did not comply with your permit requirements:

Monitoring Parameter	Sample Measurement	Permit Requirement
Fecal Coliform (GEM)	253.093 #/100 mL	200 #/100 mL
Fecal Coliform (GM7)	517 #/100 mL	400 #/100 ML

Failures to meet permit limits are violations of your NPDES Permit. You should be aware that violations are subject to enforcement action, including Administrative Orders to correct the problem and/or Civil Penalties, in accordance with [Washington Administrative Code \(WAC\) 173-220-230](#).

If your violations are chronic, you should contact us and tell us what steps you are taking to bring your facility back into compliance. Noncompliance reporting is a condition of your permit.

If you have any questions regarding this matter (or if our information is incorrect), please contact your facility manager, Eleanor Ott, at eleanor.ott@ecy.wa.gov or by phone at (360) 280-5624; or you can contact me at ginger.reddig@ecy.wa.gov or by phone at (360) 789-5425.

If you need technical assistance, please contact your facility manager or call our technical assistance specialist, Shane Cooper, at shane.cooper@ecy.wa.gov or by phone at (360) 870-6297.

Sincerely,

Ginger Reddig
Compliance Specialist
Water Quality Program
Southwest Regional Office

GR:CC(0038709)

cc: Devin Lindstrand, Fort Columbia State Park
Permit Compliance File