



The Holmes Harbor Sewer District (HHSD) diverted .38 million gallons of wastewater into the onsite off-spec pond in 2022.

There were three events in 2022.

January 3, 2022 HHSD experienced high sustained flows due to a heavy rain event (1.2" rain in 24 hours).

On February 14, 2022 HHSD staff responded to a HI EQ basin level. The root cause of this episode was never identified.

On November 4, 2022 Island County experienced extended weather-related power outages. Our new plant diversion project was completed and we were able to divert all flows to off-spec per our written SOPs. When power was restored, we were able to introduce flows to the SBR in a controlled intentional manner also per written SOPs.

HHSDs SBR was online for 365 days and diverted flows for nine of those days.

Chad Clay

Holmes Harbor Sewer District

General Manager

360-331-4636

[sbr@whidbey.com](mailto:sbr@whidbey.com)