



May 2, 2023

Washington State Department of Ecology  
Eastern Regional Office  
4601 N Monroe St,  
Spokane, WA 99205

Dear Ms. Llyn Doremus,

The Tyson Fresh Meats, Inc. – Pasco facility is submitting, as required by section S3.F. subpart (c) in the facility's Industrial Wastewater Permit, ST0005335, a written report to describe an event that led to the overflow prior to the facilities treatment works.

On April 25, 2023, wastewater intended to be transferred to facility anaerobic lagoons overflowed from a manhole located at the front driveway of the facility for a period of 15 minutes. It is estimated that 340 gallons of water overflowed. A new, larger pump had been installed during the previous weekend at the lift station intended to transport the wastewater, and the pump had not yet been operating as intended due to its Variable Frequency Drive.

The facility plans on taking procedures during the weekend of May 06 – May 07 barring availability of parts to ensure that the new pump is fully installed and operating correctly.

Sincerely,

Brad Anderson  
Plant Manager