
 DEPARTMENT OF ECOLOGY State of Washington	CONSTRUCTION STORMWATER GENERAL PERMIT INSPECTION REPORT State of Washington Department of Ecology		
Section A: General Data			
Ecology Inspector(s): Brian Johnson	On-Site Representative Name: Title: Phone: Email:	Inspection Date and Entry/Exit Time: May 17, 2023, 13:55/14:15 Receiving waters: Curtin Creek	Inspection Type: Unannounced Permit webpage: https://fortress.wa.gov/ecy/paris/FacilitySummary.aspx?FacilityId=60423
Section B: Background			
<p>The Cornerstone Christian Academy project is covered under the State of Washington's Construction Stormwater General Permit (CSWGP). The CSWGP is a National Pollutant Discharge Elimination System (NPDES) and a State Waste Discharge permit for discharge of construction-related stormwater. The purpose of this inspection is to conduct a compliance inspection and to provide technical assistance as appropriate.</p> <p>Ecology arrived on site to conduct a routine CSWGP compliance inspection. Responsible party or their representative were not present at the time of inspection. Site is stabilized.</p> <p>The project appears to be complete. If that is the case, remove the remaining drain inlet protection indicated below and sites adjacent, and submit a Notice of Termination to Ecology.</p> <p>Weather at time of inspection: Sunny Precipitation in the past 24 hours? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No </p>			
Section C: Compliance			
Violations and action required to achieve compliance		Complete or submit date	Guidance
S9.D.11 Maintain BMPs Pull drain inlet protection Failure to meet S9.D.11.b: Permittee must remove all temporary erosion and sediment control BMPs within 30 days after achieving final site stabilization or after the temporary BMPs are no longer needed. Maintain and repair all temporary and permanent BMPs, as set forth in permit condition S9.D.11.a.		Immediately begin. Address the problems no later than 10 days from the date of this inspection.	SWMMWW, Chapter II-3 Construction Stormwater BMPs, C150, C160
<p>For assistance with any of these compliance issues or recommendations regarding BMPs, please see the 2019 Stormwater Management Manual for Western Washington (SWMMWW), Volume II, Construction Stormwater Pollution Prevention which includes BMPs for Source Control and Runoff Conveyance and Treatment BMPs. The full SWMMWW is available at: http://www.ecy.wa.gov/programs/wq/stormwater/manual.html. </p>			

The Department of Ecology has the authority to issue formal enforcement actions including issuance of orders and civil penalties of up to \$10,000 per day per violation for violations of your NPDES permit and/or state laws and regulations.

Noncompliance with the limits, monitoring requirements, terms and/or conditions established in your permit may result in formal enforcement action by the Department of Ecology.

Ecology Inspector (signature):  Date: May 17, 2023
Ecology Inspector (print name): Brian Johnson

Water Quality Program
Southwest Regional Office
PO Box 47775 Olympia, WA 98504-7775
SWRO Tel: 360-407-6300

All photos taken by Brian Johnson

Photo 1

Photo Description: **Southeast corner of Early Childhood Education (ECE) building looking east. Pull drain inlet protection.**



Photo 2

Photo Description: **Southwest corner of ECE building looking south. Pull drain inlet protection.**




Photo 3

Photo Description: **West of ECE building looking south. Pull drain inlet protection.**

