



STATE OF WASHINGTON
DEPARTMENT OF ECOLOGY

1250 West Alder Street • Union Gap, Washington 98903-0009 • (509) 575-2490

February 22, 2024

James Foreman
WP Packing, Inc.
183 Windy Point Drive
Wapato, WA 98951-8811

Sent via email only: james@wp-packing.com

Dear James Foreman:

RE: 2023 Discharge Monitoring Report for WP Packing, Inc.--WAG435161

Ecology has reviewed your 2023 annual discharge monitoring reports (DMR's). The table below summarizes the permit violations found. The purpose of this letter is to provide you an opportunity to review these violations and submit corrections if the records are not accurate.

WAG435161—WP Packing

Outfall No(s).	Parameter	Date	Reported Value	Permit Limit
	Overall DMR—Late ¹			Due by the January 31 st of each year the for the previous calendar year.
001 ²	Total Dissolved Solids, mg/L	01/24/2023	766	500
And	Total Dissolved Solids, mg/L	05/18/2023	659	500
	Total Dissolved Solids, mg/L	08/31/2023	1,300	500
002	Total Dissolved Solids, mg/L	12/27/2023	680	500

¹ I am aware that there were issues getting an ESAF approved. For this reporting, the late violation will be overridden.

² If you have two separate outfalls, you must take two different samples, one from each outfall. You may not use the same results for both outfalls.

Total dissolved solids continue to be an issue at your facility. Please consider operational changes to control these discharge levels. Other than to make any corrections to the table above, no further response from your facility is required.

If you have any questions or concerns, please contact me at 509-406-6624 (cell), or email marcia.porter@ecy.wa.gov.

James Foreman
February 22, 2024
Page 2

Sincerely,

A handwritten signature in cursive script that reads "Marcia Porter".

Marcia Porter
General Permit Manager
Central Region

e.c. Alexis Ledezma, WP Packing, (alexis@wp-packing.com)