



Weekly Geometric Mean											

Reporting Codes Used: B - Below Detection Limit/No Detection, C - No Discharge, FC - Frozen Conditions/Unsafe conditions, M - Monitoring Is Conditional/Not Req This MP

Outfall: 001 - ROCK CREEK

Monitoring Point	Parameter	Sample Date/ Statistical Base	Value	Notes/Comment
001	All Parameters			during week 3 we shut down due to cold weather. we did not drain the uv channel so when we started up the next week and pulled the sample we had high fecal. There was probably left over fecal from the third week in the sampler tubing for week 4 and that is possibly why it was high as well. we double checked our fecal test and are now back down to our normal range. we are usually never above 20.

I certify under penalty of law, that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Paul Sifford

2/15/2024 11:12:29 AM

Signature

Date