



Water Quality Program

Permit Submittal Electronic Certification

Permittee: MARYSVILLE STP

Permit Number: WA0022497

Site Address: 20 COLUMBIA AVE
MARYSVILLE, WA 98270

Submittal Name: Toxicity Acute Compliance Monitoring Report

Version: 1

Due Date: 8/15/2024

Comments:

I certify under penalty of law, that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Jason Crain

8/15/2024 2:51:54 PM

Signature

Date