



November 15, 2024
 Ms. Charlotte Daskalopoulos
 Water Quality Permit Manager
 4601 N. Monroe St.
 Spokane, WA 99205-1295
 RE: Noncompliance Report

Dear Ms. Daskalopoulos,

SGL is submitting this noncompliance report in accordance with Condition S3.F.d for the month of October 2024.

Description of the noncompliance, period of noncompliance, and the cause

Violation	Period of noncompliance	Cause
Flow Daily, Total	October 4, 27, 28	SGL staff is working to find the cause for the high flow values during October. Historically, this has been caused by malfunctioning blowdown valves or overflowing swamp coolers.
Flow Monthly, Average	October 2024	

Steps taken or planned to reduce, eliminate, and prevent recurrence of the non-compliance.

At the time of this report, SGL staff has not yet found the reason for the high daily and monthly average wastewater flows. SGL staff will update Ecology via email once more information is gathered.

Untreated overflow.

The noncompliance does not involve a quantity of untreated overflow, as SGL does not conduct treatment of industrial wastewater.

Please let us know if you have any questions.

Sincerely,
 Dr. Oliver Weinegand
 President – SGL North America