



The Holmes Harbor Sewer District (HHSD) diverted .06 million gallons of wastewater into the onsite off-spec pond in 2024.

There were two diversion events in 2024.

July 11, 2024 HHSD experienced an event that was due to a failed float in the EQ basin.

On December 15, 2024 HHSD experienced regional power outages related to storms.

HHSD SBR was online for 366 days and diverted flows during two of those days.

Chad Clay

Holmes Harbor Sewer District

General Manager

360-331-4636

[sbr@whidbey.com](mailto:sbr@whidbey.com)