



February 17<sup>th</sup>, 2025

Water Quality Permit Coordinator  
State of Washington - Department of Ecology  
Southwest Regional office  
PO Box 47775  
Olympia, WA 98504-7775

RE: Pacific Seafood – Woodland, LLC Permit No. ST0006222 January 2025  
Noncompliance Notification

Dear Sir or Madam,

The discharge monitoring report (DMR) for January 2025 generated one (1) total suspended solids (TSS) daily max exceedance during the reporting period. The violation occurred on the permitted outfall, Outfall 001.

The exceedance was likely caused by improper sanitation of equipment and production areas. In the days leading up to the sampling event, the facility had an increase in sawing activities to further section fish for repacking which led to a build-up of organic material particles on the equipment and floor. Due to the infrequency of this production type's volume, the sanitation team likely did not sufficiently clean the sawing equipment and surrounding area.

To remedy this, the team has since been retrained on sanitation procedures and we do not anticipate future instances of noncompliance.

Please reach out to me if you have any further questions.

Sincerely,

Richard Carlson  
General Manager

A handwritten signature in black ink, appearing to be 'RC', written over a white background.

Pacific Seafood – Woodland, LLC  
T: 360.225.8553  
rcarlson@pacificseafood.com