



Water Quality Program

Permit Submittal Electronic Certification

Permittee: TACOMA RAIL

Permit Number: WAR001318

Site Address: 2601 SR 509 N Frontage Rd
TACOMA, WA 98421

Submittal Name: 2024 Annual Report

Version: 1

Due Date: 5/15/2025

Covers Year: 2024

1. Benchmarks Exceeded

Did you exceed the benchmark for any parameter during the above noted calendar year (Jan 1st – Dec 31st)?

☒ Yes ☐ No

Additional comments:

Refer below.

2. Stormwater Problems Identified at the Facility

Problem Date	Problem Description
--------------	---------------------

3. Corrective Actions Planned or Taken

Turbidity

Benchmark was exceeded during the following quarters:

- ☐ 1st quarter (January, February, March)
- ☐ 2nd quarter (April, May, June)
- ☒ 3rd quarter (July, August, September)
- ☐ 4th quarter (October, November, December)

Completed Actions

☒ Level 1 Corrective Action

Date completed: 10/15/2024

Describe the additional *operational source control* BMPs implemented (Permit Condition S8.B):

A Level 1 Corrective Action was triggered at distinct sample point MH2 in Q3/2024 and completed 10/15/24.
An inspection of the area identified a potential cause for exceedance. To mitigate this potential cause, the following items were removed/replaced: Refreshed secondary media treatment. Additionally, general housekeeping was improved to minimize the accumulation of turbidity.
(Note: Q4 2024 and Q1 2025 – MH2 currently meeting all established Benchmarks)

Pending Actions

No actions needed.

Zinc

Benchmark was exceeded during the following quarters:

- ☐ 1st quarter (January, February, March)
- ☐ 2nd quarter (April, May, June)
- ☐ 3rd quarter (July, August, September)
- ☒ 4th quarter (October, November, December)

Completed Actions

☒ Level 1 Corrective Action

Date completed: 1/15/2025

Describe the additional *operational source control* BMPs implemented (Permit Condition S8.B):

A Level 1 Corrective Action was triggered at distinct sample point CB2 in Q4/2024 and completed 1/15/25.

An inspection of the area identified a potential cause for exceedance. To mitigate this potential cause, the following items were removed/replaced: Refreshed secondary media treatment. Additionally, general housekeeping was improved to minimize the accumulation of turbidity.

(Note: Q1 2025 – CB2 currently meeting all established Benchmarks)

Pending Actions

No actions needed.

I certify under penalty of law, that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

James Bozic

Signature

4/7/2025

Date