



Permit No. WAR000342
Coverage Effective Date: January 1, 2025
Permit Issuance Date: December 1, 2024
Expiration Date: December 31, 2029

**THE INDUSTRIAL STORMWATER GENERAL PERMIT
MONITORING SUMMARY**

Name & Mailing Address

Mike Engel
High Cascade Veneer Inc
2022 Wind River Hwy
Carson, WA 98610

Facility Name & Location

HIGH CASCADE VENEER INC
11 HOME VALLEY PARK RD
CARSON, WA 98610

NAICS Codes Representing Activities
321113, 321212

Monitoring Point Information

<u>Feature Name</u>	<u>Monitoring Point Code</u>	<u>Monitoring Point Description</u>	<u>Latitude/ Longitude</u>	<u>NAICS Code(s)</u>	<u>Outfall Type</u>	<u>Name of Surface Waterbody</u>
D2	D2	BARKER	45.713455 / -121.785568	321113, 321212	Surface Water Body	Lake Bonneville
D4	D4	South Log Yard	45.709141 / -121.782082	321113, 321212	Surface Water Body	Lake Bonneville

Below is a summary of updated monitoring requirements based on the recently reissued ISGP, effective January 1, 2025. Please review this information and contact your permit administrator, Max Graham at gram461@ecy.wa.gov or (564) 200-2505, if you have questions or believe any of this information is incorrect.

Parameter	Unit	Value	Method	Quantitation	Frequency
Feature D4 Monitoring Point D4					
ISGP Western WA - 2025 Permit					
Turbidity	NTU	Benchmark Value: 25	EPA 180.1 Meter	0.5	1/quarter
pH	SU	Benchmark: Between 5 and 9	Calibrated Meter	±0.1	1/quarter
Oil Sheen	Yes / No	No Visible Oil Sheen	N/A	N/A	1/quarter
Copper, Total	µg/L	Benchmark Value: 14	EPA 200.8	2.0	1/quarter
Zinc, Total	µg/L	Benchmark Value: 117	EPA 200.8	2.5	1/quarter

ISGP Timber Product Industry, Paper & Allied Products - 2025 Permit					
COD	mg/L	Benchmark Value: 120	SM5220-D	10	1/quarter
TSS	mg/L	Benchmark Value: 100	SM2540-D	5.0	1/quarter
Feature D2 Monitoring Point D2					
ISGP Western WA - 2025 Permit					
Turbidity	NTU	Benchmark Value: 25	EPA 180.1 Meter	0.5	1/quarter
pH	SU	Benchmark: Between 5 and 9	Calibrated Meter	±0.1	1/quarter
Oil Sheen	Yes / No	No Visible Oil Sheen	N/A	N/A	1/quarter
Copper, Total	µg/L	Benchmark Value: 14	EPA 200.8	2.0	1/quarter
Zinc, Total	µg/L	Benchmark Value: 117	EPA 200.8	2.5	1/quarter
ISGP Timber Product Industry, Paper & Allied Products - 2025 Permit					
COD	mg/L	Benchmark Value: 120	SM5220-D	10	1/quarter
TSS	mg/L	Benchmark Value: 100	SM2540-D	5.0	1/quarter

Please refer to the permit for all of the details and fine print per parameter.



Jeff Killelea, Manager
Permit and Technical Services Section
Water Quality Program